



AACPS - Operations Division
9034 Ft. Smallwood Road

Monday, February 24, 2020

Pasadena, MD 21122

Attention: Chris Williams; Brian Wells

Certificate of Analysis
FINAL

Report for Lab No: 48070.

Brock Bridge ES (3062)

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 9212

Sampling by Martel personnel on January 8, 2020.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
48070 000011	Room 111 Bubbler [DF--C]	01/08/2020 07:35
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.67 ug/l EPA .200.8 2	02/14/2020 10:24 BJ
48070 000025	Room 123 Left Bubbler [DF--C]	01/08/2020 07:40
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	35.9 ug/l* EPA .200.8 2	02/14/2020 10:26 BJ
48070 000042	Open Space Area - Left Bubbler [DF--C]	01/08/2020 07:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	no fixture EPA .200.8 2	//
48070 000051	Instructional Area #0 Drinking Water Fountain [DF--C]	01/08/2020 07:30
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	31.8 ug/l* EPA .200.8 2	02/14/2020 10:29 BJ



Martel Laboratories JDS Inc.

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

AACOP1

Page 2 OF 2

02/24/2020


stdl.frx

Notes and references:

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date. 40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

* results exceeded 20.5 ug/l.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.



Project Manager

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Anne Arundel County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Start Date/Time: 1-8 7:25 End Date/Time: 1-8 7:45

Sampler/Relinquished By: [Signature] Received at Martel by: [Signature] Date/Time: 1-8 11:00

Brock Bridge ES (3062)

405 Brock Bridge Rd, Laurel, MD 20724

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE
SAMPLING BETWEEN THE HOURS OF 8PM AND 9PM

Martel Lab
No. **48070**

Sample #	Room #	Fixture Type <i>(Sink, Bubler, Water Fountain, Gooseneck, Ice</i>	Outlet Key		TIME/NOTES
			Codes	Cor. NC?	
11	Room 111	Bubler	DF	C	7:30
25	Room 123 Left	Bubler	DF	C	7:40
42	Open Space Area Left	Bubler	DF	e	Removed
51	Instructional Area #0	Drinking Water Fountain	DF	C	7:50