



**AACPS - Operations Division**  
9034 Ft. Smallwood Road

Tuesday, July 24, 2018

Pasadena, MD 21122

***Certificate of Analysis***  
**FINAL**

**Attention: Chris Williams**

Report for Lab No: 40019.

Woodside ES (1262) Martel No. 40019.

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 9212

Sampling by Martel personnel on April 17, 2018 - Danny Furman sampler.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40019 000001	Office Bathroom Sink [BS--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 12:01 CSG
40019 000002	Principal's Office Bathroom Sink [BS--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 12:14 CSG
40019 000003	236 Health Room Bathroom Sink [BS--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 12:16 CSG
40019 000004	236 Health Room Eye Wash [OT--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	8.92 ug/l EPA .200.8 2	07/13/2018 12:19 CSG
40019 000005	236 Health Room Sink [NO--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 12:21 CSG
40019 000006	236 Health Room Office Sink [NO--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial



MARTEL NO. 40019      000006      CLIENT SAMPLE IDENTIFICATION 236 Health Room Office Sink [NO--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 12:23 CSG

MARTEL NO. 40019      000007      CLIENT SAMPLE IDENTIFICATION 202 Gooseneck Sink [CR--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 12:26 CSG

MARTEL NO. 40019      000008      CLIENT SAMPLE IDENTIFICATION 202 Bubblers [DF--C]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 12:28 CSG

MARTEL NO. 40019      000009      CLIENT SAMPLE IDENTIFICATION 204 Gooseneck Sink [CR--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 12:31 CSG

MARTEL NO. 40019      000010      CLIENT SAMPLE IDENTIFICATION 204 Bubblers [DF--C]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 12:33 CSG

MARTEL NO. 40019      000011      CLIENT SAMPLE IDENTIFICATION Boys Bathroom (next to rm 204) Hand sink (closest to door)      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 12:44 CSG

MARTEL NO. 40019      000012      CLIENT SAMPLE IDENTIFICATION Boys Bathroom (next to rm 204) Hand sink [BS--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 12:49 CSG

MARTEL NO. 40019      000013      CLIENT SAMPLE IDENTIFICATION Boys Bathroom (next to rm 204) Hand sink [BS--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 12:51 CSG



MARTEL NO. 40019      CLIENT SAMPLE IDENTIFICATION Boys Bathroom (next to rm 204) Hand sink [BS--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 12:54 CSG

MARTEL NO. 40019      CLIENT SAMPLE IDENTIFICATION Boys Bathroom (next to rm 204) Hand sink (farthest from door)      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 12:56 CSG

MARTEL NO. 40019      CLIENT SAMPLE IDENTIFICATION Custodial Closet Sink [OT--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.16	ug/l	EPA .200.8	2	07/13/2018 12:59 CSG

MARTEL NO. 40019      CLIENT SAMPLE IDENTIFICATION Girls Bathroom Hand sink (closest to door) [BS--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 13:01 CSG

MARTEL NO. 40019      CLIENT SAMPLE IDENTIFICATION Girls Bathroom Hand sink [BS--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 13:04 CSG

MARTEL NO. 40019      CLIENT SAMPLE IDENTIFICATION Girls Bathroom Hand sink [BS--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 13:06 CSG

MARTEL NO. 40019      CLIENT SAMPLE IDENTIFICATION Girls Bathroom Hand sink [BS--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 13:09 CSG

MARTEL NO. 40019      CLIENT SAMPLE IDENTIFICATION Girls Bathroom Hand sink (farthest from door) [BS--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 13:16 CSG



MARTEL NO. 40019      000022      206 Gooseneck Sink [CR--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 13:24 CSG

MARTEL NO. 40019      000023      206 Bubbler [DF--C]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 13:26 CSG

MARTEL NO. 40019      000024      208 Gooseneck Sink [CR--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 13:29 CSG

MARTEL NO. 40019      000025      208 Bubbler [DF--C]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 13:31 CSG

MARTEL NO. 40019      000026      210 Gooseneck Sink [CR--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 13:34 CSG

MARTEL NO. 40019      000027      210 Bubbler [DF--C]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.42	ug/l	EPA .200.8	2	07/13/2018 13:36 CSG

MARTEL NO. 40019      000028      Bathroom (next to 212) Hand Sink (closest to door) [BS--N]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.62	ug/l	EPA .200.8	2	07/13/2018 13:39 CSG

MARTEL NO. 40019      000029      Bathroom (next to 212) Hand sink [BS--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 13:41 CSG



MARTEL NO. 40019      000030      CLIENT SAMPLE IDENTIFICATION Bathroom (next to 212) Hand sink [BS--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.25	ug/l	EPA .200.8	2	07/13/2018 13:44 CSG

MARTEL NO. 40019      000031      CLIENT SAMPLE IDENTIFICATION Bathroom (next to 212) Hand sink (farthest from door) [BS--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.29	ug/l	EPA .200.8	2	07/13/2018 13:54 CSG

MARTEL NO. 40019      000032      CLIENT SAMPLE IDENTIFICATION Media Center Office Gooseneck Sink [CR--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 13:59 CSG

MARTEL NO. 40019      000033      CLIENT SAMPLE IDENTIFICATION Media Center Office Bubbler [DF--C]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	19.1	ug/l	EPA .200.8	2	07/13/2018 14:01 CSG

MARTEL NO. 40019      000034      CLIENT SAMPLE IDENTIFICATION 213 Gooseneck Sink [CR--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 14:04 CSG

MARTEL NO. 40019      000035      CLIENT SAMPLE IDENTIFICATION 213 Bubbler [DF--C]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 14:06 CSG

MARTEL NO. 40019      000036      CLIENT SAMPLE IDENTIFICATION 211 Gooseneck Sink [CR--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 14:09 CSG

MARTEL NO. 40019      000037      CLIENT SAMPLE IDENTIFICATION 211 Bubbler [DF--C]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 14:11 CSG



MARTEL NO. 40019      000038      209 Gooseneck Sink [CR--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 14:13 CSG

MARTEL NO. 40019      000039      209 Bubbler [DF--C]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 14:16 CSG

MARTEL NO. 40019      000040      207 Gooseneck Sink [CR--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 14:18 CSG

MARTEL NO. 40019      000041      207 Bubbler [DF--C]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 14:26 CSG

MARTEL NO. 40019      000042      205 Gooseneck Sink [CR--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.13	ug/l	EPA .200.8	2	07/13/2018 14:33 CSG

MARTEL NO. 40019      000043      205 Bubbler [DF--C]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 14:36 CSG

MARTEL NO. 40019      000044      203 Gooseneck Sink [CR--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.60	ug/l	EPA .200.8	2	07/13/2018 14:38 CSG

MARTEL NO. 40019      000045      203 Bubbler [DF--C]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.34	ug/l	EPA .200.8	2	07/13/2018 14:41 CSG



## Certificate of Analysis

MARTEL NO. 40019      000046      201 Gooseneck Sink [CR--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 14:43 CSG

MARTEL NO. 40019      000047      201 Bubbler [DF--C]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 14:46 CSG

MARTEL NO. 40019      000048      Teacher Lounge (Loblolly Pine Path) Gooseneck Sink      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 14:48 CSG

MARTEL NO. 40019      000049      Teacher Lounge (Loblolly Pine Path) Bubbler [DF--C]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.07	ug/l	EPA .200.8	2	07/13/2018 14:51 CSG

MARTEL NO. 40019      000050      Special Classroom (Loblolly Pine Path) Gooseneck Sink [CR-      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 14:53 CSG

MARTEL NO. 40019      000051      Special Classroom (Loblolly Pine Path) Bubbler [DF--C]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 15:03 CSG

MARTEL NO. 40019      000053      Girls Bathroom Hand Sink [BS--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.04	ug/l	EPA .200.8	2	07/13/2018 15:08 CSG

MARTEL NO. 40019      000054      Girls Bathroom Hand sink (farthest from door) [BS--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.07	ug/l	EPA .200.8	2	07/13/2018 15:11 CSG



MARTEL NO. 40019 000055 CLIENT SAMPLE IDENTIFICATION Woman's Bathroom Hand Sink [BS--NC] Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 15:13 CSG

MARTEL NO. 40019 000056 CLIENT SAMPLE IDENTIFICATION Men's Bathroom Hand Sink [BS--NC] Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 15:16 CSG

MARTEL NO. 40019 000057 CLIENT SAMPLE IDENTIFICATION Kitchen Hand Sink [KS--C] Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 15:18 CSG

MARTEL NO. 40019 000058 CLIENT SAMPLE IDENTIFICATION Kitchen Bathroom Hand Sink [BS--NC] Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.61	ug/l	EPA .200.8	2	07/13/2018 15:21 CSG

MARTEL NO. 40019 000059 CLIENT SAMPLE IDENTIFICATION Kitchen Sink on Left (Rinse) [KS--C] Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 15:23 CSG

MARTEL NO. 40019 000060 CLIENT SAMPLE IDENTIFICATION Kitchen Sink on Right (Wash) [KS--C] Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 15:26 CSG

MARTEL NO. 40019 000061 CLIENT SAMPLE IDENTIFICATION Kitchen Sink [KS--C] Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 15:41 CSG

MARTEL NO. 40019 000063 CLIENT SAMPLE IDENTIFICATION Kitchen - Wash Area Sink [KS--C] Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 15:33 CSG





MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40019 000064	Kitchen - Storage Room Sink [KS--C]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	465 ug/l* EPA .200.8 2	07/13/2018 15:43 CSG
40019 000065	Gym Office Rm 250A Hand Sink [OT--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 15:46 CSG
40019 000066	Gym Rm 250B Water fountain (left) [DF--C]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 15:48 CSG
40019 000067	Gym Rm 250B Water fountain (right) [DF--C]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 15:51 CSG
40019 000068	Gym Rm 252 Hand Sink [OT--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 15:53 CSG
40019 000069	Gym Rm 253 Hand Sink [OT--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 15:56 CSG
40019 000070	Bathroom (across from 103) Hand Sink [BS--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 15:58 CSG
40019 000071	Girls Bathroom (across from 109) Hand Sink (closest to door)	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 16:08 CSG



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40019 000072	Girls Bathroom (across from 109) Hand sink (farthest from do	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	5.80 ug/l EPA .200.8 2	07/13/2018 16:13 CSG
40019 000073	Custodial Closet Sink [OT--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.34 ug/l EPA .200.8 2	07/13/2018 16:16 CSG
40019 000074	Boys Bathroom (across from 109) Hand Sink (closest to door)	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 16:18 CSG
40019 000075	Boys Bathroom (across from 109) Hand sink (farthest from doo	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 16:21 CSG
40019 000076	110 Gooseneck Sink [CR--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.88 ug/l EPA .200.8 2	07/13/2018 16:23 CSG
40019 000077	110 Bubbler [DF--C]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.95 ug/l EPA .200.8 2	07/13/2018 16:26 CSG
40019 000078	109 Gooseneck Sink [CR--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 16:28 CSG
40019 000079	109 Bubbler [DF--C]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	4.86 ug/l EPA .200.8 2	07/13/2018 16:31 CSG



# Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40019 000080	108 Gooseneck Sink [CR--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 16:33 CSG
40019 000081	108 Bubbler [DF--C]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	4.62 ug/l EPA .200.8 2	07/13/2018 16:41 CSG
40019 000082	108 Bathroom hand sink [BS--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 16:49 CSG
40019 000083	107 Gooseneck Sink [CR--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 16:51 CSG
40019 000084	107 Bubbler [DF--C]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	6.36 ug/l EPA .200.8 2	07/13/2018 16:54 CSG
40019 000085	107 Bathroom hand sink [BS--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/13/2018 16:56 CSG
40019 000086	106 Gooseneck Sink [CR--NC]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.94 ug/l EPA .200.8 2	07/13/2018 16:59 CSG
40019 000087	106 Bubbler [DF--C]	04/17/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.40 ug/l EPA .200.8 2	07/13/2018 17:01 CSG



## Certificate of Analysis

MARTEL NO. 40019 000088 CLIENT SAMPLE IDENTIFICATION 106 Bathroom hand sink [BS--NC] Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	89.7	ug/l*	EPA .200.8	2	07/13/2018 17:04 CSG

MARTEL NO. 40019 000089 CLIENT SAMPLE IDENTIFICATION 127 Custodial Closet Sink [OT--NC] Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 17:06 CSG

MARTEL NO. 40019 000090 CLIENT SAMPLE IDENTIFICATION 129 Gooseneck Sink [CR--NC] Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 17:09 CSG

MARTEL NO. 40019 000091 CLIENT SAMPLE IDENTIFICATION 129 Bubbler [DF--C] Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 17:19 CSG

MARTEL NO. 40019 000092 CLIENT SAMPLE IDENTIFICATION 129 Bathroom hand sink [BS--NC] Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 17:24 CSG

MARTEL NO. 40019 000093 CLIENT SAMPLE IDENTIFICATION 131 Gooseneck Sink [CR--NC] Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 17:26 CSG

MARTEL NO. 40019 000094 CLIENT SAMPLE IDENTIFICATION 131 Bubbler [DF--C] Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 17:29 CSG

MARTEL NO. 40019 000095 CLIENT SAMPLE IDENTIFICATION 131 Bathroom hand sink [BS--NC] Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 17:31 CSG



# Certificate of Analysis

MARTEL NO. 40019      000096      130 Gooseneck Sink [CR--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 17:34 CSG

MARTEL NO. 40019      000097      130 Bubblers [DF--C]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 17:36 CSG

MARTEL NO. 40019      000098      130 Bathroom hand sink [BS--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 17:39 CSG

MARTEL NO. 40019      000099      128 Gooseneck Sink [CR--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 17:41 CSG

MARTEL NO. 40019      000100      128 Bubblers [DF--C]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 17:44 CSG

MARTEL NO. 40019      000101      128 Bathroom hand sink [BS--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 17:51 CSG

MARTEL NO. 40019      000102      105 Gooseneck Sink [CR--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 17:59 CSG

MARTEL NO. 40019      000103      105 Bubblers [DF--C]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 18:02 CSG



MARTEL NO. 40019      000104      CLIENT SAMPLE IDENTIFICATION 105 Bathroom hand sink [BS--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 18:04 CSG

MARTEL NO. 40019      000105      CLIENT SAMPLE IDENTIFICATION 104 Gooseneck Sink [CR--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.20	ug/l	EPA .200.8	2	07/13/2018 18:07 CSG

MARTEL NO. 40019      000106      CLIENT SAMPLE IDENTIFICATION 104 Bubbler [DF--C]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 18:09 CSG

MARTEL NO. 40019      000107      CLIENT SAMPLE IDENTIFICATION 104 Bathroom hand sink [BS--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 18:12 CSG

MARTEL NO. 40019      000108      CLIENT SAMPLE IDENTIFICATION 103 Gooseneck Sink [CR--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.76	ug/l	EPA .200.8	2	07/13/2018 18:14 CSG

MARTEL NO. 40019      000109      CLIENT SAMPLE IDENTIFICATION 103 Bubbler [DF--C]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 18:17 CSG

MARTEL NO. 40019      000110      CLIENT SAMPLE IDENTIFICATION 103 Bathroom hand sink [BS--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 18:19 CSG

MARTEL NO. 40019      000111      CLIENT SAMPLE IDENTIFICATION 102 Gooseneck Sink [CR--NC]      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 18:29 CSG



MARTEL NO. 40019      000112      102 Bubbler [DF--C]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 18:34 CSG

MARTEL NO. 40019      000113      102 bathroom hand sink [BS--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 18:37 CSG

MARTEL NO. 40019      000114      101 Gooseneck Sink [CR--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.33	ug/l	EPA .200.8	2	07/13/2018 18:39 CSG

MARTEL NO. 40019      000115      101 Bubbler [DF--C]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 18:42 CSG

MARTEL NO. 40019      000116      101 bathroom hand sink [BS--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.31	ug/l	EPA .200.8	2	07/13/2018 18:44 CSG

MARTEL NO. 40019      000117      Custodial Closet Sink [OT--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 18:47 CSG

MARTEL NO. 40019      000118      Physical Edu Office Hand sink [OT--NC]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 18:49 CSG

MARTEL NO. 40019      000119      main hall (outside of main office) Drinking fountain [DF--]      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 04/17/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/13/2018 18:52 CSG



---

**Martel Laboratories JDS Inc.**

1025 Cromwell Bridge Road - Baltimore, Maryland 21286  
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

AACOP1

Page 16 OF 16  
07/24/2018  
stdl.frx

---

**Notes and references:**

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date. 40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

\* results exceeded 20.5 ug/l.

All samples tested were in acceptable condition, unless otherwise noted.  
The results presented herein relate only to the samples or items tested.

---

Project Manager



# MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

## Anne Arundel County Public Schools Drinking Water Lead Testing

Sample Date/Start Time: 4/17/18 500

End time: 700

Bottle Type/Preservative: 250 ml plastic/HNO3

Analysis: Lead (EPA 200.8)

Samples preserved properly Yes or No

NOTES:

Sampled/Relinquished by: [Signature]

Received at Martel by: [Signature]

Date/Time: 4/17/18 10 AM

**Woodside ES (1262) Martel No. 40019**

160 Funke Road, Glen Burnie, MD 21061

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE  
SAMPLING BETWEEN THE HOURS OF 8PM AND 9PM**

Sample #	Room #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb, etc.)	Key	Con sum ptio n
1	Office Bathroom	Sink	BS	NC
2	Principal's Office Bathroom	Sink	BS	NC
3	236 Health Room Bathroom	Sink	BS	NC
4	236 Health Room	Eye Wash	OT	NC
5	236 Health Room	Sink	NO	NC
6	236 Health Room Office	Sink	NO	NC
7	202	Gooseneck Sink	CR	NC
8	202	Bubbler	DF	C
9	204	Gooseneck Sink	CR	NC
10	204	Bubbler	DF	C
11	Boys Bathroom (next to rm 204)	Hand sink (closest to door)	BS	NC
12	Boys Bathroom (next to rm 204)	Hand sink	BS	NC
13	Boys Bathroom (next to rm 204)	Hand sink	BS	NC
14	Boys Bathroom (next to rm 204)	Hand sink	BS	NC
15	Boys Bathroom (next to rm 204)	Hand sink (farthest from door)	BS	NC
16	Custodial Closet	Sink <del>X</del>	OT	NC
17	Girls Bathroom	Hand sink (closest to door)	BS	NC
18	Girls Bathroom	Hand sink	BS	NC
19	Girls Bathroom	Hand sink	BS	NC
20	Girls Bathroom	Hand sink	BS	NC
21	Girls Bathroom	Hand sink (farthest from door)	BS	NC
22	206	Gooseneck Sink	CR	NC
23	206	Bubbler	DF	C
24	208	Gooseneck Sink	CR	NC
25	208	Bubbler	DF	C
26	210	Gooseneck Sink	CR	NC
27	210	Bubbler	DF	C
28	Bathroom (next to 212)	Hand Sink (closest to door)	BS	NC

**Woodside ES (1262) Martel No. 40019**

**160 Funke Road, Glen Burnie, MD 21061**

29	Bathroom (next to 212)	Hand sink	BS	NC
30	Bathroom (next to 212)	Hand sink	BS	NC
31	Bathroom (next to 212)	Hand sink (farthest from door)	BS	NC
32	Media Center Office	Gooseneck Sink	CR	NC
33	Media Center Office	Bubbler	DF	C
34	213	Gooseneck Sink	CR	NC
35	213	Bubbler	DF	C
36	211	Gooseneck Sink	CR	NC
37	211	Bubbler	DF	C
38	209	Gooseneck Sink	CR	NC
39	209	Bubbler	DF	C
40	207	Gooseneck Sink	CR	NC
41	207	Bubbler	DF	C
42	205	Gooseneck Sink	CR	NC
43	205	Bubbler	DF	C
44	203	Gooseneck Sink	CR	NC
45	203	Bubbler	DF	C
46	201	Gooseneck Sink	CR	NC
47	201	Bubbler	DF	C
48	Teacher Lounge (Loblolly Pine Path)	Gooseneck Sink	CR	NC
49	Teacher Lounge (Loblolly Pine Path)	Bubbler	DF	C
50	Special Classroom (Loblolly Pine Path)	Gooseneck Sink	CR	NC
51	Special Classroom (Loblolly Pine Path)	Bubbler	DF	C
52	Girls Bathroom	Hand Sink (closest to door)	BS	NC
53	Girls Bathroom	Hand Sink	BS	NC
54	Girls Bathroom	Hand sink (farthest from door)	BS	NC
55	Woman's Bathroom	Hand Sink	BS	NC
56	Men's Bathroom	Hand Sink	BS	NC
57	Kitchen	Hand Sink	KS	C
58	Kitchen Bathroom	Hand Sink	BS	NC
59	Kitchen	Sink on Left (Rinse)	KS	C
60	Kitchen	Sink on Right (Wash)	KS	C
61	Kitchen	Sink <i>fell/spilled</i>	KS	C
62	Kitchen - Wash Area	Hose	KS	C
63	Kitchen - Wash Area	Sink	KS	C
64	Kitchen - Storage Room	Sink	KS	C
65	Gym Office Rm 250A	Hand Sink	OT	NC
66	Gym Rm 250B	Water fountain (left)	DF	C

**Woodside ES (1262) Martel No. 40019**

160 Funke Road, Glen Burnie, MD 21061

67	Gym Rm 250B	Water fountain (right) <i>Fell/spilled</i>	DF	C
68	Gym Rm 252	Hand Sink <i>Fell/spilled</i>	OT	NC
69	Gym Rm 253	Hand Sink	OT	NC
70	Bathroom (across from 103)	Hand Sink	BS	NC
71	Girls Bathroom (across from 109)	Hand Sink (closest to door)	BS	NC
72	Girls Bathroom (across from 109)	Hand sink (farthest from door)	BS	NC
73	Custodial Closet	Sink	OT	NC
74	Boys Bathroom (across from 109)	Hand Sink (closest to door)	BS	NC
75	Boys Bathroom (across from 109)	Hand sink (farthest from door)	BS	NC
76	110	Gooseneck Sink	CR	NC
77	110	Bubbler	DF	C
78	109	Gooseneck Sink	CR	NC
79	109	Bubbler	DF	C
80	108	Gooseneck Sink	CR	NC
81	108	Bubbler	DF	C
82	108 Bathroom	hand sink	BS	NC
83	107	Gooseneck Sink	CR	NC
84	107	Bubbler	DF	C
85	107 Bathroom	hand sink	BS	NC
86	106	Gooseneck Sink	CR	NC
87	106	Bubbler	DF	C
88	106 Bathroom	hand sink	BS	NC
89	127 Custodial Closet	Sink <i>X</i>	OT	NC
90	129	Gooseneck Sink	CR	NC
91	129	Bubbler	DF	C
92	129 Bathroom	hand sink	BS	NC
93	131	Gooseneck Sink	CR	NC
94	131	Bubbler	DF	C
95	131 Bathroom	hand sink	BS	NC
96	130	Gooseneck Sink	CR	NC
97	130	Bubbler	DF	C
98	130 Bathroom	hand sink	BS	NC
99	128	Gooseneck Sink	CR	NC
100	128	Bubbler	DF	C
101	128 Bathroom	hand sink	BS	NC
102	105	Gooseneck Sink	CR	NC
103	105	Bubbler	DF	C
104	105 Bathroom	hand sink	BS	NC

**Woodside ES (1262) Martel No. 40019**

160 Funke Road, Glen Burnie, MD 21061

105	104	Gooseneck Sink	CR	NC
106	104	Bubbler	DF	C
107	104 Bathroom	hand sink	BS	NC
108	103	Gooseneck Sink	CR	NC
109	103	Bubbler	DF	C
110	103 Bathroom	hand sink	BS	NC
111	102	Gooseneck Sink	CR	NC
112	102	Bubbler	DF	C
113	102 bathroom	hand sink	BS	NC
114	101	Gooseneck Sink	CR	NC
115	101	Bubbler	DF	C
116	101 bathroom	hand sink	BS	NC
117	Custodial Closet	Sink	OT	NC
118	Physical Edu Office	Hand sink	OT	NC
119	main hall (outside of main office)	Drinking fountain	DF	C
120	Outside (See Map)	Hose Bibb	OT	NC
121	Outside (See Map)	Hose Bibb	OT	NC
122	Outside (See Map)	Hose Bibb	OT	NC
123	Outside (See Map)	Hose Bibb	OT	NC
124	Outside (See Map)	Hose Bibb	OT	NC
125	Outside (See Map)	Hose Bibb	OT	NC
126	Outside (See Map)	Hose Bibb	OT	NC
127	Outside (See Map)	Hose Bibb	OT	NC
128	Outside (See Map)	Hose Bibb	OT	NC

~~129~~ ~~cafeteria water fountain~~ N/F *g*

*9 HB  
- 2 scoop  
+ 1*