

**AACPS RETESTING OF "CRITICAL OUTLETS," TESTING OF CONCESSION AREAS, TEAM ROOMS AND
NEW ADDITIONS (CONSUMABLE AND NON-CONSUMABLE OUTLETS) AT SCHOOLS**

School	Number of Outlets Tested	Number of Outlets Not Elevated	Number of Total Outlets Elevated	Number of Consumable Outlets Elevated
Annapolis Middle School	1	1	0	0
Arundel High School (Concession)	3	3	0	0
Bates Middle	1	1	0	0
Broadneck High (Concession)	7	7	0	0
Brock Bridge Elementary	15	14	1	1
Ctr of Applied Technology South	1	1	0	0
Central Special	1	1	0	0
Chesapeake Bay Middle	1	0	1	1
Chesapeake High (Concession)	7	6	1	1
Crofton Middle	1	1	0	0
Davidsonville Elementary	1	1	0	0
Glen Burnie High	2	1	1	1
J. Albert Adams Academy	1	1	0	0
Lake Shore Elementary	1	1	0	0
Magothy River Middle	1	1	0	0
Marley Elementary (Addition)	13	13	0	0
Marley Middle	1	1	0	0
Meade High (Concession)	10	10	0	0
Northeast High	1	1	0	0
Park Elementary (Addition)	18	18	0	0
Rippling Woods Elementary	1	0	1	1
Ruth Parker Eason School	1	1	0	0
Severn Elementary	1	1	0	0
Severn River Middle	1	0	1	1
Severna Park High (Concession)	34	34	0	0
Severna Park Middle	2	1	1	1
South River High	1	1	0	0
TOTAL TO DATE	128	121	7	7
PERCENT OF TESTED OUTLETS WITHOUT ELEVATED LEAD LEVELS				94.53%
PERCENT OF TESTED OUTLETS WITH ELEVATED LEAD LEVELS				5.47%
PERCENT OF TESTED OUTLETS WITH CONSUMABLE WATER AND ELEVATED LEAD LEVELS				5.47%

Source: AACPS Facilities Division