



AACPS - Operations Division
9034 Ft. Smallwood Road

Monday, April 16, 2018

Pasadena, CA 21222

Attention: Chris Williams/Brian Wells

Certificate of Analysis
FINAL

Report for Lab No: 40001. School: Belle Grove ES (1082)

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 9212

Sampling by Martel personnel on March 16, 2018, by Lauren Couch, Patrick Shannon, Joe Wolfkill.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40001 000001	Gym Water Fountain (LEFT)	03/16/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA 200.8 2	04/04/2018 15:10 BJ
40001 000002	Gym Water Fountain (RIGHT)	03/16/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.00 ug/l EPA 200.8 2	04/04/2018 15:22 BJ
40001 000003	Gym Bathroom 100B Hand Sink	03/16/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA 200.8 2	04/04/2018 15:25 BJ
40001 000004	Gym Bathroom 100D Hand Sink	03/16/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA 200.8 2	04/04/2018 15:27 BJ
40001 000005	Gym Office 100 G Gooseneck	03/16/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	5.97 ug/l EPA 200.8 2	04/04/2018 15:30 BJ
40001 000006	Kitchen (behind serves line) Hand Sink	03/16/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.10 ug/l EPA 200.8 2	04/04/2018 15:32 BJ



MARTEL NO. 40001 000007 Kitchen 104F Slop Sink CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 15:35 BJ

MARTEL NO. 40001 000008 Kitchen Bathroom Hand Sink CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.38	ug/l	EPA 200.8	2	04/04/2018 15:37 BJ

MARTEL NO. 40001 000009 Kitchen (rear) Gooseneck (LEFT) CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 15:40 BJ

MARTEL NO. 40001 000010 Kitchen (rear) Gooseneck (CENTER) CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 15:42 BJ

MARTEL NO. 40001 000011 Kitchen (rear) Gooseneck (RIGHT) CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 15:52 BJ

MARTEL NO. 40001 000012 Kitchen (right) Gooseneck CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.79	ug/l	EPA 200.8	2	04/04/2018 15:57 BJ

MARTEL NO. 40001 000013 123 Music Bathroom Hand Sink CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:00 BJ

MARTEL NO. 40001 000014 123 Music Bubblers CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:02 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time		
40001	000015	123 Music Hand Sink	03/16/2018 05:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:05 BJ
40001	000016	112 Resource Bubblers	03/16/2018 05:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:07 BJ
40001	000017	112 Resource Hand Sink	03/16/2018 05:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:10 BJ
40001	000018	114 Resource Bubblers	03/16/2018 05:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:12 BJ
40001	000019	114 Resource Hand Sink	03/16/2018 05:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:14 BJ
40001	000020	116 Resource Bathroom Hand Sink	03/16/2018 05:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:17 BJ
40001	000021	116 Bubblers	03/16/2018 05:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:25 BJ
40001	000022	116 Hand Sink	03/16/2018 05:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:32 BJ



MARTEL NO. 40001 000023 118 Hand Sink CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:34 BJ

MARTEL NO. 40001 000024 118 Bubblers CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:37 BJ

MARTEL NO. 40001 000025 118 Bathroom Hand Sink CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:39 BJ

MARTEL NO. 40001 000026 120 Bubblers CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:42 BJ

MARTEL NO. 40001 000027 120 Hand Sink CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:44 BJ

MARTEL NO. 40001 000028 120 Bathroom Hand Sink CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:47 BJ

MARTEL NO. 40001 000029 124 Bathroom Hand Sink CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:49 BJ

MARTEL NO. 40001 000030 124 Bubblers CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 16:52 BJ



MARTEL NO. 40001 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000031 124 Hand Sink 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 17:01 BJ

MARTEL NO. 40001 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000032 126 Bathroom Hand Sink 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 17:06 BJ

MARTEL NO. 40001 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000033 126 Hand Sink 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.09	ug/l	EPA 200.8	2	04/04/2018 17:09 BJ

MARTEL NO. 40001 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000034 126 Bubblers 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 17:11 BJ

MARTEL NO. 40001 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000035 128 Bathroom Hand Sink 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 17:14 BJ

MARTEL NO. 40001 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000036 128 Bubblers 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 17:16 BJ

MARTEL NO. 40001 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000037 128 Hand Sink 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 17:19 BJ

MARTEL NO. 40001 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000038 130 Bathroom Hand Sink 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 17:21 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time		
40001	000039	130 Hand Sink	03/16/2018 05:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 17:24 BJ
40001	000040	130 Bubblers	03/16/2018 05:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2*	ug/l	EPA 200.8	2	04/04/2018 17:26 BJ
40001	000041	134 Bathroom Hand Sink	03/16/2018 05:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 17:33 BJ
40001	000042	134 Bubblers	03/16/2018 05:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 17:41 BJ
40001	000043	134 Hand Sink	03/16/2018 05:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 17:43 BJ
40001	000044	136 Bathroom Hand Sink	03/16/2018 05:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	35.5**	ug/l	EPA 200.8	2	04/04/2018 17:46 BJ
40001	000045	136 Bubblers	03/16/2018 05:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 17:48 BJ
40001	000046	136 Hand Sink	03/16/2018 05:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 17:51 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
40001	000047	138 Bubbler		03/16/2018 05:00	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 17:53 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
40001	000048	138 Hand Sink		03/16/2018 05:00	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.35	ug/l	EPA 200.8	2	04/04/2018 17:56 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
40001	000049	138 Bathroom Hand Sink		03/16/2018 05:00	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 17:58 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
40001	000050	140 Bathroom Hand Sink		03/16/2018 05:00	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 18:00 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
40001	000051	140 Bubbler		03/16/2018 05:00	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 18:10 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
40001	000052	140 Hand Sink		03/16/2018 05:00	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 18:15 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
40001	000053	Bathroom (across from 157) Hand Sink		03/16/2018 05:00	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	14.9	ug/l	EPA 200.8	2	04/04/2018 18:18 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION			Sample Date/Time	
40001	000054	144 Bubbler		03/16/2018 05:00	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 18:20 BJ



Certificate of Analysis

MARTEL NO. 40001 000055 144 Hand Slnk CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 18:23 BJ

MARTEL NO. 40001 000056 144 Bathroom Hand Slnk CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 18:25 BJ

MARTEL NO. 40001 000057 159 Bubblers CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 18:28 BJ

MARTEL NO. 40001 000058 159 Hand Slnk CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 18:30 BJ

MARTEL NO. 40001 000059 159 Bathroom Hand Slnk CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 18:33 BJ

MARTEL NO. 40001 000060 157 Custodial Closet Slop Slnk CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 18:35 BJ

MARTEL NO. 40001 000061 155 Hand Slnk CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 18:50 BJ

MARTEL NO. 40001 000062 155 Bubblers CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 18:57 BJ



Certificate of Analysis

MARTEL NO. 40001 000063 155 Bathroom Hand Sink CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 19:00 BJ

MARTEL NO. 40001 000064 153 Bathroom Hand Sink CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 19:02 BJ

MARTEL NO. 40001 000065 153 Bubblers CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 19:05 BJ

MARTEL NO. 40001 000066 153 Hand Sink CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 19:07 BJ

MARTEL NO. 40001 000067 149 Bubblers CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.40	ug/l	EPA 200.8	2	04/04/2018 19:10 BJ

MARTEL NO. 40001 000068 149 Hand Sink CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.80	ug/l	EPA 200.8	2	04/04/2018 19:12 BJ

MARTEL NO. 40001 000069 145 Hand Sink (RIGHT) CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 19:15 BJ

MARTEL NO. 40001 000070 145 Bubblers (RIGHT) CLIENT SAMPLE IDENTIFICATION Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 19:17 BJ



Certificate of Analysis

MARTEL NO. 40001 000071 CLIENT SAMPLE IDENTIFICATION 145 Hand Sink (LEFT) Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 19:27 BJ

MARTEL NO. 40001 000072 CLIENT SAMPLE IDENTIFICATION 145 Bubbler (LEFT) Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 19:32 BJ

MARTEL NO. 40001 000073 CLIENT SAMPLE IDENTIFICATION 145 Bathroom Hand Sink Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 19:35 BJ

MARTEL NO. 40001 000074 CLIENT SAMPLE IDENTIFICATION 145 Eye Wash Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	23.4**	ug/l	EPA 200.8	2	04/04/2018 19:37 BJ

MARTEL NO. 40001 000075 CLIENT SAMPLE IDENTIFICATION 141 Bathroom Hand Sink Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 19:40 BJ

MARTEL NO. 40001 000076 CLIENT SAMPLE IDENTIFICATION 141 Gooseneck Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.37	ug/l	EPA 200.8	2	04/04/2018 19:42 BJ

MARTEL NO. 40001 000077 CLIENT SAMPLE IDENTIFICATION 141 Bubbler Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 19:44 BJ

MARTEL NO. 40001 000078 CLIENT SAMPLE IDENTIFICATION 141 Hand Sink Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 19:47 BJ



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40001	000079	139 Bubbler			03/16/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 19:49 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40001	000080	139 Hand Sink			03/16/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 19:52 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40001	000081	137 Hand Sink			03/16/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.22	ug/l	EPA 200.8	2	04/04/2018 19:59 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40001	000082	137 Bubbler			03/16/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 20:07 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40001	000083	135 Staff Lounge Hand Sink			03/16/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 20:09 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40001	000084	Bathroom (across from 122) Hand Sink			03/16/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 20:12 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40001	000085	119 B Media Work Room Hand Sink			03/16/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 20:14 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40001	000086	Media Bathroom Hand Sink			03/16/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 20:17 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40001 000087	Bathroom (across from 108 Boys) Hand Sink (LEFT)	03/16/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA 200.8 2	04/04/2018 20:19 BJ
40001 000088	Bathroom (across from 108 Boys) Hand Sink (RIGHT)	03/16/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA 200.8 2	04/04/2018 20:22 BJ
40001 000089	Girls Bathroom (next to boys) Hand Sink (LEFT)	03/16/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA 200.8 2	04/04/2018 20:24 BJ
40001 000090	Girls Bathroom (next to boys) Hand Sink (RIGHT)	03/16/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA 200.8 2	04/04/2018 20:27 BJ
40001 000091	115 Custodial Closet Slop Sink	03/16/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA 200.8 2	04/04/2018 20:37 BJ
40001 000092	Hallway (outside of gym) Water Fountain (LEFT)	03/16/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA 200.8 2	04/04/2018 20:42 BJ
40001 000093	Hallway (outside of gym) Water Fountain (RIGHT)	03/16/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA 200.8 2	04/04/2018 20:44 BJ
40001 000094	Health Room Eye Wash	03/16/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	14.0 ug/l EPA 200.8 2	04/04/2018 20:47 BJ



Certificate of Analysis

MARTEL NO. 40001 000095 CLIENT SAMPLE IDENTIFICATION Health Room Hand Sink Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 20:49 BJ

MARTEL NO. 40001 000096 CLIENT SAMPLE IDENTIFICATION Health Room Bathroom Hand Sink Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 20:52 BJ

MARTEL NO. 40001 000097 CLIENT SAMPLE IDENTIFICATION 107 Nurse Office Hand Sink Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 20:54 BJ

MARTEL NO. 40001 000098 CLIENT SAMPLE IDENTIFICATION 101 Office Hand Sink Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 20:57 BJ

MARTEL NO. 40001 000099 CLIENT SAMPLE IDENTIFICATION 101 Office Bathroom Hand Sink Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 20:59 BJ

MARTEL NO. 40001 000100 CLIENT SAMPLE IDENTIFICATION Office Bathroom (near 101F Storage) Hand Sink Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.41	ug/l	EPA 200.8	2	04/04/2018 21:01 BJ

MARTEL NO. 40001 000101 CLIENT SAMPLE IDENTIFICATION 101 Conference Hand Sink Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/04/2018 21:16 BJ

MARTEL NO. 40001 000102 CLIENT SAMPLE IDENTIFICATION Outside (see map) Hose Bibb Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	26.2**	ug/l	EPA 200.8	2	04/04/2018 21:24 BJ



Certificate of Analysis

MARTEL NO. 40001 000103 CLIENT SAMPLE IDENTIFICATION Outside (see map) Hose Bibb Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	20.1**	ug/l	EPA 200.8	2	04/04/2018 21:26 BJ

MARTEL NO. 40001 000104 CLIENT SAMPLE IDENTIFICATION Outside (see map) Hose Bibb Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA 200.8	2	/ /

MARTEL NO. 40001 000105 CLIENT SAMPLE IDENTIFICATION Outside (see map) Hose Bibb Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	30.6**	ug/l	EPA 200.8	2	04/04/2018 21:29 BJ

MARTEL NO. 40001 000106 CLIENT SAMPLE IDENTIFICATION Outside (see map) Hose Bibb Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	15.2	ug/l	EPA 200.8	2	04/04/2018 21:31 BJ

MARTEL NO. 40001 000107 CLIENT SAMPLE IDENTIFICATION Outside (see map) Hose Bibb Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	42.9***	ug/l	EPA 200.8	2	04/04/2018 21:34 BJ

MARTEL NO. 40001 000108 CLIENT SAMPLE IDENTIFICATION Outside (see map) Hose Bibb Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA 200.8	2	/ /

MARTEL NO. 40001 000109 CLIENT SAMPLE IDENTIFICATION Outside (see map) Hose Bibb Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	49.8**	ug/l	EPA 200.8	2	04/04/2018 21:36 BJ

MARTEL NO. 40001 000110 CLIENT SAMPLE IDENTIFICATION Outside (see map) Hose Bibb Sample Date/Time 03/16/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	24.5**	ug/l	EPA 200.8	2	04/04/2018 21:39 BJ



MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
40001	000111	Outside (see map) Hose Bibb				03/16/2018 05:00	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	18.4	ug/l	EPA 200.8	2	04/04/2018 21:41 BJ		

Page 15 OF 15

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

stddl.frx

Notes and references:

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date. 40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

- * - fixture broken but sample obtained
- ** - result exceeds 20 ug/l (ppb).
- *** - result exceeds 20 ug/l (ppb), redigestion.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, martel@martellabs.com

AACPS Drinking Water Lead Testing

SHANNON
WOODRUFF
COUCH

Sample Date/Start Time: 3/16/18 0704

End time: 0650

Bottle Type/Preservative: 250 ml plastic/HNO3 Analysis: Lead (EPA 200.8)

Samples preserved: Yes or No

NOTES:

Sampled/Relinquished by: [Signature]

Received at Martel by: 3/16/18 750 [Signature]

Date/Time: 3/16/18 7:30

Belle Grove ES (1082)

4502 Belle Grove Road, Baltimore, MD 21225

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE
SAMPLING BETWEEN THE HOURS OF 8PM AND 9PM**

Sample #	Room #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb, etc.)
1	Gym	Water Fountain (LEFT)
2	Gym	Water Fountain (RIGHT)
3	Gym Bathroom 100B	Hand Sink
4	Gym Bathroom 100D	Hand Sink
5	Gym Office 100 G	Gooseneck
6	Kitchen (behind serves line)	Hand Sink
7	Kitchen 104F	Slop Sink
8	Kitchen Bathroom	Hand Sink
9	Kitchen (rear)	Gooseneck (LEFT)
10	Kitchen (rear)	Gooseneck (CENTER)
11	Kitchen (rear)	Gooseneck (RIGHT)
12	Kitchen (right)	Gooseneck
13	123 Music Bathroom	Hand Sink
14	123 Music	Bubbler
15	123 Music	Hand Sink
16	112 Resource	Bubbler
17	112 Resource	Hand Sink
18	114 Resource	Bubbler
19	114 Resource	Hand Sink
20	116 Resource Bathroom	Hand Sink
21	116	Bubbler
22	116	Hand Sink
23	118	Hand Sink
24	118	Bubbler
25	118 Bathroom	Hand Sink
26	120	Bubbler
27	120	Hand Sink
28	120 Bathroom	Hand Sink
29	124 Bathroom	Hand Sink
30	124	Bubbler
31	124	Hand Sink
32	126 Bathroom	Hand Sink
33	126	Hand Sink
34	126	Bubbler
35	128 Bathroom	Hand Sink
36	128	Bubbler
37	128	Hand Sink
38	130 Bathroom	Hand Sink
39	130	Hand Sink
40	130	Bubbler (Broken)
41	134 Bathroom	Hand Sink

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, martel@martellabs.com

AACPS Drinking Water Lead Testing

Belle Grove ES (1082)

42	134	Bubbler
43	134	Hand Sink
44	136 Bathroom	Hand Sink
45	136	Bubbler
46	136	Hand Sink
47	138	Bubbler
48	138	Hand Sink
49	138 Bathroom	Hand Sink
50	140 Bathroom	Hand Sink
51	140	Bubbler
52	140	Hand Sink
53	Bathroom (across from 157)	Hand Sink
54	144	Bubbler
55	144	Hand Sink
56	144 Bathroom	Hand Sink
57	159	Bubbler
58	159	Hand Sink
59	159 Bathroom	Hand Sink
60	157 Custodial Closet	Slop Sink
61	155	Hand Sink
62	155	Bubbler
63	155 Bathroom	Hand Sink
64	153 Bathroom	Hand Sink
65	153	Bubbler
66	153	Hand Sink
67	149	Bubbler
68	149	Hand Sink
69	145	Hand Sink (RIGHT)
70	145	Bubbler (RIGHT)
71	145	Hand Sink (LEFT)
72	145	Bubbler (LEFT)
73	145 Bathroom	Hand Sink
74	145	Eye Wash
75	141 Bathroom	Hand Sink
76	141	Gooseneck
77	141	Bubbler
78	141	Hand Sink
79	139	Bubbler
80	139	Hand Sink
81	137	Hand Sink
82	137	Bubbler
83	135 Staff Lounge	Hand Sink
84	Bathroom (across from 122)	Hand Sink
85	119 B Media Work Room	Hand Sink
86	Media Bathroom	Hand Sink
87	Bathroom (across from 108 Boys)	Hand Sink (LEFT)
88	Bathroom (across from 108 Boys)	Hand Sink (RIGHT)
89	Girls Bathroom (next to boys)	Hand Sink (LEFT)
90	Girls Bathroom (next to boys)	Hand Sink (RIGHT)
91	115 Custodial Closet	Slop Sink
92	Hallway (outside of gym)	Water Fountain (LEFT)
93	Hallway (outside of gym)	Water Fountain (RIGHT)
94	Health Room	Eye Wash
95	Health Room	Hand Sink
96	Health Room Bathroom	Hand Sink
97	107 Nurse Office	Hand Sink
98	101 Office	Hand Sink

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, martel@martellabs.com

AACPS Drinking Water Lead Testing

Belle Grove ES (1082)

99	101 Office Bathroom		Hand Sink
100	Office Bathroom (near 101F Storage)		Hand Sink
101	101 Conference		Hand Sink
102	Outside (see map)		Hose Bibb
103	Outside (see map)		Hose Bibb
104	Outside (see map)	N/F	Hose Bibb
105	Outside (see map)		Hose Bibb
106	Outside (see map)		Hose Bibb
107	Outside (see map)		Hose Bibb
108	Outside (see map)	N/F	Hose Bibb
109	Outside (see map)		Hose Bibb
110	Outside (see map)		Hose Bibb
111	Outside (see map)		Hose Bibb

