

# Lead in Drinking Water – Public and Nonpublic Schools

## **IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT(S)** **Brooklyn Park Elementary School**

### **ELEVATED LEAD WATER SAMPLE RESULT(S)**

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On March 20, 2018, **one hundred sixteen (116)** lead water samples were collected from **Brooklyn Park Elementary School**. Of these lead water samples, twenty-three (**23**) had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings. The elevated lead results from the sample(s) collected at Brooklyn Park Elementary School were as follows: (see attached map)

Sample No.000004-54.7 ppb: Kindergarten Bathroom Hand Sink (non-consumable).  
Sample No.000010-24.8 ppb: Kindergarten 3 Bathroom Hand Sink (non-consumable).  
Sample No. 000015-856 ppb: Boys Bathroom (near A128) Hand Sink Right (non-consumable).  
Sample No.000016-33.6 ppb: A125 Custodial Closet Slop Sink (non-consumable).  
Sample No. 000026-21.8 ppb: Girls Bathroom (near A118) Hand Sink Left (non-consumable).  
Sample No. 000028-31.9 ppb: Girls Bathroom (near A118) Hand Sink Right (non-consumable).  
Sample No. 000031-317 ppb: A115 Custodial Closet Slop Sink (non-consumable).  
Sample No. 000032-23.0 ppb: Boys Bathroom (near A114) Hand Sink Left (non-consumable).  
Sample No. 000034-101 ppb: Boys Bathroom (near A114) Hand Sink Right (non-consumable).  
Sample No. 000045-25.9 ppb: Girls Bathroom (across A104) Hand Sink Left (non-consumable).  
Sample No. 000046-37.7 ppb: Girls Bathroom (across A104) Hand Sink Center (non-consumable).  
Sample No. 000047-27.5 ppb: Girls Bathroom (across A104) Hand Sink Right (non-consumable).  
Sample No. 000055-131 ppb: Boys Bathroom (across A228) Hand Sink Center (non-consumable).  
Sample No. 000072-44.3 ppb: A 215 Custodial Closet Slop Sink (non-consumable).  
Sample No. 000086-45.8 ppb: Girls Bathroom (across A 204) Hand Sink Left (non-consumable).  
Sample No. 000087-34.8 ppb: Girls Bathroom (across A 204) Hand Sink Center (non-consumable).  
Sample No. 000088-24.9 ppb: Girls Bathroom (across A204) Hand Sink Right (non-consumable).  
Sample No. 000092-52.2 ppb: Media Hall (CPU Lab) Gooseneck Left (non-consumable).  
Sample No. 000093-43.9 ppb: Media Hall (CPU Lab) Bubbler Left (**consumable**).  
Sample No.000094-26.4 ppb: Media Hall (CPU Lab) Bubbler Right (**consumable**).  
Sample No. 000102-40.9 ppb: Gym Office Hand Sink (non-consumable).  
Sample No. 000116-33.7 ppb: Outside Hose Bibb (non-consumable).  
Sample No. 000118-42.1 ppb: Outside Hose Bibb (non-consumable).

### **ACTION LEVEL (AL)**

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

### **HEALTH EFFECTS OF LEAD**

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

## **SOURCES OF HUMAN EXPOSURE TO LEAD**

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the work place and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

## **IMMEDIATE ACTIONS TAKEN**

1. Consumable water sources will be taken out of service and shutoff.
2. Non-Consumable water sources will be posted with signage indicating "Do Not Use For Drinking" or "Hand Washing Only".

## **NEXT STEPS**

1. Consumable water sources will be replaced with new plumbing fixtures.
2. Non-Consumable water sources will be permanently posted with signage if a second flush test is acceptable.

## **TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:**

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

*Please note that boiling the water will not reduce lead levels.*

## **ADDITIONAL INFORMATION**

1. For additional information, please contact Chris Williams, Environmental Issues Program Manager, at 410-360-0138. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at [www.epa.gov/lead](http://www.epa.gov/lead). If you are concerned about exposure, contact your local health department or healthcare provider to find out how you can get your child tested for lead.



**AACPS - Operations Division**  
9034 Ft. Smallwood Road

Tuesday, May 1, 2018

Pasadena, MD 21122

**Attention: Chris Williams**

***Certificate of Analysis***  
**AMENDED**

*Brooklyn Park ES (1092) Report for Lab No. 40002*  
*Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water*  
*P.O. Number: PO 9212*  
*Sampling by Martel personnel on March 20, 2018, Patrick Shannon.*

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40002	000001	Health Room Bathroom Gooseneck	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.11	ug/l	EPA 200.8	2	04/17/2018 13:33 BJ	
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40002	000002	Health Room Gooseneck Hand Sink	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	5.92	ug/l	EPA 200.8	2	04/17/2018 13:45 BJ	
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40002	000003	Office Bathroom Hand Sink	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.42	ug/l	EPA 200.8	2	04/17/2018 13:48 BJ	
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40002	000004	Kindergarten Bathroom Hand Sink	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	54.7	ug/l*	EPA 200.8	2	04/17/2018 13:50 BJ	
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40002	000005	Kindergarten 1 Bubbler	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	4.95	ug/l	EPA 200.8	2	04/17/2018 13:53 BJ	
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40002	000006	Kindergarten 1 Gooseneck	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 13:55 BJ	



MARTEL NO. 40002      000007      CLIENT SAMPLE IDENTIFICATION Kindergarten 2 Bubblers      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.53	ug/l	EPA 200.8	2	04/17/2018 13:58 BJ

MARTEL NO. 40002      000008      CLIENT SAMPLE IDENTIFICATION Kindergarten 2 Gooseneck      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	12.3	ug/l	EPA 200.8	2	04/17/2018 14:00 BJ

MARTEL NO. 40002      000009      CLIENT SAMPLE IDENTIFICATION Kindergarten 3 Bubblers      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.77	ug/l	EPA 200.8	2	04/17/2018 14:02 BJ

MARTEL NO. 40002      000010      CLIENT SAMPLE IDENTIFICATION Kindergarten 3 Bathroom Hand Sink      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	24.8	ug/l*	EPA 200.8	2	04/17/2018 14:05 BJ

MARTEL NO. 40002      000011      CLIENT SAMPLE IDENTIFICATION A131 Bubblers      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.37	ug/l	EPA 200.8	2	04/17/2018 14:15 BJ

MARTEL NO. 40002      000012      CLIENT SAMPLE IDENTIFICATION A131 Gooseneck      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.19	ug/l	EPA 200.8	2	04/17/2018 14:20 BJ

MARTEL NO. 40002      000013      CLIENT SAMPLE IDENTIFICATION Boys Bathroom (near A128) Hand Sink (LEFT)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.59	ug/l	EPA 200.8	2	04/17/2018 14:23 BJ

MARTEL NO. 40002      000014      CLIENT SAMPLE IDENTIFICATION Boys Bathroom (near A128) Hand Sink (CENTER)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	10.7	ug/l	EPA 200.8	2	04/17/2018 14:25 BJ



MARTEL NO. 40002      CLIENT SAMPLE IDENTIFICATION Boys Bathroom (near A128) Hand Sink (RIGHT)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	856	ug/l*	EPA 200.8	2	04/17/2018 14:28 BJ

MARTEL NO. 40002      CLIENT SAMPLE IDENTIFICATION A125 Custodial Slopset Slop Sink      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	33.6	ug/l*	EPA 200.8	2	04/17/2018 14:30 BJ

MARTEL NO. 40002      CLIENT SAMPLE IDENTIFICATION Fountain (near A125) Bubbler (LEFT)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 14:33 BJ

MARTEL NO. 40002      CLIENT SAMPLE IDENTIFICATION Fountain (near A125) Goosneck (LEFT)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 14:35 BJ

MARTEL NO. 40002      CLIENT SAMPLE IDENTIFICATION Fountain (near A125) Bubbler (RIGHT)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 14:38 BJ

MARTEL NO. 40002      CLIENT SAMPLE IDENTIFICATION Fountain (near A125) Goosneck (RIGHT)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 14:40 BJ

MARTEL NO. 40002      CLIENT SAMPLE IDENTIFICATION Sink (across from A122 Bathroom) Hand Sink      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 14:48 BJ

MARTEL NO. 40002      CLIENT SAMPLE IDENTIFICATION Fountain (across from A120) Bubbler (LEFT)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.05	ug/l	EPA 200.8	2	04/17/2018 14:55 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40002	000023	Fountain (across from A120) Goosneck (LEFT)	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	7.49	ug/l	EPA 200.8	2	04/17/2018 14:58 BJ	
40002	000024	Fountain (across from A120) Bubbler (RIGHT)	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	7.45	ug/l	EPA 200.8	2	04/17/2018 15:00 BJ	
40002	000025	Fountain (across from A120) Goosneck (RIGHT)	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	6.45	ug/l	EPA 200.8	2	04/17/2018 15:03 BJ	
40002	000026	Girls Bathroom (near A118) Hand Sink (LEFT)	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	21.8	ug/l*	EPA 200.8	2	04/17/2018 15:05 BJ	
40002	000027	Girls Bathroom (near A118) Hand Sink (CENTER)	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	8.06	ug/l	EPA 200.8	2	04/17/2018 15:08 BJ	
40002	000028	Girls Bathroom (near A118) Hand Sink (RIGHT)	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	31.9	ug/l*	EPA 200.8	2	04/17/2018 15:10 BJ	
40002	000029	Fountain (near A131) Goosneck	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	16.6	ug/l	EPA 200.8	2	04/17/2018 15:13 BJ	
40002	000030	Fountain (near A131) Bubbler	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	16.4	ug/l	EPA 200.8	2	04/17/2018 15:15 BJ	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40002	000031	A115 Custodial Closet Slop Sink	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	317	ug/l*	EPA 200.8	2	04/17/2018 15:25 BJ	
40002	000032	Boys Bathroom (near A114) Hand Sink (LEFT)	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	23.0	ug/l*	EPA 200.8	2	04/17/2018 15:30 BJ	
40002	000033	Boys Bathroom (near A114) Hand Sink (CENTER)	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	non	operational	EPA 200.8	2	/ /	
40002	000034	Boys Bathroom (near A114) Hand Sink (RIGHT)	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	101	ug/l*	EPA 200.8	2	04/17/2018 15:35 BJ	
40002	000035	Fountain (across from A114) Bubbler (LEFT)	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	8.83	ug/l	EPA 200.8	2	04/17/2018 15:37 BJ	
40002	000036	Fountain (across from A114) Goosneck (LEFT)	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	15.0	ug/l	EPA 200.8	2	04/17/2018 15:40 BJ	
40002	000037	Fountain (across from A114) Bubbler (RIGHT)	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	14.2	ug/l	EPA 200.8	2	04/17/2018 15:42 BJ	
40002	000038	Fountain (across from A114) Goosneck (RIGHT)	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	17.4	ug/l	EPA 200.8	2	04/17/2018 15:45 BJ	



MARTEL NO. 40002      000039      CLIENT SAMPLE IDENTIFICATION A111 Custodial Closet Slop Sink      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.98	ug/l	EPA 200.8	2	04/17/2018 15:47 BJ

MARTEL NO. 40002      000040      CLIENT SAMPLE IDENTIFICATION Bathroom (Across A110) Hand Sink      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 15:50 BJ

MARTEL NO. 40002      000041      CLIENT SAMPLE IDENTIFICATION Fountain (across from A108) Bubblers (LEFT)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.99	ug/l	EPA 200.8	2	04/17/2018 15:57 BJ

MARTEL NO. 40002      000042      CLIENT SAMPLE IDENTIFICATION Fountain (across from A108) Goosneck (LEFT)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.56	ug/l	EPA 200.8	2	04/17/2018 16:04 BJ

MARTEL NO. 40002      000043      CLIENT SAMPLE IDENTIFICATION Fountain (across from A108) Bubblers (RIGHT)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.52	ug/l	EPA 200.8	2	04/17/2018 16:07 BJ

MARTEL NO. 40002      000044      CLIENT SAMPLE IDENTIFICATION Fountain (across from A108) Goosneck (RIGHT)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.58	ug/l	EPA 200.8	2	04/17/2018 16:09 BJ

MARTEL NO. 40002      000045      CLIENT SAMPLE IDENTIFICATION Girls Bathroom (across from A104) Hand Sink (      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	25.9	ug/l*	EPA 200.8	2	04/17/2018 16:12 BJ

MARTEL NO. 40002      000046      CLIENT SAMPLE IDENTIFICATION Girls Bathroom (across from A104) Hand Sink (      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	37.7	ug/l*	EPA 200.8	2	04/17/2018 16:14 BJ





MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40002	000047	Girls Bathroom (across from A104) Hand Sink (	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	27.5	ug/l*	EPA 200.8	2	04/17/2018 16:17 BJ	
40002	000048	A101 Gooseneck	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 16:19 BJ	
40002	000049	A101 Bubblers	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 16:22 BJ	
40002	000050	A201 Gooseneck	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	4.52	ug/l	EPA 200.8	2	04/17/2018 16:24 BJ	
40002	000051	A201 Bubblers	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 16:34 BJ	
40002	000052	A231 Gooseneck	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 16:39 BJ	
40002	000053	A231 Bubblers	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 16:42 BJ	
40002	000054	Boys Bathroom (across from A228) Hand Sink (L	03/20/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	5.46	ug/l	EPA 200.8	2	04/17/2018 16:44 BJ	



MARTEL NO. 40002	000055	CLIENT SAMPLE IDENTIFICATION Boys Bathroom (across from A228) Hand Sink (C)	Sample Date/Time 03/20/2018 05:00
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	131	ug/l*	EPA 200.8	2	04/17/2018 16:47 BJ

MARTEL NO. 40002	000056	CLIENT SAMPLE IDENTIFICATION Boys Bathroom (across from A228) Hand Sink (R)	Sample Date/Time 03/20/2018 05:00
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.53	ug/l	EPA 200.8	2	04/17/2018 16:49 BJ

MARTEL NO. 40002	000057	CLIENT SAMPLE IDENTIFICATION Fountain (across from A222) Bubbler (LEFT)	Sample Date/Time 03/20/2018 05:00
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 16:52 BJ

MARTEL NO. 40002	000058	CLIENT SAMPLE IDENTIFICATION Fountain (across from A222) Goosneck (LEFT)	Sample Date/Time 03/20/2018 05:00
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 16:54 BJ

MARTEL NO. 40002	000059	CLIENT SAMPLE IDENTIFICATION Fountain (across from A222) Bubbler (RIGHT)	Sample Date/Time 03/20/2018 05:00
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 16:57 BJ

MARTEL NO. 40002	000060	CLIENT SAMPLE IDENTIFICATION Fountain (across from A222) Goosneck (RIGHT)	Sample Date/Time 03/20/2018 05:00
---------------------	--------	--	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 16:59 BJ

MARTEL NO. 40002	000061	CLIENT SAMPLE IDENTIFICATION A225 Custodial Closet Slop Sink	Sample Date/Time 03/20/2018 05:00
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.22	ug/l	EPA 200.8	2	04/17/2018 17:14 BJ

MARTEL NO. 40002	000062	CLIENT SAMPLE IDENTIFICATION A201 Bathroom Hand Sink	Sample Date/Time 03/20/2018 05:00
---------------------	--------	---	--------------------------------------

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 17:22 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40002 000063	Fountain (across from A220) Bubbler (LEFT)	03/20/2018 05:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	2.95 ug/l EPA 200.8	2 04/17/2018 17:24 BJ
40002 000064	Fountain (across from A220) Goosneck (LEFT)	03/20/2018 05:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	7.63 ug/l EPA 200.8	2 04/17/2018 17:27 BJ
40002 000065	Fountain (across from A220) Bubbler (RIGHT)	03/20/2018 05:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	6.22 ug/l EPA 200.8	2 04/17/2018 17:29 BJ
40002 000066	Fountain (across from A220) Goosneck (RIGHT)	03/20/2018 05:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	6.76 ug/l EPA 200.8	2 04/17/2018 17:32 BJ
40002 000067	Girls Bathroom (across from A216) Hand Sink (	03/20/2018 05:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA 200.8	2 04/17/2018 17:34 BJ
40002 000068	Girls Bathroom (across from A216) Hand Sink (	03/20/2018 05:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	6.36 ug/l EPA 200.8	2 04/17/2018 17:37 BJ
40002 000069	Girls Bathroom (across from A216) Hand Sink (	03/20/2018 05:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	14.9 ug/l EPA 200.8	2 04/17/2018 17:39 BJ
40002 000070	A217 Goosneck	03/20/2018 05:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	10.9 ug/l EPA 200.8	2 04/17/2018 17:42 BJ



MARTEL NO. 40002      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
 000071      A217 Bubbler      03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.63	ug/l	EPA 200.8	2	04/17/2018 17:51 BJ

MARTEL NO. 40002      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
 000072      A215 Custodial Closet Slop Sink      03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	44.3	ug/l*	EPA 200.8	2	04/17/2018 17:56 BJ

MARTEL NO. 40002      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
 000073      Boys Bathroom (next to A215) Hand Sink (LEFT)      03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.74	ug/l	EPA 200.8	2	04/17/2018 17:59 BJ

MARTEL NO. 40002      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
 000074      Boys Bathroom (next to A215) Hand Sink (CENTE)      03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.87	ug/l	EPA 200.8	2	04/17/2018 18:02 BJ

MARTEL NO. 40002      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
 000075      Boys Bathroom (next to A215) Hand Sink (RIGHT)      03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.2	ug/l	EPA 200.8	2	04/17/2018 18:04 BJ

MARTEL NO. 40002      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
 000076      Fountain (across from rm A214) Bubbler (LEFT)      03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 18:07 BJ

MARTEL NO. 40002      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
 000077      Fountain (across from rm A214) Goosneck (LEFT)      03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 18:09 BJ

MARTEL NO. 40002      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
 000078      Fountain (across from rm A214) Bubbler (RIGHT)      03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 18:11 BJ



MARTEL NO. 40002      000079      CLIENT SAMPLE IDENTIFICATION Fountain (across from rm A214) Gooseneck (RIG)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 18:14 BJ

MARTEL NO. 40002      000080      CLIENT SAMPLE IDENTIFICATION Custodial Closet A211 Slop Sink      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/17/2018 18:16 BJ

MARTEL NO. 40002      000081      CLIENT SAMPLE IDENTIFICATION Bathroom (across from A210) Hand Sink      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/24/2018 17:17 BJ

MARTEL NO. 40002      000082      CLIENT SAMPLE IDENTIFICATION Fountain (across from rm A210) Bubbler (LEFT)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.10	ug/l	EPA 200.8	2	04/24/2018 17:29 BJ

MARTEL NO. 40002      000083      CLIENT SAMPLE IDENTIFICATION Fountain (across from rm A210) Gooseneck (LEFT)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.50	ug/l	EPA 200.8	2	04/24/2018 17:31 BJ

MARTEL NO. 40002      000084      CLIENT SAMPLE IDENTIFICATION Fountain (across from rm A210) Bubbler (RIGHT)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.78	ug/l	EPA 200.8	2	04/24/2018 17:34 BJ

MARTEL NO. 40002      000085      CLIENT SAMPLE IDENTIFICATION Fountain (across from rm A210) Gooseneck (RIG)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/24/2018 17:36 BJ

MARTEL NO. 40002      000086      CLIENT SAMPLE IDENTIFICATION Girls Bathroom (across from A204) Hand Sink (      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	45.8	ug/l*	EPA 200.8	2	04/24/2018 17:39 BJ



MARTEL NO. 40002 000087 CLIENT SAMPLE IDENTIFICATION Girls Bathroom (across from A204) Hand Sink ( Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	34.8	ug/l*	EPA 200.8	2	04/24/2018 17:41 BJ

MARTEL NO. 40002 000088 CLIENT SAMPLE IDENTIFICATION Girls Bathroom (across from A204) Hand Sink ( Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	24.9	ug/l*	EPA 200.8	2	04/24/2018 17:44 BJ

MARTEL NO. 40002 000089 CLIENT SAMPLE IDENTIFICATION Art Gooseneck (LEFT) Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	15.4	ug/l	EPA 200.8	2	04/24/2018 17:46 BJ

MARTEL NO. 40002 000090 CLIENT SAMPLE IDENTIFICATION Art Gooseneck (Center) Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.00	ug/l	EPA 200.8	2	04/24/2018 17:49 BJ

MARTEL NO. 40002 000091 CLIENT SAMPLE IDENTIFICATION Art Gooseneck (RIGHT) Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.99	ug/l	EPA 200.8	2	04/24/2018 17:59 BJ

MARTEL NO. 40002 000092 CLIENT SAMPLE IDENTIFICATION Median Hall (near cpu lab) Gooseneck (LEFT) Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	52.2	ug/l*	EPA 200.8	2	04/24/2018 18:04 BJ

MARTEL NO. 40002 000093 CLIENT SAMPLE IDENTIFICATION Median Hall (near cpu lab) Bubbler (LEFT) Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	43.9	ug/l*	EPA 200.8	2	04/24/2018 18:06 BJ

MARTEL NO. 40002 000094 CLIENT SAMPLE IDENTIFICATION Median Hall (near cpu lab) Bubbler (RIGHT) Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	26.4	ug/l*	EPA 200.8	2	04/24/2018 18:09 BJ



MARTEL NO. 40002 000095 CLIENT SAMPLE IDENTIFICATION Custodial Closet (near cpu lab) Slop Sink Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/24/2018 18:11 BJ

MARTEL NO. 40002 000096 CLIENT SAMPLE IDENTIFICATION Bathroom (near staff lounge) Hand Sink Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.62	ug/l	EPA 200.8	2	04/24/2018 18:14 BJ

MARTEL NO. 40002 000097 CLIENT SAMPLE IDENTIFICATION Teachers Lounge Gooseneck Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.23	ug/l	EPA 200.8	2	04/24/2018 18:16 BJ

MARTEL NO. 40002 000098 CLIENT SAMPLE IDENTIFICATION Teachers Lounge Womans Bathroom Gooseneck Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.07	ug/l	EPA 200.8	2	04/24/2018 18:19 BJ

MARTEL NO. 40002 000099 CLIENT SAMPLE IDENTIFICATION Gym Girls Bathroom Hand Sink Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.08	ug/l	EPA 200.8	2	04/24/2018 18:21 BJ

MARTEL NO. 40002 000100 CLIENT SAMPLE IDENTIFICATION Fountain (near boys bathroom gym) Water Fount Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/24/2018 18:24 BJ

MARTEL NO. 40002 000101 CLIENT SAMPLE IDENTIFICATION Gym Boys Bathroom Hand Sink Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.18	ug/l	EPA 200.8	2	04/24/2018 18:31 BJ

MARTEL NO. 40002 000102 CLIENT SAMPLE IDENTIFICATION Gym Office Bathroom Hand Sink Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	40.9	ug/l*	EPA 200.8	2	04/24/2018 18:39 BJ



MARTEL NO. 40002      000103      Kitchen Sink (LEFT)      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/24/2018 18:41 BJ

MARTEL NO. 40002      000104      Kitchen Gooseneck (LEFT)      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/24/2018 18:44 BJ

MARTEL NO. 40002      000105      Kitchen Gooseneck (RIGHT)      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.21	ug/l	EPA 200.8	2	04/24/2018 18:46 BJ

MARTEL NO. 40002      000106      Kitchen hand Sink (MIDDLE OF KITCHEN)      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.86	ug/l	EPA 200.8	2	04/24/2018 18:49 BJ

MARTEL NO. 40002      000107      Kitchen Custodial Slop Sink      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/24/2018 18:51 BJ

MARTEL NO. 40002      000108      Kitchen Bathroom Hand Sink      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.33	ug/l	EPA 200.8	2	04/24/2018 18:54 BJ


MARTEL NO. 40002      000109      Cafeteria Water Fountain      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/24/2018 18:56 BJ

MARTEL NO. 40002      000110      Boys Bathroom (next to Music) Hand Sink (LEFT)      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.54	ug/l	EPA 200.8	2	04/24/2018 18:59 BJ





MARTEL NO. 40002      000111      CLIENT SAMPLE IDENTIFICATION Boys Bathroom (next to Music) Hand Sink (RIGH)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA 200.8	2	//

MARTEL NO. 40002      000112      CLIENT SAMPLE IDENTIFICATION Hall Fountain (between boys and girls bathroo)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/24/2018 19:08 BJ

MARTEL NO. 40002      000113      CLIENT SAMPLE IDENTIFICATION Girls Bathroom (next to Music) Hand Sink (LEF)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	04/24/2018 19:13 BJ

MARTEL NO. 40002      000114      CLIENT SAMPLE IDENTIFICATION Girls Bathroom (next to Music) Hand Sink (RIG)      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.19	ug/l	EPA 200.8	2	04/24/2018 19:16 BJ

MARTEL NO. 40002      000115      CLIENT SAMPLE IDENTIFICATION Custodial Closet (near health room) SI      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.04	ug/l	EPA 200.8	2	04/24/2018 19:18 BJ

MARTEL NO. 40002      000116      CLIENT SAMPLE IDENTIFICATION Outside (see map) Hose Bibb      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	33.7	ug/l*	EPA 200.8	2	04/24/2018 19:21 BJ

MARTEL NO. 40002      000117      CLIENT SAMPLE IDENTIFICATION Outside (see map) Hose Bibb      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA 200.8	2	//

MARTEL NO. 40002      000118      CLIENT SAMPLE IDENTIFICATION Outside (see map) Hose Bibb      Sample Date/Time 03/20/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	42.1	ug/l*	EPA 200.8	2	04/24/2018 19:23 BJ



MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
40002	000119	Outside (see map) Hose Bibb				03/20/2018 05:00	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	non	operational	EPA 200.8	2	/ /		

Page 16 OF 16

1025 Cromwell Bridge Road - Baltimore, Maryland 21286  
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

stdl.frx

### Notes and references:

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date. 40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

\* result exceeds 20 ug/l (ppb).

All samples tested were in acceptable condition, unless otherwise noted.  
The results presented herein relate only to the samples or items tested.

  
Project Manager

# MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

## Anne Arundel County Public Schools Drinking Water Lead Testing

Sample Date/Start Time: 5:00 End time: 6:30  
 Bottle Type/Preservative: 250 ml plastic/HNO3 Analysis: Lead (EPA 200.8) Samples preserved properly Yes or No NOTES:  
 Sampled/Relinquished by: Lauren & Danny Received at Martel by: [Signature] Date/Time: 08/31/21

**Brooklyn Park ES (1092) MARTEL LAB NO. 40002**

200 14th Avenue, Baltimore, MD 21225

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE**

Sample #	Room #	Fixture Type
1	Health Room Bathroom	Gooseneck
2	Health Room Gooseneck	Hand Sink
3	Office Bathroom	Hand Sink
4	Kindergarten Bathroom	Hand Sink
5	Kindergarten 1	Bubbler
6	Kindergarten 1	Gooseneck
7	Kindergarten 2	Bubbler
8	Kindergarten 2	Gooseneck
9	Kindergarten 3	Bubbler
10	Kindergarten 3 Bathroom	Hand Sink
11	A131	Bubbler
12	A131	Gooseneck
13	Boys Bathroom (near A128)	Hand Sink (LEFT)
14	Boys Bathroom (near A128)	Hand Sink (CENTER)
15	Boys Bathroom (near A128)	Hand Sink (RIGHT)
16	A125 Custodial Sloset	Slop Sink
17	Fountain (near A125)	Bubbler (LEFT)
18	Fountain (near A125)	Goosneck (LEFT)
19	Fountain (near A125)	Bubbler (RIGHT)
20	Fountain (near A125)	Gooseneck (RIGHT)
21	Sink (across from A122 Bathroom)	Hand Sink
22	Fountain (across from A120)	Bubbler (LEFT)
23	Fountain (across from A120)	Goosneck (LEFT)
24	Fountain (across from A120)	Bubbler (RIGHT)
25	Fountain (across from A120)	Gooseneck (RIGHT)
26	Girls Bathroom (near A118)	Hand Sink (LEFT)
27	Girls Bathroom (near A118)	Hand Sink (CENTER)
28	Girls Bathroom (near A118)	Hand Sink (RIGHT)
29	Fountain (near A131)	Gooseneck
30	Fountain (near A131)	Bubbler
31	A115 Custodial Closet	Slop Sink
32	Boys Bathroom (near A114)	Hand Sink (LEFT)
33	Boys Bathroom (near A114)	Hand Sink (CENTER)

*not functional*

**Brooklyn Park ES (1092) MARTEL LAB NO. 40002**

34	Boys Bathroom (near A114)	Hand Sink (RIGHT)
35	Fountain (across from A114)	Bubbler (LEFT)
36	Fountain (across from A114)	Goosneck (LEFT)
37	Fountain (across from A114)	Bubbler (RIGHT)
38	Fountain (across from A114)	Goosneck (RIGHT)
39	A111 Custodial Closet	Slop Sink
40	Bathroom (Across A110)	Hand Sink
41	Fountain (across from A108)	Bubbler (LEFT)
42	Fountain (across from A108)	Goosneck (LEFT)
43	Fountain (across from A108)	Bubbler (RIGHT)
44	Fountain (across from A108)	Goosneck (RIGHT)
45	Girls Bathroom (across from A104)	Hand Sink (LEFT)
46	Girls Bathroom (across from A104)	Hand Sink (CENTER)
47	Girls Bathroom (across from A104)	Hand Sink (RIGHT)
48	A101	Goosneck
49	A101	Bubbler
50	A201	Goosneck
51	A201	Bubbler
52	A231	Goosneck
53	A231	Bubbler
54	Boys Bathroom (across from A228)	Hand Sink (LEFT)
55	Boys Bathroom (across from A228)	Hand Sink (CENTER)
56	Boys Bathroom (across from A228)	Hand Sink (RIGHT)
57	Fountain (across from A222)	Bubbler (LEFT)
58	Fountain (across from A222)	Goosneck (LEFT)
59	Fountain (across from A222)	Bubbler (RIGHT)
60	Fountain (across from A222)	Goosneck (RIGHT)
61	A225 Custodial Closet	Slop Sink
62	A201 Bathroom	Hand Sink
63	Fountain (across from A220)	Bubbler (LEFT)
64	Fountain (across from A220)	Goosneck (LEFT)
65	Fountain (across from A220)	Bubbler (RIGHT)
66	Fountain (across from A220)	Goosneck (RIGHT)
67	Girls Bathroom (across from A216)	Hand Sink (LEFT)
68	Girls Bathroom (across from A216)	Hand Sink (CENTER)
69	Girls Bathroom (across from A216)	Hand Sink (RIGHT)
70	A217	Goosneck
71	A217	Bubbler
72	A215 Custodial Closet	Slop Sink
73	Boys Bathroom (next to A215)	Hand Sink (LEFT)
74	Boys Bathroom (next to A215)	Hand Sink (CENTER)
75	Boys Bathroom (next to A215)	Hand Sink (RIGHT)
76	Fountain (across from rm A214)	Bubbler (LEFT)
77	Fountain (across from rm A214)	Goosneck (LEFT)

**Brooklyn Park ES (1092) MARTEL LAB NO. 40002**

78	Fountain (across from rm A214)	Bubbler (RIGHT)	
79	Fountain (across from rm A214)	Gooseneck (RIGHT)	
80	Custodial Closet A211	Slop Sink	
81	Bathroom (across from A210)	Hand Sink	
82	Fountain (across from rm A210)	Bubbler (LEFT)	
83	Fountain (across from rm A210)	Goosneck (LEFT)	
84	Fountain (across from rm A210)	Bubbler (RIGHT)	
85	Fountain (across from rm A210)	Gooseneck (RIGHT)	
86	Girls Bathroom (across from A204)	Hand Sink (LEFT)	
87	Girls Bathroom (across from A204)	Hand Sink (CENTER)	
88	Girls Bathroom (across from A204)	Hand Sink (RIGHT)	A bead fell out of faucet *
89		Art Gooseneck (LEFT)	
90		Art Gooseneck (Center)	
91		Art Gooseneck (RIGHT)	
92	Median Hall (near cpu lab)	Gooseneck (LEFT)	
93	Median Hall (near cpu lab)	Bubbler (LEFT)	
94	Median Hall (near cpu lab)	Bubbler (RIGHT)	
95	Custodial Closet (near cpu lab)	Slop Sink	
96	Bathroom (near staff lounge)	Hand Sink	
97	Teachers Lounge	Gooseneck	
98	Teachers Lounge Womans Bathroom	Gooseneck	
99	Gym Girls Bathroom	Hand Sink	
100	Fountain (near boys bathroom gym)	Water Fountain	
101	Gym Boys Bathroom	Hand Sink	
102	Gym Office Bathroom	Hand Sink	
103	Kitchen	Sink (LEFT)	
104	Kitchen	Gooseneck (LEFT)	
105	Kitchen	Gooseneck (RIGHT)	
106	Kitchen	hand Sink (MIDDLE OF KITCHEN)	
107	Kitchen Custodial	Slop Sink	
108	Kitchen Bathroom	Hand Sink	
109	Cafeteria	Water Fountain	
110	Boys Bathroom (next to Music)	Hand Sink (LEFT)	
111	Boys Bathroom (next to Music)	Hand Sink (RIGHT)	not functional
112	Hall Fountain (between boys and girls bathroom)	Water Fountain	
113	Girls Bathroom (next to Music)	Hand Sink (LEFT)	
114	Girls Bathroom (next to Music)	Hand Sink (RIGHT)	
115	Custodial Closet (near health room)	Slop Sink	
116	Outside (see map)	Hose Bibb	
117	Outside (see map)	Hose Bibb	not functional
118	Outside (see map)	Hose Bibb	
119	Outside (see map)	Hose Bibb	Not functional