

Lead in Drinking Water – Public and Nonpublic Schools

IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT(S) **Ferndale Early Education Center**

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On April 6, 2018, **fifty-one (51)** lead water samples were collected from **Ferndale Early Education Center**. Of these lead water samples, one (1) had a level of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings. The elevated lead result from the samples collected at Ferndale Early Education Center was as follows:

Sample Number 000039-Kitchen Custodial Closet 133 Slop Sink: 20.4 ppb (non-consumable).

ACTION LEVEL (AL)

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the work place and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

IMMEDIATE ACTIONS TAKEN

1. The kitchen custodial closet 133 slop sink will not be used for drinking and will be posted with green signage indicating "Hand Washing Only".
2. The outside hose bibbs are shut off with keyed access only and posted with red signage indicating "Do Not Use for Drinking".

NEXT STEPS

1. The kitchen custodial closet 133 slop sink will be posted permanently with green signage indicating “Hand Washing Only”.
2. The outside hose bibbs will not be used for drinking water consumption and are shut off with keyed access only and posted with permanent red signage.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn’t been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

1. For additional information, please contact Chris Williams, Environmental Issues Program Manager, at 410-360-0138. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA’s website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.



AACPS - Operations Division
9034 Ft. Smallwood Road

Tuesday, May 29, 2018

Pasadena, MD 21122

Certificate of Analysis
FINAL

Attention: Chris Williams

Report for Lab No: 40009.

Ferndale EEC (1102)

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 9212

Sampling by Martel personnel on April 6, 2018, Megan Greenfield

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40009	000001	Main office Hand Sink [OT--NC]			04/06/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 15:02 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40009	000002	Main office work room Gooseneck [OT--NC]			04/06/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 15:15 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40009	000003	Main office work room Bubbler [DF--NC]			04/06/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 15:17 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40009	000004	Conference Room Gooseneck [OT--NC]			04/06/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 15:20 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40009	000005	Conference Room Bubbler [DF--NC]			04/06/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 15:22 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40009	000006	Hallway Fountain (by 106) Water Fountain (RIGHT) [DF--NC]			04/06/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial



MARTEL NO. 40009 000006 CLIENT SAMPLE IDENTIFICATION: Hallway Fountain (by 106) Water Fountain (RIGHT) [DF--NC] Sample Date/Time: 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 15:25 BJ

MARTEL NO. 40009 000007 CLIENT SAMPLE IDENTIFICATION: Hallway Fountain (by 106) Water Fountain (LEFT) [DF--NC] Sample Date/Time: 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 15:28 BJ

MARTEL NO. 40009 000008 CLIENT SAMPLE IDENTIFICATION: 108 Gooseneck [CR--NC] Sample Date/Time: 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 15:30 BJ

MARTEL NO. 40009 000009 CLIENT SAMPLE IDENTIFICATION: 108 Bathroom Hand Sink [BS--NC] Sample Date/Time: 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 15:33 BJ

MARTEL NO. 40009 000010 CLIENT SAMPLE IDENTIFICATION: 109 Bathroom Hand Sink [BS--NC] Sample Date/Time: 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 15:35 BJ

MARTEL NO. 40009 000011 CLIENT SAMPLE IDENTIFICATION: 109 Gooseneck [CR--NC] Sample Date/Time: 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 15:46 BJ

MARTEL NO. 40009 000012 CLIENT SAMPLE IDENTIFICATION: 110 Bathroom Hand Sink [BS--C] Sample Date/Time: 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 15:51 BJ

MARTEL NO. 40009 000013 CLIENT SAMPLE IDENTIFICATION: 110 Gooseneck [CR--NC] Sample Date/Time: 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 15:54 BJ



MARTEL NO. 40009 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000014 111 Bathroom Hand Sink [BS--C] 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 15:56 BJ

MARTEL NO. 40009 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000015 111 Gooseneck [CR--C] 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 15:59 BJ

MARTEL NO. 40009 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000016 113 Gooseneck [CR--NC] 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 16:01 BJ

MARTEL NO. 40009 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000017 113 Bathroom Hand Sink [BS--NC] 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 16:04 BJ

MARTEL NO. 40009 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000018 114 Gooseneck [CR--NC] 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 16:06 BJ

MARTEL NO. 40009 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000019 Health Room 115 Eye Wash [OT--C] 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 16:09 BJ

MARTEL NO. 40009 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000020 Health Room 115 Gooseneck [NO--NC] 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 16:11 BJ

MARTEL NO. 40009 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000021 Health Room 115C Gooseneck [NO--NC] 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 16:19 BJ



MARTEL NO. 40009 000022 Health Room 115 Bathroom Hand Sink [BS--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 16:27 BJ

MARTEL NO. 40009 000023 Teachers Lounge 116 Bathroom Hand Sink [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 16:30 BJ

MARTEL NO. 40009 000024 Teachers Lounge 116 Gooseneck [TL--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 16:32 BJ

MARTEL NO. 40009 000025 Teachers Lounge 1156 Bubbler [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 16:35 BJ

MARTEL NO. 40009 000026 Custodial Closet 117 Slop Sink [OT--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 16:37 BJ

MARTEL NO. 40009 000027 138 Bathroom Hand Sink [BS--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 16:40 BJ

MARTEL NO. 40009 000028 138 Gooseneck [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 16:43 BJ

MARTEL NO. 40009 000029 139 Gooseneck [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 16:45 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40009	000030	139 Bathroom Hand Sink [BS--C]			04/06/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 16:48 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40009	000031	140 Gooseneck [CR--C]			04/06/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 16:58 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40009	000032	140 Bathroom Hand Sink [BS--NC]			04/06/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 17:03 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40009	000033	Mechanical Room 137 Slop Sink [OT--NC]			04/06/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 17:06 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40009	000034	Girls Bathroom (across from room 139) Hand Sink (LEFT) [BS			04/06/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 17:08 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40009	000035	Girls Bathroom (across from room 139) Hand Sink (RIGHT) [B			04/06/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.75	ug/l	EPA 200.8	2	05/21/2018 17:11 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40009	000036	Kitchen Hand Sink [KS--NC]			04/06/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 17:13 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40009	000037	Kitchen Split Sink Sink (RIGHT) [KS--NC]			04/06/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 17:16 BJ



MARTEL NO. 40009 000038 CLIENT SAMPLE IDENTIFICATION: Kitchen Split Sink Sink (LEFT) [KS--NC] Sample Date/Time: 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 17:18 BJ

MARTEL NO. 40009 000039 CLIENT SAMPLE IDENTIFICATION: Kitchen Custodial Closet 133 Slop Sink [OT--C] Sample Date/Time: 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	20.4	ug/l	EPA 200.8	2	05/21/2018 17:21 BJ

MARTEL NO. 40009 000040 CLIENT SAMPLE IDENTIFICATION: Kitchen Bathroom Hand Sink [BS--NC] Sample Date/Time: 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 17:24 BJ

MARTEL NO. 40009 000041 CLIENT SAMPLE IDENTIFICATION: Kitchen Hand Sink (near office) [KS--NC] Sample Date/Time: 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.36	ug/l	EPA 200.8	2	05/21/2018 17:31 BJ

MARTEL NO. 40009 000042 CLIENT SAMPLE IDENTIFICATION: Multipurpose Room 126 Water Fountain [DF--C] Sample Date/Time: 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 17:39 BJ

MARTEL NO. 40009 000043 CLIENT SAMPLE IDENTIFICATION: Multipurpose Room 126 Gooseneck [CR--NC] Sample Date/Time: 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 17:42 BJ

MARTEL NO. 40009 000044 CLIENT SAMPLE IDENTIFICATION: Hallway Fountain (by 126) Water Fountain (LEFT) [DF--NC] Sample Date/Time: 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 17:44 BJ

MARTEL NO. 40009 000045 CLIENT SAMPLE IDENTIFICATION: Hallway Fountain (by 126) Water Fountain (RIGHT) [DF--C] Sample Date/Time: 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 17:47 BJ



MARTEL NO. 40009 000046 CLIENT SAMPLE IDENTIFICATION Boys Bathroom (by 126) Hand Sink (LEFT) [BS--NC] Sample Date/Time 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 17:49 BJ

MARTEL NO. 40009 000047 CLIENT SAMPLE IDENTIFICATION Boys Bathroom (by 126) Hand Sink (RIGHT) [BS--NC] Sample Date/Time 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 17:52 BJ

MARTEL NO. 40009 000048 CLIENT SAMPLE IDENTIFICATION Adult Bathroom Right Hand Sink [BS--C] Sample Date/Time 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 17:54 BJ

MARTEL NO. 40009 000049 CLIENT SAMPLE IDENTIFICATION Adult Bathroom Left Hand Sink [BS--NC] Sample Date/Time 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 17:57 BJ

MARTEL NO. 40009 000050 CLIENT SAMPLE IDENTIFICATION 119 Bathroom Hand Sink [BS--NC] Sample Date/Time 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 18:00 BJ

MARTEL NO. 40009 000051 CLIENT SAMPLE IDENTIFICATION 119 Gooseneck [CR--C] Sample Date/Time 04/06/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	05/21/2018 18:10 BJ



Martel Laboratories JDS Inc.

Page 8 OF 8

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

AACOP1


05/29/2018
stdl.frx

Notes and references:

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date. 40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

* result exceeds 20.5 ug/l (ppb).

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.



Project Manager

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Anne Arundel County Public Schools Drinking Water Lead Testing

Sample Date/Start Time: 5:00 am 4/6/16 End time: 5:45 am
 Bottle Type/Preservative: 250 ml plastic/HNO3 Analysis: Lead (EPA 200.8) Samples preserved properly Yes or No NOTES:
 Sampled/Relinquished by: [Signature] Received at Martel by: _____ Date/Time: _____

Ferndale EEC (1102) MARTEL NO. 40009

105 Packard Avenue, Glen Burnie, MD 21061

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE
 SAMPLING BETWEEN THE HOURS OF 8PM AND 9PM**

Sample #	Room #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb, etc.)
1	Main office	Hand Sink
2	Main office work room	Gooseneck
3	Main office work room	Bubbler
4	Conference Room	Gooseneck
5	Conference Room	Bubbler
6	Hallway Fountain (by 106)	Water Fountain (RIGHT)
7	Hallway Fountain (by 106)	Water Fountain (LEFT)
8	108	Gooseneck
9	108 Bathroom	Hand Sink
10	109 Bathroom	Hand Sink
11	109	Gooseneck
12	110 Bathroom	Hand Sink
13	110	Gooseneck
14	111 Bathroom	Hand Sink
15	111	Gooseneck
16	113	Gooseneck
17	113 Bathroom	Hand Sink
18	114	Gooseneck
19	Health Room 115	Eye Wash
20	Health Room 115	Gooseneck
21	Health Room 115C	Gooseneck
22	Health Room 115 Bathroom	Hand Sink
23	Teachers Lounge 116 Bathroom	Hand Sink
24	Teachers Lounge 116	Gooseneck
25	Teachers Lounge 1156	Bubbler
26	Custodial Closet 117	Slop Sink
27	138 Bathroom	Hand Sink
28	138	Gooseneck
29	139	Gooseneck
30	139 Bathroom	Hand Sink
31	140	Gooseneck
32	140 Bathroom	Hand Sink

Ferndale EEC (1102) MARTEL NO. 40009**105 Packard Avenue, Glen Burnie, MD 21061**

33	Mechanical Room 137	Slop Sink
34	Girls Bathroom (across from room 139)	Hand Sink (LEFT)
35	Girls Bathroom (across from room 139)	Hand Sink (RIGHT)
36	Kitchen	Hand Sink
37	Kitchen Split Sink	Sink (RIGHT)
38	Kitchen Split Sink	Sink (LEFT)
39	Kitchen Custodial Closet 133	Slop Sink
40	Kitchen Bathroom	Hand Sink
41	Kitchen	Hand Sink (near office)
42	Multipurpose Room 126	Water Fountain
43	Multipurpose Room 126	Gooseneck
44	Hallway Fountain (by 126)	Water Fountain (LEFT)
45	Hallway Fountain (by 126)	Water Fountain (RIGHT)
46	Boys Bathroom (by 126)	Hand Sink (LEFT)
47	Boys Bathroom (by 126)	Hand Sink (RIGHT)
48	Adult Bathroom Right	Hand Sink
49	Adult Bathroom Left	Hand Sink
50	119 Bathroom	Hand Sink
51	119	Gooseneck
52	Outside (see map)	Hose Bibb
53	Outside (see map)	Hose Bibb
54	Outside (see map)	Hose Bibb
55	Outside (see map)	Hose Bibb
56	Outside (see map)	Hose Bibb