

Lead in Drinking Water – Public and Nonpublic Schools

IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT(S) **High Point Elementary School**

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On April 25, 2018, **one hundred four (104)** lead water samples were collected from **High Point Elementary School**. Of these lead water samples, thirteen (13) had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings. The elevated lead result from the sample(s) collected at High Point Elementary School were as follows:

Sample Number 000006-Kindergarten Bubbler (Right): 21.0 ppb (consumable).

Sample Number 000007-Kindergarten Bubbler (Left): 155 ppb (consumable).

Sample Number 000019-Kitchen Hand Sink (across from tri-sink): 72.8 ppb (non-consumable).

Sample Number 000022-Kitchen Hand Sink (tray storage area): 611 ppb (non-consumable).

Sample Number 000033-Media Center Gooseneck: 25.3 ppb (consumable).

Sample Number 000035-Media Center Bubbler (Right): 50.8 ppb (consumable).

Sample Number 000055-Fixture opposite samples 48-50 (bottom left rear) Bubbler: 35.9 ppb (consumable).

Sample Number 000065-Fixtures opposite samples 57-58 (bottom right rear) Bubbler: 265 ppb (consumable).

Sample Number 000086-Fixture (top left rear) Bubbler (Right): 20.5 ppb (consumable).

Sample Number 000091-Fixture opposite samples 85-89 (top left rear) Gooseneck: 22.6 ppb (consumable).

Sample Number 000093-Fixture opposite samples 85-87 (top left rear) Bubbler Right: 28.6 ppb (consumable).

Sample Number 000104-Fixture near Facility Resources (top right front) Bubbler: 1950 ppb (consumable)

Sample Number 000106-Girls Bathroom across from Storage F (top right front) Hand Sink: 27.3 ppb (non-consumable).

ACTION LEVEL (AL)

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the work place and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

IMMEDIATE ACTIONS TAKEN

1. Since the old school building has been demolished for the renovation of the new school, there is no need to replace the plumbing fixtures or post signage.

NEXT STEPS

1. The new school renovation will necessitate the sampling of the new plumbing fixtures within one year of occupancy.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

1. For additional information, please contact Chris Williams, Environmental Issues Program Manager, at 410-360-0138. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.



AACPS - Operations Division
9034 Ft. Smallwood Road

Tuesday, July 24, 2018

Pasadena, MD 21122

Attention: Chris Williams

Report for Lab No: 40020.

High Point ES (2132).

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 9212

Sampling by Martel personnel on April 25, 2018, Patrick Shannon.

Certificate of Analysis
FINAL

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40020 000001	Main Office Bathroom Hand Sink [BS--NC]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/20/2018 09:41 CSG
40020 000002	Health Room Hand Sink [NO--NC]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/20/2018 09:54 CSG
40020 000003	Health Room Bathroom Hand Sink [BS--NC]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.21 ug/l EPA .200.8 2	07/20/2018 09:56 CSG
40020 000004	Custodial Closet (next to health room) Slop Sink [OT--NC]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/20/2018 09:59 CSG
40020 000005	Kindergarten Hand Sink (outside bathroom) [CR--NC]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.88 ug/l EPA .200.8 2	07/20/2018 10:01 CSG
40020 000006	Kindergarten Bubbler (right) [DF--C]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial



MARTEL NO. 40020 000006 CLIENT SAMPLE IDENTIFICATION Kindergarten Bubbler (right) [DF--C] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	21.0	ug/l*	EPA .200.8	2	07/20/2018 10:04 CSG

MARTEL NO. 40020 000007 CLIENT SAMPLE IDENTIFICATION Kindergarten Bubbler (left) [DF--C] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	155	ug/l*	EPA .200.8	2	07/20/2018 10:06 CSG

MARTEL NO. 40020 000008 CLIENT SAMPLE IDENTIFICATION Kindergarten Gooseneck (right) [CR--NC] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.19	ug/l	EPA .200.8	2	07/20/2018 10:09 CSG

MARTEL NO. 40020 000009 CLIENT SAMPLE IDENTIFICATION Kindergarten Gooseneck (left) [CR--NC] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.50	ug/l	EPA .200.8	2	07/20/2018 10:11 CSG

MARTEL NO. 40020 000010 CLIENT SAMPLE IDENTIFICATION Kindergarten Hand Sink (inside bathroom) [BS--NC] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.91	ug/l	EPA .200.8	2	07/20/2018 10:14 CSG

MARTEL NO. 40020 000011 CLIENT SAMPLE IDENTIFICATION Boys Bathroom Main Hall (across from Café) Hand Sink (LEFT) Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.20	ug/l	EPA .200.8	2	07/20/2018 10:24 CSG

MARTEL NO. 40020 000012 CLIENT SAMPLE IDENTIFICATION Boys Bathroom Main Hall (across from Café) Hand Sink Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.93	ug/l	EPA .200.8	2	07/20/2018 10:29 CSG

MARTEL NO. 40020 000013 CLIENT SAMPLE IDENTIFICATION Girls Bathroom Main Hall (across from Café) Hand Sink (LEFT) Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.30	ug/l	EPA .200.8	2	07/20/2018 10:32 CSG



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40020 000014	Girls Bathroom Main Hall (across from Caf�) Hand Sink (RIGHT)	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.96 ug/l EPA .200.8 2	07/20/2018 10:34 CSG
40020 000015	Kitchen - Serving Area Gooseneck [KS--C]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	18.1 ug/l EPA .200.8 2	07/20/2018 10:37 CSG
40020 000016	Kitchen - Double Sink Gooseneck [KS--NC]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/20/2018 10:39 CSG
40020 000017	Kitchen - Tri-Sink Gooseneck (LEFT) [KS--C]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/20/2018 10:42 CSG
40020 000018	Kitchen - Tri-Sink Gooseneck (RIGHT) [KS--C]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	7.82 ug/l EPA .200.8 2	07/20/2018 10:44 CSG
40020 000019	Kitchen (across from tri-sink) Hand Sink [KS--C]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	72.8 ug/l* EPA .200.8 2	07/20/2018 10:46 CSG
40020 000020	Kitchen - Custodial Area Slop Sink [OT--NC]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/20/2018 10:49 CSG
40020 000021	Kitchen - Bathroom Hand Sink [BS--NC]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	17.3 ug/l EPA .200.8 2	07/20/2018 10:57 CSG



MARTEL NO. 40020 000022 CLIENT SAMPLE IDENTIFICATION Kitchen - tray storage area Hand Sink [OT--NC] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	611	ug/l*	EPA .200.8	2	07/20/2018 20:20 CSG

MARTEL NO. 40020 000023 CLIENT SAMPLE IDENTIFICATION Gym - PE Office Bathroom Hand Sink [BS--NC] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.79	ug/l	EPA .200.8	2	07/20/2018 11:07 CSG

MARTEL NO. 40020 000024 CLIENT SAMPLE IDENTIFICATION Gym Hallway Water Fountain [DF--C] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 11:09 CSG

MARTEL NO. 40020 000025 CLIENT SAMPLE IDENTIFICATION Gym Hallway - Girls Bathroom Hand Sink [BS--NC] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.20	ug/l	EPA .200.8	2	07/20/2018 11:12 CSG

MARTEL NO. 40020 000026 CLIENT SAMPLE IDENTIFICATION Gym Hallway - Boys Bathroom Hand Sink [BS--NC] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 11:14 CSG

MARTEL NO. 40020 000027 CLIENT SAMPLE IDENTIFICATION Teachers Lounge Gooseneck [TL--NC] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	14.1	ug/l	EPA .200.8	2	07/20/2018 11:17 CSG

MARTEL NO. 40020 000028 CLIENT SAMPLE IDENTIFICATION Art Room A110 - Kiln Room A130A Slop Sink [OT--NC] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.62	ug/l	EPA .200.8	2	07/20/2018 11:19 CSG

MARTEL NO. 40020 000029 CLIENT SAMPLE IDENTIFICATION Art Room A110 Bubbler (RIGHT) [DF--C] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 11:22 CSG



MARTEL NO. 40020 000030 CLIENT SAMPLE IDENTIFICATION Art Room A110 Gooseneck (RIGHT) [CR--NC] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 11:24 CSG

MARTEL NO. 40020 000031 CLIENT SAMPLE IDENTIFICATION Art Room A110 Bubbler (LEFT) [DF--C] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 11:34 CSG

MARTEL NO. 40020 000032 CLIENT SAMPLE IDENTIFICATION Art Room A110 Bubbler (RIGHT) [DF--C] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 11:39 CSG

MARTEL NO. 40020 000033 CLIENT SAMPLE IDENTIFICATION Media Center Gooseneck [OT--NC] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	25.3	ug/l*	EPA .200.8	2	07/20/2018 11:41 CSG

MARTEL NO. 40020 000034 CLIENT SAMPLE IDENTIFICATION Media Center Bubbler (LEFT) [DF--C] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	19.7	ug/l	EPA .200.8	2	07/20/2018 11:44 CSG

MARTEL NO. 40020 000035 CLIENT SAMPLE IDENTIFICATION Media Center Bubbler (RIGHT) [DF--C] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	50.8	ug/l*	EPA .200.8	2	07/20/2018 11:46 CSG

MARTEL NO. 40020 000036 CLIENT SAMPLE IDENTIFICATION Mens Bathroom A160 (new additon) Hand Sink [BS--NC] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 11:49 CSG

MARTEL NO. 40020 000037 CLIENT SAMPLE IDENTIFICATION Girls Bathroom A161 (new addition) Hand Sink [BS--NC] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 11:51 CSG



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
40020 000038	Boys Bathroom - instructional area (bottom, left, front) Han					04/25/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	10.5	ug/l	EPA .200.8	2	07/20/2018 11:54 CSG	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
40020 000039	Boys Bathroom - instructional area (bottom, left, front) Han					04/25/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	16.1	ug/l	EPA .200.8	2	07/20/2018 11:56 CSG	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
40020 000040	Boys Bathroom - instructional area (bottom, left, front) Han					04/25/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	5.18	ug/l	EPA .200.8	2	07/20/2018 11:59 CSG	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
40020 000041	Custodial Closet(bottom, left, front) Slop Sink [OT--NC]					04/25/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.40	ug/l	EPA .200.8	2	07/20/2018 12:06 CSG	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
40020 000042	Fixture (bottom, left, front) Gooseneck [CR--NC]					04/25/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 12:14 CSG	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
40020 000043	Fixture (bottom, left, front) Bubbler (LEFT) [DF--C]					04/25/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.70	ug/l	EPA .200.8	2	07/20/2018 12:16 CSG	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
40020 000044	Fixture (bottom, left, front) Bubbler (RIGHT) [DF--C]					04/25/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	9.67	ug/l	EPA .200.8	2	07/20/2018 12:19 CSG	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
40020 000045	Fixtures opposite sampls 42-44 (bottom, left, front) Goosene					04/25/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.59	ug/l	EPA .200.8	2	07/20/2018 12:21 CSG	



Certificate of Analysis

MARTEL NO. 40020 000046 CLIENT SAMPLE IDENTIFICATION Fixtures opposite sampls 42-44 (bottom, left, front) Bubbler Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 12:24 CSG

MARTEL NO. 40020 000048 CLIENT SAMPLE IDENTIFICATION Fixture (bottom, left, rear) Gooseneck [CR--NC] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 12:26 CSG

MARTEL NO. 40020 000049 CLIENT SAMPLE IDENTIFICATION Fixture (bottom, left, rear) Bubbler (LEFT) [DF--C] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.25	ug/l	EPA .200.8	2	07/20/2018 12:29 CSG

MARTEL NO. 40020 000050 CLIENT SAMPLE IDENTIFICATION Fixture (bottom, left, rear) Bubbler (RIGHT) [DF--C] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.28	ug/l	EPA .200.8	2	07/20/2018 12:31 CSG

MARTEL NO. 40020 000051 CLIENT SAMPLE IDENTIFICATION Girls Bathroom (bottom, left, rear) Hand Sink (LEFT) [BS--] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.00	ug/l	EPA .200.8	2	07/20/2018 12:41 CSG

MARTEL NO. 40020 000052 CLIENT SAMPLE IDENTIFICATION Girls Bathroom (bottom, left, rear) Hand Sink (CENTER) [BS] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.12	ug/l	EPA .200.8	2	07/20/2018 12:46 CSG

MARTEL NO. 40020 000054 CLIENT SAMPLE IDENTIFICATION Fixture opposite samples 48-50 (bottom, left, rear) Gooseneck Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.17	ug/l	EPA .200.8	2	07/20/2018 12:49 CSG

MARTEL NO. 40020 000055 CLIENT SAMPLE IDENTIFICATION Fixture opposite samples 48-50 (bottom, left, rear) Bubbler Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	35.9	ug/l*	EPA .200.8	2	07/20/2018 12:51 CSG



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40020 000056	Fixture opposite samples 48-50 (bottom, left, rear) Bubbler	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	5.32 ug/l EPA .200.8 2	07/20/2018 12:54 CSG
40020 000057	Fixture (bottom, right, rear) Goosneck [CR--NC]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.80 ug/l EPA .200.8 2	07/20/2018 12:56 CSG
40020 000058	Fixture (bottom, right, rear) Bubbler [DF--C]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/20/2018 12:59 CSG
40020 000060	Boys Bathroom (bottom, right, rear) Hand Sink (LEFT) [BS--	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.83 ug/l EPA .200.8 2	07/20/2018 13:04 CSG
40020 000061	Boys Bathroom (bottom, right, rear) Hand Sink (CENTER) [BS	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.71 ug/l EPA .200.8 2	07/20/2018 13:11 CSG
40020 000062	Boys Bathroom (bottom, right, rear) Hand Sink (RIGHT) [BS-	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.24 ug/l EPA .200.8 2	07/20/2018 13:19 CSG
40020 000063	Fixtures opposite samples 57, 58 (bottom, right, rear) Goose	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/20/2018 13:22 CSG
40020 000064	Fixtures opposite samples 57, 58 (bottom, right, rear) Bubbl	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/20/2018 13:24 CSG



MARTEL NO. 40020 000065 CLIENT SAMPLE IDENTIFICATION Fixtures opposite samples 57, 58 (bottom, right, rear) Bubbl Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	265	ug/l*	EPA .200.8	2	07/20/2018 20:26 CSG

MARTEL NO. 40020 000066 CLIENT SAMPLE IDENTIFICATION Custodial Closet next to sample 63-65 (bottom, right, rear) Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 13:29 CSG

MARTEL NO. 40020 000067 CLIENT SAMPLE IDENTIFICATION Fixture next to Facility Resource III (bottom, right, front) Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.33	ug/l	EPA .200.8	2	07/20/2018 13:32 CSG

MARTEL NO. 40020 000068 CLIENT SAMPLE IDENTIFICATION Fixture next to Facility Resource III (bottom, right, front) Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.35	ug/l	EPA .200.8	2	07/20/2018 13:34 CSG

MARTEL NO. 40020 000069 CLIENT SAMPLE IDENTIFICATION Fixture next to Facility Resource III (bottom, right, front) Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 13:37 CSG

MARTEL NO. 40020 000070 CLIENT SAMPLE IDENTIFICATION Girls Bathroom (bottom, right, front) Hand Sink (LEFT) [BS] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.71	ug/l	EPA .200.8	2	07/20/2018 13:39 CSG

MARTEL NO. 40020 000071 CLIENT SAMPLE IDENTIFICATION Girls Bathroom (bottom, right, front) Hand Sink (CENTER) [Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 13:49 CSG

MARTEL NO. 40020 000072 CLIENT SAMPLE IDENTIFICATION Girls Bathroom (bottom, right, front) Hand Sink (RIGHT) [B] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.47	ug/l	EPA .200.8	2	07/20/2018 13:54 CSG



Certificate of Analysis

MARTEL NO. 40020 000073 CLIENT SAMPLE IDENTIFICATION Fixture opposite samples 67-69 (bottom, right, front) Goosen Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 13:57 CSG

MARTEL NO. 40020 000074 CLIENT SAMPLE IDENTIFICATION (bottom, right, front) Bubbler [DF--C] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 13:59 CSG

MARTEL NO. 40020 000075 CLIENT SAMPLE IDENTIFICATION Boys Bathroom across from Storage VI (top, left, front) Hand Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.19	ug/l	EPA .200.8	2	07/20/2018 14:02 CSG

MARTEL NO. 40020 000076 CLIENT SAMPLE IDENTIFICATION Boys Bathroom across from Storage VI (top, left, front) Hand Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.86	ug/l	EPA .200.8	2	07/20/2018 14:04 CSG

MARTEL NO. 40020 000077 CLIENT SAMPLE IDENTIFICATION Boys Bathroom across from Storage VI (top, left, front) Hand Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.02	ug/l	EPA .200.8	2	07/20/2018 14:07 CSG

MARTEL NO. 40020 000078 CLIENT SAMPLE IDENTIFICATION Custodial Closet (top, left, front) Slop Sink [OT--NC] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.16	ug/l	EPA .200.8	2	07/20/2018 14:09 CSG

MARTEL NO. 40020 000079 CLIENT SAMPLE IDENTIFICATION Fixtures (top, left, front) Gooseneck [CR--NC] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 14:12 CSG

MARTEL NO. 40020 000080 CLIENT SAMPLE IDENTIFICATION Fixtures (top, left, front) Bubbler (LEFT) [DF--C] Sample Date/Time 04/25/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	07/20/2018 14:14 CSG



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40020 000081	Fixtures (top, left, front) Bubbler (RIGHT) [DF--C]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.49 ug/l EPA .200.8 2	07/20/2018 14:22 CSG
40020 000082	Fixtures opposite samples 79-80 (top, left, front) Gooseneck	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	9.04 ug/l EPA .200.8 2	07/20/2018 14:29 CSG
40020 000083	Fixtures opposite samples 79-80 (top, left, front) Bubbler (04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	19.3 ug/l EPA .200.8 2	07/20/2018 14:32 CSG
40020 000084	Fixtures opposite samples 79-80 (top, left, front) Bubbler (04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	12.1 ug/l EPA .200.8 2	07/20/2018 14:35 CSG
40020 000085	Fixtures (top, left, rear) Gooseneck [CR--NC]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	4.12 ug/l EPA .200.8 2	07/20/2018 14:37 CSG
40020 000086	Fixtures (top, left, rear) Bubbler (LEFT) [DF--C]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	20.5 ug/l EPA .200.8 2	07/20/2018 14:40 CSG
40020 000087	Fixtures (top, left, rear) Bubbler (RIGHT) [DF--C]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.96 ug/l EPA .200.8 2	07/20/2018 14:42 CSG
40020 000088	Girls Bathroom (top, left, rear) Hand Sink (LEFT) [BS--NC]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	12.7 ug/l EPA .200.8 2	07/20/2018 14:45 CSG



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40020 000089	Girls Bathroom (top, left, rear) Hand Sink (CENTER) [BS--N]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/20/2018 14:47 CSG
40020 000090	Girls Bathroom (top, left, rear) Hand Sink (RIGHT) [BS--NC]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/20/2018 14:50 CSG
40020 000091	Fixtures opposite samples 85-87 (top, left, rear) Gooseneck	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	22.6 ug/l* EPA .200.8 2	07/20/2018 15:00 CSG
40020 000092	Fixtures opposite samples 85-87 (top, left, rear) Bubbler (L)	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	18.9 ug/l EPA .200.8 2	07/20/2018 15:05 CSG
40020 000093	Fixtures opposite samples 85-87 (top, left, rear) Bubbler (R)	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	29.7 ug/l* EPA .200.8 2	07/20/2018 15:07 CSG
40020 000094	Custodial Closet (top, right, rear) Slop Sink [OT--NC]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	11.9 ug/l EPA .200.8 2	07/20/2018 15:10 CSG
40020 000095	Boys Bathroom (top, right, rear) Hand Sink (LEFT) [BS--NC]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.54 ug/l EPA .200.8 2	07/20/2018 15:12 CSG
40020 000096	Boys Bathroom (top, right, rear) Hand Sink (CENTER) [BS--N]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.90 ug/l EPA .200.8 2	07/20/2018 15:15 CSG



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40020 000097	Boys Bathroom (top, right, rear) Hand Sink (RIGHT) [BS--NC]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	6.49 ug/l EPA .200.8 2	07/20/2018 15:17 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40020 000098	Fixtures(top, right, rear) Gooseneck [CR--NC]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	4.33 ug/l EPA .200.8 2	07/20/2018 15:20 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40020 000099	Fixtures(top, right, rear) Bubbler (LEFT) [DF--C]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	07/20/2018 15:22 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40020 000100	Fixtures(top, right, rear) Bubbler (RIGHT) [DF--C]	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.89 ug/l EPA .200.8 2	07/20/2018 15:25 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40020 000102	Fixtures near Facility Resources (top, right, front) Goosene	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.25 ug/l EPA .200.8 2	07/20/2018 15:40 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40020 000103	Fixtures near Facility Resources (top, right, front) Bubbler	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.72 ug/l EPA .200.8 2	07/20/2018 15:43 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40020 000104	Fixtures near Facility Resources (top, right, front) Bubbler	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	1950 ug/l* EPA .200.8 2	07/20/2018 20:28 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40020 000105	Girls Bathroom across from Storage F (top, right, front) Han	04/25/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.93 ug/l EPA .200.8 2	07/20/2018 15:48 CSG



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40020 000106	Girls Bathroom across from Storage F (top, right, front) Han	04/25/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	27.3	ug/l*	EPA .200.8	2	07/20/2018 15:50 CSG

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40020 000107	Girls Bathroom across from Storage F (top, right, front) Han	04/25/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.29	ug/l	EPA .200.8	2	07/20/2018 15:53 CSG

Page 14 OF 14

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

stddl.frx

Notes and references:

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date. 40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

* results exceeded 20.5 ug/l.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.



Project Manager

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Anne Arundel County Public Schools Drinking Water Lead Testing

Sample Date/Start Time: 5:00 A

End time: 7:00 A

Bottle Type/Preservative: 250 ml plastic/HNO3

Analysis: Lead (EPA 200.8)

Samples preserved properly Yes or No

NOTES:

Sampled/Relinquished by: [Signature]

Received at Martel by: JCW

Date/Time: 4-25-18 13:00

High Point ES (2132) Martel No. 40020

924 Duvall Highway, Pasadena, MD 21122

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE
SAMPLING BETWEEN THE HOURS OF 8PM AND 9PM**

1	Main Office Bathroom	Hand Sink	BS	NC
2	Health Room	Hand Sink	NO	NC
3	Health Room Bathroom	Hand Sink	BS	NC
4	Custodial Closet (next to health room)	Slop Sink X	OT	NC
5	Kindergarten	Hand Sink (outside bathroom)	CR	NC
6	Kindergarten	Bubbler (right)	DF	C
7	Kindergarten	Bubbler (left)	DF	C
8	Kindergarten	Gooseneck (right)	CR	NC
9	Kindergarten	Gooseneck (left)	CR	NC
10	Kindergarten	Hand Sink (inside bathroom)	BS	NC
11	Boys Bathroom Main Hall (across from Café)	Hand Sink (LEFT)	BS	NC
12	Boys Bathroom Main Hall (across from Café)	Hand Sink (RIGHT)	BS	NC
13	Girls Bathroom Main Hall (across from Café)	Hand Sink (LEFT)	BS	NC
14	Girls Bathroom Main Hall (across from Café)	Hand Sink (RIGHT)	BS	NC
15	Kitchen - Serving Area	Gooseneck	KS	C
16	Kitchen - Double Sink	Gooseneck	KS	NC
17	Kitchen - Tri-Sink	Gooseneck (LEFT)	KS	C
18	Kitchen - Tri-Sink	Gooseneck (RIGHT)	KS	C
19	Kitchen (across from tri-sink)	Hand Sink	KS	C
20	Kitchen - Custodial Area	Slop Sink X	OT	NC
21	Kitchen - Bathroom	Hand Sink	BS	NC
22	Kitchen - tray storage area	Hand Sink	OT	NC
23	Gym - PE Office Bathroom	Hand Sink	BS	NC
24	Gym Hallway	Water Fountain	DF	C
25	Gym Hallway - Girls Bathroom	Hand Sink	BS	NC
26	Gym Hallway - Boys Bathroom	Hand Sink	BS	NC
27	Teachers Lounge	Gooseneck	TL	NC
28	Art Room A110 - Kiln Room A130A	Slop Sink X	OT	NC
29	Art Room A110	Bubbler (RIGHT)	DF	C
30	Art Room A110	Gooseneck (RIGHT)	CR	NC
31	Art Room A110	Bubbler (LEFT)	DF	C

High Point ES (2132) Martel No. 40020

924 Duvall Highway, Pasadena, MD 21122

32	Art Room A110	Bubbler (RIGHT)	DF	C
33	Media Center	Gooseneck	OT	NC
34	Media Center	Bubbler (LEFT)	DF	C
35	Media Center	Bubbler (RIGHT)	DF	C
36	Mens Bathroom A160 (new additon)	Hand Sink	BS	NC
37	Girls Bathroom A161 (new addition)	Hand Sink	BS	NC
38	Boys Bathroom - instructional area (bottom, left, front)	Hand Sink (LEFT)	BS	NC
39	Boys Bathroom - instructional area (bottom, left, front)	Hand Sink (CENTER)	BS	NC
40	Boys Bathroom - instructional area (bottom, left, front)	Hand Sink (RIGHT)	BS	NC
41	Custodial Closet(bottom, left, front)	Slop Sink X	OT	NC
42	Fixture (bottom, left, front)	Gooseneck	CR	NC
43	Fixture (bottom, left, front)	Bubbler (LEFT)	DF	C
44	Fixture (bottom, left, front)	Bubbler (RIGHT)	DF	C
45	Fixtures opposite sampls 42-44 (bottom, left, front)	Gooseneck	CR	NC
46	Fixtures opposite sampls 42-44 (bottom, left, front)	Bubbler (LEFT)	DF	C
47	Fixtures opposite sampls 42-44 (bottom, left, front)	Bubbler (RIGHT)	DF	C
48	Fixture (bottom, left, rear)	Gooseneck	CR	NC
49	Fixture (bottom, left, rear)	Bubbler (LEFT)	DF	C
50	Fixture (bottom, left, rear)	Bubbler (RIGHT)	DF	C
51	Girls Bathroom (bottom, left, rear)	Hand Sink (LEFT)	BS	NC
52	Girls Bathroom (bottom, left, rear)	Hand Sink (CENTER)	BS	NC
53	Girls Bathroom (bottom, left, rear)	Hand Sink (RIGHT)	BS	NC
54	Fixture opposite samples 48-50 (bottom, left, rear)	Gooseneck	CR	NC
55	Fixture opposite samples 48-50 (bottom, left, rear)	Bubbler (LEFT)	DF	C
56	Fixture opposite samples 48-50 (bottom, left, rear)	Bubbler (RIGHT)	DF	C
57	Fixture (bottom, right, rear)	Goosneck	CR	NC
58	Fixture (bottom, right, rear)	Bubbler	DF	C
59	Custodial Closet (bottom, right, rear)	Slop Sink X	CR	NC
60	Boys Bathroom (bottom, right, rear)	Hand Sink (LEFT)	BS	NC
61	Boys Bathroom (bottom, right, rear)	Hand Sink (CENTER)	BS	NC
62	Boys Bathroom (bottom, right, rear)	Hand Sink (RIGHT)	BS	NC
63	Fixtures opposite samples 57, 58 (bottom, right, rear)	Gooseneck	CR	NC
64	Fixtures opposite samples 57, 58 (bottom, right, rear)	Bubbler (LEFT)	DF	C
65	Fixtures opposite samples 57, 58 (bottom, right, rear)	Bubbler (RIGHT)	DF	C
66	Custodail Closet next to sample 63-65 (bottom, right, rear)	Slop Sink X	OT	NC
67	Fixture next to Facility Resource III (bottom, right, front)	Gooseneck	CR	NC
68	Fixture next to Facility Resource III (bottom, right, front)	Bubbler (LEFT)	DF	C
69	Fixture next to Facility Resource III (bottom, right, front)	Bubbler (RIGHT)	DF	C

High Point ES (2132) Martel No. 40020

924 Duvall Highway, Pasadena, MD 21122

70	Girls Bathroom (bottom, right, front)	Hand Sink (LEFT)	BS	NC
71	Girls Bathroom (bottom, right, front)	Hand Sink (CENTER)	BS	NC
72	Girls Bathroom (bottom, right, front)	Hand Sink (RIGHT)	BS	NC
73	Fixture opposite samples 67-69 (bottom, right, front)	Gooseneck	CR	NC
74	(bottom, right, front)	Bubbler	DF	C
75	Boys Bathroom across from Storage VI (top, left, front)	Hand Sink (LEFT)	BS	NC
76	Boys Bathroom across from Storage VI (top, left, front)	Hand Sink (CENTER)	BS	NC
77	Boys Bathroom across from Storage VI (top, left, front)	Hand Sink (RIGHT)	BS	NC
78	Custodial Closet (top, left, front)	Slop Sink X	OT	NC
79	Fixtures (top, left, front)	Gooseneck	CR	NC
80	Fixtures (top, left, front)	Bubbler (LEFT)	DF	C
81	Fixtures (top, left, front)	Bubbler (RIGHT)	DF	C
82	Fixtures opposite samples 79-80 (top, left, front)	Gooseneck	CR	NC
83	Fixtures opposite samples 79-80 (top, left, front)	Bubbler (LEFT)	DF	C
84	Fixtures opposite samples 79-80 (top, left, front)	Bubbler (RIGHT)	DF	C
85	Fixtures (top, left, rear)	Gooseneck	CR	NC
86	Fixtures (top, left, rear)	Bubbler (LEFT)	DF	C
87	Fixtures (top, left, rear)	Bubbler (RIGHT)	DF	C
88	Girls Bathroom (top, left, rear)	Hand Sink (LEFT)	BS	NC
89	Girls Bathroom (top, left, rear)	Hand Sink (CENTER)	BS	NC
90	Girls Bathroom (top, left, rear)	Hand Sink (RIGHT)	BS	NC
91	Fixtures opposite samples 85-87 (top, left, rear)	Gooseneck	CR	NC
92	Fixtures opposite samples 85-87 (top, left, rear)	Bubbler (LEFT)	DF	C
93	Fixtures opposite samples 85-87 (top, left, rear)	Bubbler (RIGHT)	DF	C
94	Custodial Closet (top, right, rear)	Slop Sink X	OT	NC
95	Boys Bathroom (top, right, rear)	Hand Sink (LEFT)	BS	NC
96	Boys Bathroom (top, right, rear)	Hand Sink (CENTER)	BS	NC
97	Boys Bathroom (top, right, rear)	Hand Sink (RIGHT)	BS	NC
98	Fixtures(top, right, rear)	Gooseneck	CR	NC
99	Fixtures(top, right, rear)	Bubbler (LEFT)	DF	C
100	Fixtures(top, right, rear)	Bubbler (RIGHT)	DF	C
101	Custodial Closet (top, right, rear)	Slop Sink X	OT	NC
102	Fixtures near Facility Resources (top, right, front)	Gooseneck	CR	NC
103	Fixtures near Facility Resources (top, right, front)	Bubbler (LEFT)	DF	C
104	Fixtures near Facility Resources (top, right, front)	Bubbler (RIGHT)	DF	C
105	Girls Bathroom across from Storage F (top, right, front)	Hand Sink (LEFT)	BS	NC
106	Girls Bathroom across from Storage F (top, right, front)	Hand Sink (CENTER)	BS	NC
107	Girls Bathroom across from Storage F (top, right, front)	Hand Sink (RIGHT)	BS	NC