

Lead in Drinking Water – Public and Nonpublic Schools

IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT(S) **Corkran Middle School**

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On April 28, 2018, **one hundred fourteen (114)** lead water samples were collected from **Corkran Middle School**. Of these lead water samples, twenty-three (23) had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings. The elevated lead result from the sample(s) collected at Corkran Middle School were as follows:

Sample Number 000027-303 Gooseneck: 23.6 ppb (non-consumable).
Sample Number 000029- 305 Gooseneck (Center): 334 ppb (non-consumable).
Sample Number 000031-309 Gooseneck (Right): 334 ppb (non-consumable).
Sample Number 000032-309 Gooseneck (Center): 924 ppb (non-consumable).
Sample Number 000038-315 Gooseneck (Center): 81.8 ppb (non-consumable).
Sample Number 000042-317 Sprayer (Left): 22.8 ppb (non-consumable).
Sample Number 000054-121 Gooseneck (Left): 39.4 ppb (non-consumable).
Sample Number 000055-122 Bubbler (Right): 22.7 ppb (consumable).
Sample Number 000081-336 Hand Sink (Right): 20.8 ppb (non-consumable).
Sample Number 000082-334 Hand Sink (Corner): 60.5 ppb (non-consumable).
Sample Number 000083-334 Hand Sink (Left): 54.0 ppb (non-consumable).
Sample Number 000084-334 Hand Sink (Right): 25.2 ppb (non-consumable).
Sample Number 000085-332 Hand Sink (Corner Left): 139 ppb (non-consumable).
Sample Number 000087-332 Hand Sink (Left): 69.1 ppb (non-consumable).
Sample Number 000092-330 Sink (Left): 74.0 ppb (non-consumable).
Sample Number 000095-314/320 Laundry Hand Sink: 49.3 ppb (non-consumable).
Sample Number 000106-308 Hand Sink: 45.1 ppb (non-consumable).
Sample Number 000107-302/308 Laundry Room Hand Sink: 40.2 ppb (non-consumable).
Sample Number 000109-302 Sink (Hall Side Center): 180 ppb (non-consumable).
Sample Number 000111-302 Sink (Rear of Room Left): 485 ppb (non-consumable).
Sample Number 000121-Girls Locker Room Hand Sink (Right): 42.1 ppb (non-consumable).
Sample Number 000125-Boys Locker Room Hand Sink (Center): 29.9 ppb (non-consumable).
Sample Number 000126-Boys Locker Room Hand Sink (Right): 83.6 ppb (non-consumable).

ACTION LEVEL (AL)

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the work place and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

IMMEDIATE ACTIONS TAKEN

1. The one (1) consumable water source consisting of a bubbler will be shut off immediately.
2. This one (1) consumable source will be retested in accordance with the regulations.
3. Twenty-two (22) non-consumable water sources consisting of goosenecks and hand sinks will be retested and posted with green signage indicating "Hand Washing Only".

NEXT STEPS

1. One (1) consumable water source plumbing fixture will be replaced and retested in accordance with the regulations.
2. All twenty-two (22) non-consumable water sources will be replaced and retested in accordance with the regulations.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

1. For additional information, please contact Chris Williams, Environmental Issues Program Manager, at 410-360-0138. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.



AACPS - Operations Division
9034 Ft. Smallwood Road

Monday, September 24, 2018

Pasadena, MD 21122

Attention: Chris Williams

Certificate of Analysis

FINAL

Report for Lab No: 40030.

Corkran MS (1043)

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 9212

Sampling by Martel personnel on April 28, 2018 by Lauren Couch.

Samples analyzed according to method requirements and QC exceptions available.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40030	000001	Principals Office Hand Sink [OT--NC]	04/28/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.01	ug/l	EPA .200.8	2	08/31/2018 14:24 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40030	000002	Main Office Bathroom Hand Sink [BS--NC]	04/28/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 14:36 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40030	000003	Guidance Bathroom Hand Sink (LEFT) [BS--NC]	04/28/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.03	ug/l	EPA .200.8	2	08/31/2018 14:39 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40030	000004	Guidance Bathroom Hand Sink (RIGHT) [BS--NC]	04/28/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	7.53	ug/l	EPA .200.8	2	08/31/2018 14:41 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40030	000005	Financial Sec. Office Hand Sink [OT--NC]	04/28/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 14:44 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40030	000006	Girls Bathroom Hallway (acroos from Guidance) Hand Sink	04/28/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	



MARTEL NO. 40030 000006 CLIENT SAMPLE IDENTIFICATION: Girls Bathroom Hallway (acroos from Guidance) Hand Sink Sample Date/Time: 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.61	ug/l	EPA .200.8	2	08/31/2018 14:46 BJ

MARTEL NO. 40030 000007 CLIENT SAMPLE IDENTIFICATION: Girls Bathroom Hallway (acroos from Guidance) Hand Sink Sample Date/Time: 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 14:49 BJ

MARTEL NO. 40030 000008 CLIENT SAMPLE IDENTIFICATION: Girls Bathroom Hallway (acroos from Guidance) Hand Sink Sample Date/Time: 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 14:51 BJ

MARTEL NO. 40030 000009 CLIENT SAMPLE IDENTIFICATION: Hall Fountain (Outside of samples 6-8) Water Fountain [DF- Sample Date/Time: 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 14:54 BJ

MARTEL NO. 40030 000011 CLIENT SAMPLE IDENTIFICATION: Media Work Room Kitchen Gooseneck [OT--NC] Sample Date/Time: 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 15:06 BJ

MARTEL NO. 40030 000012 CLIENT SAMPLE IDENTIFICATION: Hall Fountain (across from main entrance) Water Fountain Sample Date/Time: 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 15:12 BJ

MARTEL NO. 40030 000013 CLIENT SAMPLE IDENTIFICATION: Girls Bathroom 203 (across from main entrance) Hand Sink (L Sample Date/Time: 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 15:14 BJ

MARTEL NO. 40030 000014 CLIENT SAMPLE IDENTIFICATION: Girls Bathroom 203 (across from main entrance) Hand Sink (C Sample Date/Time: 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 15:17 BJ



MARTEL NO. 40030 000015 CLIENT SAMPLE IDENTIFICATION: Girls Bathroom (across from main entrance) Hand Sink (R) Sample Date/Time: 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 15:19 BJ

MARTEL NO. 40030 000016 CLIENT SAMPLE IDENTIFICATION: Boys Bathroom (across from main entrance) Hand Sink Sample Date/Time: 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.01	ug/l	EPA .200.8	2	08/31/2018 15:21 BJ

MARTEL NO. 40030 000017 CLIENT SAMPLE IDENTIFICATION: Boys Bathroom (across from main entrance) Hand Sink (LEFT) Sample Date/Time: 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 15:24 BJ

MARTEL NO. 40030 000018 CLIENT SAMPLE IDENTIFICATION: Boys Bathroom (across from main entrance) Hand Sink Sample Date/Time: 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 15:26 BJ

MARTEL NO. 40030 000019 CLIENT SAMPLE IDENTIFICATION: Boys Bathroom (across from main entrance) Hand Sink Sample Date/Time: 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 15:29 BJ

MARTEL NO. 40030 000022 CLIENT SAMPLE IDENTIFICATION: Womans Bathroom (across from gym) Hand Sink (LEFT) Sample Date/Time: 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 15:47 BJ

MARTEL NO. 40030 000023 CLIENT SAMPLE IDENTIFICATION: Womans Bathroom (across from gym) Hand Sink (RIGHT) Sample Date/Time: 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.44	ug/l	EPA .200.8	2	08/31/2018 15:49 BJ

MARTEL NO. 40030 000024 CLIENT SAMPLE IDENTIFICATION: Mens Bathroom (across from gym) Hand Sink (LEFT) Sample Date/Time: 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 15:51 BJ



MARTEL NO. 40030 000025 CLIENT SAMPLE IDENTIFICATION Mens Bathroom (across from gym) Hand Sink (RIGHT) Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 15:54 BJ

MARTEL NO. 40030 000026 CLIENT SAMPLE IDENTIFICATION Hall Fountain (next to 303) Water Fountain [DF--C] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 15:56 BJ

MARTEL NO. 40030 000027 CLIENT SAMPLE IDENTIFICATION 303 Gooseneck [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	23.6	ug/l*	EPA .200.8	2	08/31/2018 15:59 BJ

MARTEL NO. 40030 000028 CLIENT SAMPLE IDENTIFICATION 305 Gooseneck (RIGHT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.15	ug/l	EPA .200.8	2	08/31/2018 16:01 BJ

MARTEL NO. 40030 000029 CLIENT SAMPLE IDENTIFICATION 305 Gooseneck (CENTER) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	334	ug/l*	EPA .200.8	2	08/31/2018 10:49 BJ

MARTEL NO. 40030 000030 CLIENT SAMPLE IDENTIFICATION 305 Sprayer (LEFT) [OT--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.63	ug/l	EPA .200.8	2	08/31/2018 16:06 BJ

MARTEL NO. 40030 000031 CLIENT SAMPLE IDENTIFICATION 309 Gooseneck (RIGHT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	80.2	ug/l*	EPA .200.8	2	08/31/2018 16:16 BJ

MARTEL NO. 40030 000032 CLIENT SAMPLE IDENTIFICATION 309 Gooseneck (CENTER) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	924	ug/l*	EPA .200.8	2	08/31/2018 10:51 BJ



MARTEL NO. 40030 000033 CLIENT SAMPLE IDENTIFICATION 309 Sprayer (LEFT) [OT--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.19	ug/l	EPA .200.8	2	08/31/2018 16:24 BJ

MARTEL NO. 40030 000034 CLIENT SAMPLE IDENTIFICATION 313 Gooseneck (RIGHT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	10.5	ug/l	EPA .200.8	2	08/31/2018 16:26 BJ

MARTEL NO. 40030 000035 CLIENT SAMPLE IDENTIFICATION 313 Gooseneck (CENTER) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.91	ug/l	EPA .200.8	2	08/31/2018 16:29 BJ

MARTEL NO. 40030 000036 CLIENT SAMPLE IDENTIFICATION 313 Sprayer (LEFT) [OT--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.91	ug/l	EPA .200.8	2	08/31/2018 16:31 BJ

MARTEL NO. 40030 000037 CLIENT SAMPLE IDENTIFICATION 315 Gooseneck (RIGHT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.14	ug/l	EPA .200.8	2	08/31/2018 16:34 BJ

MARTEL NO. 40030 000038 CLIENT SAMPLE IDENTIFICATION 315 Gooseneck (CENTER) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	81.8	ug/l*	EPA .200.8	2	08/31/2018 16:36 BJ

MARTEL NO. 40030 000039 CLIENT SAMPLE IDENTIFICATION 315 Sprayer (LEFT) [OT--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	/ /

MARTEL NO. 40030 000040 CLIENT SAMPLE IDENTIFICATION 317 Gooseneck (RIGHT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 16:41 BJ



MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000041 317 Gooseneck (CENTER) [CR--NC] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.99	ug/l	EPA .200.8	2	08/31/2018 16:49 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000042 317 Sprayer (LEFT) [OT--NC] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	22.8	ug/l*	EPA .200.8	2	08/31/2018 16:56 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000043 Girls Bathroom (across from café) Hand Sink (LEFT) [BS--NC] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.84	ug/l	EPA .200.8	2	08/31/2018 16:58 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000044 Girls Bathroom (across from café) Hand Sink (CENTER) [BS--] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.98	ug/l	EPA .200.8	2	08/31/2018 17:01 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000045 Girls Bathroom (across from café) Hand Sink (RIGHT) [BS--N] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.27	ug/l	EPA .200.8	2	08/31/2018 17:04 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000046 Hall Fountain (across from café) Water Fountain [DF--C] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 17:06 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000047 Boys Bathroom (next to room 121) Hand Sink (LEFT) 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 17:08 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000048 Boys Bathroom (next to room 121) Hand Sink (LEFT CENTER) 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 17:11 BJ



MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Boys Bathroom (next to room 121) Hand Sink (RIGHT) Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 17:13 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Boys Bathroom (next to room 121) Hand Sink (RIGHT) Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 17:16 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Custodial Closet (next to room 121) Slop Sink [OT--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 17:26 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION 121 Bubbler (RIGHT) [DF--C] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.09	ug/l	EPA .200.8	2	08/31/2018 17:31 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION 121 Gooseneck (CENTER) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 17:33 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION 121 Gooseneck (LEFT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	39.4	ug/l*	EPA .200.8	2	08/31/2018 17:36 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION 122 Bubbler (RIGHT) [DF--C] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	22.7	ug/l*	EPA .200.8	2	08/31/2018 17:38 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION 122 Gooseneck (CENTER) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	12.8	ug/l	EPA .200.8	2	08/31/2018 17:41 BJ



MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION 122 Gooseneck (LEFT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.54	ug/l	EPA .200.8	2	08/31/2018 17:43 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Art 3 Bubbler (RIGHT) [DF--C] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.2	ug/l	EPA .200.8	2	08/31/2018 17:46 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Art 3 Gooseneck (CENTER) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.54	ug/l	EPA .200.8	2	08/31/2018 17:48 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Art 3 Gooseneck (LEFT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.82	ug/l	EPA .200.8	2	08/31/2018 17:51 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION 124 Hand Sink [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.39	ug/l	EPA .200.8	2	08/31/2018 17:59 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Hall Fountain (next to room 124) Water Fountain [DF--C] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 18:06 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Teachers Lounge Mens Bathroom Hand Sink [BS--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 18:09 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Teachers Lounge Hand Sink [TL--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 18:11 BJ



MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000065 Teachers Lounge Womens Bathroom Hand Sink (LEFT) 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 18:14 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000066 Teachers Lounge Womens Bathroom Hand Sink (RIGHT) 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 18:16 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000067 Receiving Hand Sink [OT--NC] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 18:19 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000068 Engineers Office Hand Sink [OT--NC] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.3	ug/l	EPA .200.8	2	08/31/2018 18:21 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000069 Café Fountain Water Fountain (LEFT) [DF--C] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 18:24 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000070 Café Fountain Water Fountain (RIGHT) [DF--C] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 18:26 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000071 Kitchen (serving area) Hand Sink [KS--C] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 18:36 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000072 Kitchen Tri Sink Gooseneck (LEFT) [KS--C] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 18:41 BJ



MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000073 Kitchen Tri Sink Gooseneck (RIGHT) [KS--C] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 18:44 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000075 Kitchen Bathroom Hand Sink [BS--NC] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 18:49 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000077 Kitchen Tri Sink (left of kitchen bathroom) Gooseneck (LEFT) 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 18:54 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000078 Kitchen Tri Sink (left of kitchen bathroom) Gooseneck (RIGHT) 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 18:56 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000079 336 hand Sink (corner) [CR--NC] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	/ /

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000080 336 hand sink (LEFT) [CR--NC] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.67	ug/l	EPA .200.8	2	08/31/2018 19:01 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000081 336 Hand Sink (RIGHT) [CR--NC] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	20.8	ug/l*	EPA .200.8	2	08/31/2018 19:09 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000082 334 hand Sink (corner) [CR--NC] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	60.5	ug/l*	EPA .200.8	2	08/31/2018 19:16 BJ



MARTEL NO. 40030 000083 CLIENT SAMPLE IDENTIFICATION 334 hand sink (LEFT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	54.0	ug/l*	EPA .200.8	2	08/31/2018 19:19 BJ

MARTEL NO. 40030 000084 CLIENT SAMPLE IDENTIFICATION 334 Hand Sink (RIGHT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	25.2	ug/l*	EPA .200.8	2	08/31/2018 19:21 BJ

MARTEL NO. 40030 000085 CLIENT SAMPLE IDENTIFICATION 332 Hand Sink (CORNER LEFT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	139	ug/l*	EPA .200.8	2	08/31/2018 19:24 BJ

MARTEL NO. 40030 000086 CLIENT SAMPLE IDENTIFICATION 332 Hand Sink (CORNER RIGHT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//

MARTEL NO. 40030 000087 CLIENT SAMPLE IDENTIFICATION 332 Hand Sink (LEFT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	69.1	ug/l*	EPA .200.8	2	08/31/2018 10:54 BJ

MARTEL NO. 40030 000088 CLIENT SAMPLE IDENTIFICATION 332 Hand Sink (RIGHT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.28	ug/l	EPA .200.8	2	08/31/2018 19:31 BJ

MARTEL NO. 40030 000089 CLIENT SAMPLE IDENTIFICATION 330 Sink (CORNER LEFT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//

MARTEL NO. 40030 000090 CLIENT SAMPLE IDENTIFICATION 330 Sink (CORNER CENTER) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//



MARTEL NO. 40030 000091 CLIENT SAMPLE IDENTIFICATION 330 Sink (CORNER RIGHT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	/ / :

MARTEL NO. 40030 000092 CLIENT SAMPLE IDENTIFICATION 330 Sink (LEFT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	74.0	ug/l*	EPA .200.8	2	08/31/2018 19:46 BJ

MARTEL NO. 40030 000093 CLIENT SAMPLE IDENTIFICATION 330 Sink (RIGHT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.24	ug/l	EPA .200.8	2	08/31/2018 19:54 BJ

MARTEL NO. 40030 000094 CLIENT SAMPLE IDENTIFICATION 320 Hand Sink [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	13.5	ug/l	EPA .200.8	2	08/31/2018 19:56 BJ

MARTEL NO. 40030 000095 CLIENT SAMPLE IDENTIFICATION 314/320 Laundry Hand Sink [OT--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	49.3	ug/l*	EPA .200.8	2	08/31/2018 19:59 BJ

MARTEL NO. 40030 000096 CLIENT SAMPLE IDENTIFICATION 314 Sink (Hallside LEFT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.22	ug/l	EPA .200.8	2	08/31/2018 20:01 BJ

MARTEL NO. 40030 000097 CLIENT SAMPLE IDENTIFICATION 314 Sink (Hallside CENTER) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.64	ug/l	EPA .200.8	2	08/31/2018 20:04 BJ

MARTEL NO. 40030 000098 CLIENT SAMPLE IDENTIFICATION 314 Sink (Hallside RIGHT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.44	ug/l	EPA .200.8	2	08/31/2018 20:06 BJ



MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION 314 Sink (rear of room LEFT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.49	ug/l	EPA .200.8	2	08/31/2018 20:09 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION 314 Sink (rear of room CENTER) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.36	ug/l	EPA .200.8	2	08/31/2018 20:11 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION 314 Sink (rear of room RIGHT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 20:19 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Health Room Sprayer (RIGHT) [NO--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 20:27 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Health Room Hand Sink (LEFT) [NO--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.45	ug/l	EPA .200.8	2	08/31/2018 20:29 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Health Room Bathroom Hand Sink [BS--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	08/31/2018 20:32 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION 308 Hand Sink [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	45.1	ug/l*	EPA .200.8	2	08/31/2018 20:37 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION 302/308 Laundry Room Hand Sink [OT--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	40.2	ug/l*	EPA .200.8	2	08/31/2018 20:39 BJ



MARTEL NO. 40030 000108 CLIENT SAMPLE IDENTIFICATION 302 Sink (Hallside LEFT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	/ /

MARTEL NO. 40030 000109 CLIENT SAMPLE IDENTIFICATION 302 Sink (Hallside CENTER) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	180	ug/l*	EPA .200.8	2	08/31/2018 20:44 BJ

MARTEL NO. 40030 000110 CLIENT SAMPLE IDENTIFICATION 302 Sink (Hallside RIGHT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	19.1	ug/l	EPA .200.8	2	08/31/2018 20:47 BJ

MARTEL NO. 40030 000111 CLIENT SAMPLE IDENTIFICATION 302 Sink (rear of room LEFT) [CR--] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	485	ug/l*	EPA .200.8	2	08/31/2018 10:56 BJ

MARTEL NO. 40030 000112 CLIENT SAMPLE IDENTIFICATION 302 Sink (rear of room CENTER) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	/ /

MARTEL NO. 40030 000113 CLIENT SAMPLE IDENTIFICATION 302 Sink (rear of room RIGHT) [CR--NC] Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	/ /

MARTEL NO. 40030 000114 CLIENT SAMPLE IDENTIFICATION Boys Bathroom (next to room 302) Hand Sink (LEFT) Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/18/2018 00:32 BJ

MARTEL NO. 40030 000115 CLIENT SAMPLE IDENTIFICATION Boys Bathroom (next to room 302) Hand Sink (LEFT CENTER) Sample Date/Time 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.8	ug/l	EPA .200.8	2	09/18/2018 00:40 BJ



MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000116 Boys Bathroom (next to room 302) Hand Sink (RIGHT) 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/18/2018 00:43 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000117 Boys Bathroom (next to room 302) Hand Sink (RIGHT) 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/18/2018 00:45 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000118 Girls Locker Room Office Hand Sink [OT--NC] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/18/2018 00:48 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000119 Girls Locker Room Hand Sink (LEFT) [OT--NC] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.50	ug/l	EPA .200.8	2	09/18/2018 00:50 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000120 Girls Locker Room Hand Sink (CENTER) [OT--NC] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.54	ug/l	EPA .200.8	2	09/18/2018 00:53 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000121 Girls Locker Room Hand Sink (RIGHT) [OT--NC] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	42.1	ug/l*	EPA .200.8	2	09/18/2018 00:55 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000122 Girls Locker Room Water Fountain [DF--C] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/18/2018 00:58 BJ

MARTEL NO. 40030 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000123 Boys Locker Room Water Fountain [DF--C] 04/28/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.80	ug/l	EPA .200.8	2	09/18/2018 01:01 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40030	000124	Boys Locker Room Hand Sink (LEFT) [OT--NC]			04/28/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	19.9	ug/l	EPA .200.8	2	09/18/2018 01:11 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40030	000125	Boys Locker Room Hand Sink (CENTER) [OT--NC]			04/28/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	29.9	ug/l*	EPA .200.8	2	09/18/2018 01:16 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40030	000126	Boys Locker Room Hand Sink (RIGHT) [OT--NC]			04/28/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	83.6	ug/l*	EPA .200.8	2	09/18/2018 01:18 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time
40030	000127	Boys Locker Room Office Hand Sink [OT--NC]			04/28/2018 05:00
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	09/18/2018 01:21 BJ

Notes and references:

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date. 40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

* results exceeded 20.5 ug/l.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Anne Arundel County Public Schools Drinking Water Lead Testing

Sample Date/Start Time: 4-28-18 8:00 AM End time: 9:50 AM
 Bottle Type/Preservative: 250 ml plastic/HNO3 Analysis: Lead (EPA 200.8) Samples preserved properly Yes or No NOTES:
 Sampled/Relinquished by: Lauren Couch Received at Martel by: [Signature] Date/Time: 4/28/18 1400

Corkran MS (1043) Martel No. 40030

7600 Quarterfield Road, Glen Burnie, MD 21061

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE
 SAMPLING BETWEEN THE HOURS OF 8PM AND 9PM**

1	Principals Office	Hand Sink	OT	NC
2	Main Office Bathroom	Hand Sink	BS	NC
3	Guidance Bathroom	Hand Sink (LEFT)	BS	NC
4	Guidance Bathroom	Hand Sink (RIGHT)	BS	NC
5	Financial Sec. Office	Hand Sink	OT	NC
6	Girls Bathroom Hallway (across from Guidance)	Hand Sink (LEFT)	BS	NC
7	Girls Bathroom Hallway (across from Guidance)	Hand Sink (CENTER)	BS	NC
8	Girls Bathroom Hallway (across from Guidance)	Hand Sink (RIGHT)	BS	NC
9	Hall Fountain (Outside of samples 6-8)	Water Fountain	DF	C
10	Custodial Closet (Roof Hatch)	Slop Sink <i>K</i>	OT	NC
11	Media Work Room Kitchen	Gooseneck	OT	NC
12	Hall Fountain (across from main entrance)	Water Fountain	DF	C
13	Girls Bathroom 203 (across from main entrance)	Hand Sink (LEFT)	BS	NC
14	Girls Bathroom 203 (across from main entrance)	Hand Sink (CENTER)	BS	NC
15	Girls Bathroom 203 (across from main entrance)	Hand Sink (RIGHT)	BS	NC
16	Boys Bathroom (across from main entrance)	Hand Sink (LEFT)	BS	NC
17	Boys Bathroom (across from main entrance)	Hand Sink (LEFT CENTER)	BS	NC
18	Boys Bathroom (across from main entrance)	Hand Sink (RIGHT CENTER)	BS	NC
19	Boys Bathroom (across from main entrance)	Hand Sink (RIGHT)	BS	NC
20	Custodial Closet (across from main entrance)	Slop Sink <i>R</i>	OT	NC
21	Custodial Closet 301	Slop Sink <i>R</i>	OT	NC
22	Womans Bathroom (across from gym)	Hand Sink (LEFT)	BS	NC
23	Womans Bathroom (across from gym)	Hand Sink (RIGHT)	BS	NC
24	Mens Bathroom (across from gym)	Hand Sink (LEFT)	BS	NC
25	Mens Bathroom (across from gym)	Hand Sink (RIGHT)	BS	NC
26	Hall Fountain (next to 303)	Water Fountain	DF	C
27	303	Gooseneck	CR	NC
28	305	Gooseneck (RIGHT)	CR	NC
29	305	Gooseneck (CENTER)	CR	NC
30	305	Sprayer (LEFT)	OT	NC
31	309	Gooseneck (RIGHT)	CR	NC

Corkran MS (1043) Martel No. 40030

7600 Quarterfield Road, Glen Burnie, MD 21061

32		309 Gooseneck (CENTER)	✓	CR	NC
33		309 Sprayer (LEFT)	✓	OT	NC
34		313 Gooseneck (RIGHT)		CR	NC
35		313 Gooseneck (CENTER)		CR	NC
36		313 Sprayer (LEFT)		OT	NC
37		315 Gooseneck (RIGHT)		CR	NC
38		315 Gooseneck (CENTER)		CR	NC
39		315 Sprayer (LEFT)		OT	NC
40		317 Gooseneck (RIGHT)		CR	NC
41		317 Gooseneck (CENTER)		CR	NC
42		317 Sprayer (LEFT)		OT	NC
43	Girls Bathroom (across from café)	Hand Sink (LEFT)		BS	NC
44	Girls Bathroom (across from café)	Hand Sink (CENTER)		BS	NC
45	Girls Bathroom (across from café)	Hand Sink (RIGHT)		BS	NC
46	Hall Fountain (across from café)	Water Fountain		DF	C
47	Boys Bathroom (next to room 121)	Hand Sink (LEFT)		BS	NC
48	Boys Bathroom (next to room 121)	Hand Sink (LEFT CENTER)		BS	NC
49	Boys Bathroom (next to room 121)	Hand Sink (RIGHT CENTER)		BS	NC
50	Boys Bathroom (next to room 121)	Hand Sink (RIGHT)		BS	NC
51	Custodial Closet (next to room 121)	Slop Sink		OT	NC
52		121 Bubbler (RIGHT)		DF	C
53		121 Gooseneck (CENTER)		CR	NC
54		121 Gooseneck (LEFT)		CR	NC
55		122 Bubbler (RIGHT)		DF	C
56		122 Gooseneck (CENTER)		CR	NC
57		122 Gooseneck (LEFT)		CR	NC
58		Art 3 Bubbler (RIGHT)		DF	C
59		Art 3 Gooseneck (CENTER)		CR	NC
60		Art 3 Gooseneck (LEFT)		CR	NC
61		124 Hand Sink		CR	NC
62	Hall Fountain (next to room 124)	Water Fountain		DF	C
63	Teachers Lounge Mens Bathroom	Hand Sink		BS	NC
64	Teachers Lounge	Hand Sink		TL	NC
65	Teachers Lounge Womens Bathroom	Hand Sink (LEFT)		BS	NC
66	Teachers Lounge Womens Bathroom	Hand Sink (RIGHT)		BS	NC
67	Receiving	Hand Sink	✗	OT	NC
68	Engineers Office	Hand Sink		OT	NC
69	Café Fountain	Water Fountain (LEFT)		DF	C

Corkran MS (1043) Martel No. 40030

7600 Quarterfield Road, Glen Burnie, MD 21061

70	Café Fountain	Water Fountain (RIGHT)	DF	C
71	Kitchen (serving area)	Hand Sink	KS	C
72	Kitchen Tri Sink	Gooseneck (LEFT)	KS	C
73	Kitchen Tri Sink	Gooseneck (RIGHT)	KS	C
74	Kitchen Custodial Room (across from kitchen bathroom)	Slop Sink <input checked="" type="checkbox"/>	OT	C
75	Kitchen Bathroom	Hand Sink	BS	NC
76	Custodial Closet (left of kitchen bathroom)	Slop Sink <input checked="" type="checkbox"/>	OT	NC
77	Kitchen Tri Sink (left of kitchen bathroom)	Gooseneck (LEFT)	KS	C
78	Kitchen Tri Sink (left of kitchen bathroom)	Gooseneck (RIGHT)	KS	C
79		336 hand Sink (corner)	CR	NC
80		336 hand sink (LEFT)	CR	NC
81		336 Hand Sink (RIGHT)	CR	NC
82		334 hand Sink (corner)	CR	NC
83		334 hand sink (LEFT)	CR	NC
84		334 Hand Sink (RIGHT)	CR	NC
85		332 Hand Sink (CORNER LEFT)	CR	NC
86		332 Hand Sink (CORNER RIGHT)	CR	NC
87		332 Hand Sink (LEFT)	CR	NC
88		332 Hand Sink (RIGHT)	CR	NC
89		330 Sink (CORNER LEFT)	CR	NC
90		330 Sink (CORNER CENTER)	CR	NC
91		330 Sink (CORNER RIGHT)	CR	NC
92		330 Sink (LEFT)	CR	NC
93		330 Sink (RIGHT)	CR	NC
94		320 Hand Sink	CR	NC
95	314/320 Laundry	Hand Sink	OT	NC
96		314 Sink (Hallside LEFT)	CR	NC
97		314 Sink (Hallside CENTER)	CR	NC
98		314 Sink (Hallside RIGHT)	CR	NC
99		314 Sink (rear of room LEFT)	CR	NC
100		314 Sink (rear of room CENTER)	CR	NC
101		314 Sink (rear of room RIGHT)	CR	NC
102	Health Room	Sprayer (RIGHT)	NO	NC
103	Health Room	Hand Sink (LEFT)	NO	NC
104	Health Room Bathroom	Hand Sink	BS	NC
105	Health Room Bathroom	Eye wash <input checked="" type="checkbox"/>	OT	NC
106		308 Hand Sink	CR	NC
107	302/308 Laundry Room	Hand Sink	OT	NC

-LS -1E

Corkran MS (1043) Martel No. 40030

7600 Quarterfield Road, Glen Burnie, MD 21061

108		302 Sink (Hallside LEFT)	CR	NC
109		302 Sink (Hallside CENTER)	CR	NC
110		302 Sink (Hallside RIGHT)	CR	NC
111		302 Sink (rear of room LEFT)		
112		302 Sink (rear of room CENTER)	CR	NC
113		302 Sink (rear of room RIGHT)	CR	NC
114	Boys Bathroom (next to room 302)	Hand Sink (LEFT)	BS	NC
115	Boys Bathroom (next to room 302)	Hand Sink (LEFT CENTER)	BS	NC
116	Boys Bathroom (next to room 302)	Hand Sink (RIGHT CENTER)	BS	NC
117	Boys Bathroom (next to room 302)	Hand Sink (RIGHT)	BS	NC
118	Girls Locker Room Office	Hand Sink	OT	NC
119	Girls Locker Room	Hand Sink (LEFT)	OT	NC
120	Girls Locker Room	Hand Sink (CENTER)	OT	NC
121	Girls Locker Room	Hand Sink (RIGHT)	OT	NC
122	Girls Locker Room	Water Fountain	DF	C
123	Boys Locker Room	Water Fountain	DF	C
124	Boys Locker Room	Hand Sink (LEFT)	OT	NC
125	Boys Locker Room	Hand Sink (CENTER)	OT	NC
126	Boys Locker Room	Hand Sink (RIGHT)	OT	NC
127	Boys Locker Room Office	Hand Sink	OT	NC