

Lead in Drinking Water – Public and Nonpublic Schools

IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT(S) **Arnold Elementary School**

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On February 22, 2019, **fourteen (14)** lead water samples were collected from **Arnold Elementary School**. Of these lead water samples, none (0) had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings.

ACTION LEVEL (AL)

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the work place and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

IMMEDIATE ACTIONS TAKEN

1. Since there were no samples of consumable and non-consumable water samples above the action level, no further action is required.

NEXT STEPS

1. The school will be resampled every three years in accordance with State regulations.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

1. For additional information, please contact Chris Williams, Environmental Issues Program Manager, at 410-360-0138. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.



AACPS - Operations Division
9034 Ft. Smallwood Road

Monday, March 4, 2019

Pasadena, MD 21122

Attention: Chris Williams; Brian Wells

Certificate of Analysis
FINAL

Report for Lab No: 40095.

Arnold ES (Portable) @ Severn River Middle School.

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 9212

Sampling by Martel personnel on February 22, 2019.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40095 000001	Boys Restroom Left Hand Sink (HS) [BS--NC]	02/22/2019 05:08
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/28/2019 09:22 BJ
40095 000002	Boys Restroom 2nd Left Hand Sink (HS) [BS--NC]	02/22/2019 05:08
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/28/2019 09:34 BJ
40095 000003	Boys Restroom Center Left Hand Sink (HS) [BS--NC]	02/22/2019 05:09
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/28/2019 09:37 BJ
40095 000004	Boys Restroom Center Right Hand Sink (HS) [BS--NC]	02/22/2019 05:09
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/28/2019 09:39 BJ
40095 000005	Boys Restroom Right Hand Sink (HS) [BS--NC]	02/22/2019 05:09
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/28/2019 09:41 BJ
40095 000006	Staff Restroom Hand Sink (HS) [BS--NC]	02/22/2019 05:10
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial



MARTEL NO. 40095 000006 CLIENT SAMPLE IDENTIFICATION Staff Restroom Hand Sink (HS) [BS--NC] Sample Date/Time 02/22/2019 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/28/2019 09:44 BJ

MARTEL NO. 40095 000007 CLIENT SAMPLE IDENTIFICATION Left Hallway Water Fountain Water Fountain [DF--C] Sample Date/Time 02/22/2019 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/28/2019 09:47 BJ

MARTEL NO. 40095 000008 CLIENT SAMPLE IDENTIFICATION Middle Hallway Water Fountain Hand Sink (HS) [DF--C] Sample Date/Time 02/22/2019 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/28/2019 09:49 BJ

MARTEL NO. 40095 000009 CLIENT SAMPLE IDENTIFICATION Right Hallway Water Fountain Hand Sink (HS) [DF--C] Sample Date/Time 02/22/2019 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/28/2019 09:51 BJ

MARTEL NO. 40095 000010 CLIENT SAMPLE IDENTIFICATION Girls Restroom Left Hand Sink (HS) [BS--NC] Sample Date/Time 02/22/2019 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/28/2019 09:54 BJ

MARTEL NO. 40095 000011 CLIENT SAMPLE IDENTIFICATION Girls Restroom 2nd Left Hand Sink (HS) [BS--NC] Sample Date/Time 02/22/2019 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/28/2019 10:04 BJ

MARTEL NO. 40095 000012 CLIENT SAMPLE IDENTIFICATION Girls Restroom Center Left Hand Sink (HS) [BS--NC] Sample Date/Time 02/22/2019 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/28/2019 10:09 BJ

MARTEL NO. 40095 000013 CLIENT SAMPLE IDENTIFICATION Girls Restroom Center Right Hand Sink (HS) [BS--NC] Sample Date/Time 02/22/2019 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/28/2019 10:12 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
40095 000014	Girls Restroom Right Hand Sink (HS) [BS--NC]	02/22/2019 05:25			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/28/2019 10:14 BJ

Page 3 OF 3

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

stddl.frx

Notes and references:

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date. 40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Anne Arundel County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Start Date/Time: 2-22-19 5:07AM End Date/Time: 2-22-19 5:30AM

Sampler/Relinquished By: Jawen Couch Received at Martel by Jawen Couch Date/Time: 2-22-19 6:30AM

Arnold ES (Portables) @ Severn River Middle School, Martel No. 40095

241 Peninsula Farm Road, Arnold MD, 21012

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE
SAMPLING BETWEEN THE HOURS OF 8PM AND 9PM

Sample #	Room #	Fixture Type <i>(Sink Rubbler Water Fountain)</i>	Key	Cons umnt	Time/notes
1	Boys rr Left	hand sink			5:08
2	Boys rr 2nd Left	hand sink			↓
3	Boys rr Center left	hand sink			5:09
4	Boys rr Center right	hand sink			↓
5	Boys rr Right	hand sink			↓
6	Staff rr	hand sink			5:10
7	L Water fountain (hallway)	Left hallway WF			5:15
8	M Water fountain (hallway)	Center hallway WF			↓
9	R Water fountain (hallway)	Right hallway WF			↓
10	Girls rr left	hand sink			5:20
11	Girls rr 2nd left	hand sink			↓
12	Girls rr center left	hand sink			↓
13	Girls rr Center right	hand sink			5:25
14	Girls rr right	hand sink			↓
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					

Lead in Drinking Water – Public and Nonpublic Schools

IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT(S) **Severn River Middle School**

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On November 29, 2018, **eighty-two (82)** lead water samples were collected from **Severn River Middle School**. Of these lead water samples, four (4) had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings. The elevated lead result from the sample(s) collected at Severn River Middle School were as follows:

Sample Number 000055-Boys Locker Room Hand Sink-Right: 25.8 ppb (non-consumable).

Sample Number 000062-FAC-122-Home EEC Sink (next to dryer): 41.1 ppb (consumable).

Sample Number 000070-Boys Bathroom (next to Rm. 214) Hand Sink-Left: 50.7 ppb (non-consumable).

Sample Number 000071-Boys Bathroom (next to Rm. 214) Hand Sink-Center: 152 ppb (non-consumable).

ACTION LEVEL (AL)

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the work place and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

IMMEDIATE ACTIONS TAKEN

1. One (1) consumable water source consisting of a sink will be shut off immediately and retested.
2. Three (3) non-consumable water sources consisting of hand sinks will be posted with signage indicating “Hand Washing Only” and retested.

NEXT STEPS

1. One (1) consumable and three (3) non-consumable water sources will be replaced and retested in accordance with the regulations.


TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

1. For additional information, please contact Chris Williams, Environmental Issues Program Manager, at 410-360-0138. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.



AACPS - Operations Division
9034 Ft. Smallwood Road

Monday, January 28, 2019

Pasadena, MD 21122

Certificate of Analysis
FINAL

Attention: Chris Williams; Brian Wells

Report for Lab No: 40082.

Severn River MS (2413)

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 9212

Sampling by Martel personnel on November 29, 2018.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40082	000001	Main Office Womens BR Hand Sink (HS) [BS--NC]	11/29/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 08:58 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40082	000002	Main Office Mens BR HS [BS--NC]	11/29/2018 05:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 09:11 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40082	000003	Health Room HS [NO--C]	11/29/2018 05:01			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 09:13 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40082	000004	Health Room BR-Left (Left) HS [BS--NC]	11/29/2018 05:02			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.33	ug/l	EPA .200.8	2	01/16/2019 09:15 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40082	000005	Health Room BR-Right (R.) HS [BS--NC]	11/29/2018 05:03			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 09:18 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40082	000006	Main Lobby Fountain Drinking Fountain (DF) [DF--C]	11/29/2018 05:03			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	



MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000006 Main Lobby Fountain Drinking Fountain (DF) [DF--C] 11/29/2018 05:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 09:20 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000007 Girls BR-Main Lobby HS-L [BS--NC] 11/29/2018 05:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 09:23 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000008 Girls BR-Main Lobby HS-Center (C.) [BS--NC] 11/29/2018 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.03	ug/l	EPA .200.8	2	01/16/2019 09:25 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000009 Girls BR-Main Lobby HS-R [BS--NC] 11/29/2018 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 09:28 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000010 Boys BR-Main Lobby HS-L [BS--NC] 11/29/2018 05:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 09:30 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000011 Boys BR-Main Lobby HS-C [BS--NC] 11/29/2018 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 09:40 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000012 Boys BR-Main Lobby HS-R [BS--NC] 11/29/2018 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 09:46 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000013 Media 129A Office HS [OT--NC] 11/29/2018 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 09:48 BJ



MARTEL NO. 40082 000014 CLIENT SAMPLE IDENTIFICATION Media 129A Office-BR HS [BS--NC] Sample Date/Time 11/29/2018 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 09:51 BJ

MARTEL NO. 40082 000015 CLIENT SAMPLE IDENTIFICATION Boys BR (Large Group) HS-L [BS--NC] Sample Date/Time 11/29/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	/ /

MARTEL NO. 40082 000016 CLIENT SAMPLE IDENTIFICATION Boys BR (Large Group) HS-C [BS--NC] Sample Date/Time 11/29/2018 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 09:53 BJ

MARTEL NO. 40082 000017 CLIENT SAMPLE IDENTIFICATION Boys BR (Large Group) HS-R [BS--NC] Sample Date/Time 11/29/2018 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.37	ug/l	EPA .200.8	2	01/16/2019 09:56 BJ

MARTEL NO. 40082 000018 CLIENT SAMPLE IDENTIFICATION Girls BR (Large Group) HS-L [BS--NC] Sample Date/Time 11/29/2018 05:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.61	ug/l	EPA .200.8	2	01/16/2019 09:58 BJ

MARTEL NO. 40082 000019 CLIENT SAMPLE IDENTIFICATION Girls BR (Large Group) HS-C [BS--NC] Sample Date/Time 11/29/2018 05:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 10:00 BJ

MARTEL NO. 40082 000020 CLIENT SAMPLE IDENTIFICATION Girls BR (Large Group) HS-R [BS--NC] Sample Date/Time 11/29/2018 05:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.46	ug/l	EPA .200.8	2	01/16/2019 10:03 BJ

MARTEL NO. 40082 000021 CLIENT SAMPLE IDENTIFICATION Hall Fountain (next to 009) DF-L [DF--C] Sample Date/Time 11/29/2018 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 10:11 BJ



MARTEL NO. 40082 000022 CLIENT SAMPLE IDENTIFICATION Hall Fountain (next to 009) DF-R [DF--C] Sample Date/Time 11/29/2018 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 10:18 BJ

MARTEL NO. 40082 000023 CLIENT SAMPLE IDENTIFICATION Health Room-009-BR-L HS [BS--NC] Sample Date/Time 11/29/2018 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 10:20 BJ

MARTEL NO. 40082 000024 CLIENT SAMPLE IDENTIFICATION Health Room-009-BR-R HS [BS--NC] Sample Date/Time 11/29/2018 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 10:23 BJ

MARTEL NO. 40082 000025 CLIENT SAMPLE IDENTIFICATION 116 Closet HS [OT--NC] Sample Date/Time 11/29/2018 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 10:25 BJ

MARTEL NO. 40082 000026 CLIENT SAMPLE IDENTIFICATION Hall Fountain (across from 116) DF [DF--C] Sample Date/Time 11/29/2018 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 10:28 BJ

MARTEL NO. 40082 000027 CLIENT SAMPLE IDENTIFICATION Boys BR (across from 116) HS-L [BS--NC] Sample Date/Time 11/29/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	/ /

MARTEL NO. 40082 000028 CLIENT SAMPLE IDENTIFICATION Boys BR (across from 116) HS-C [BS--NC] Sample Date/Time 11/29/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	/ /

MARTEL NO. 40082 000029 CLIENT SAMPLE IDENTIFICATION Boys BR (across from 116) HS-R [BS--NC] Sample Date/Time 11/29/2018 05:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.17	ug/l	EPA .200.8	2	01/16/2019 10:30 BJ



MARTEL NO. 40082 000030 CLIENT SAMPLE IDENTIFICATION Girls BR (across from 116) HS-L [BS--NC] Sample Date/Time 11/29/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	/ /

MARTEL NO. 40082 000031 CLIENT SAMPLE IDENTIFICATION Girls BR (across from 116) HS-C [BS--NC] Sample Date/Time 11/29/2018 05:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.95	ug/l	EPA .200.8	2	01/16/2019 10:40 BJ

MARTEL NO. 40082 000032 CLIENT SAMPLE IDENTIFICATION Girls BR (across from 116) HS-R [BS--NC] Sample Date/Time 11/29/2018 05:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.83	ug/l	EPA .200.8	2	01/16/2019 10:45 BJ

MARTEL NO. 40082 000033 CLIENT SAMPLE IDENTIFICATION 118 HS [CR--NC] Sample Date/Time 11/29/2018 05:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 10:48 BJ

MARTEL NO. 40082 000034 CLIENT SAMPLE IDENTIFICATION 119-Music HS [OT--NC] Sample Date/Time 11/29/2018 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 10:50 BJ

MARTEL NO. 40082 000035 CLIENT SAMPLE IDENTIFICATION Café Fountain DF-L [DF--C] Sample Date/Time 11/29/2018 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 10:53 BJ

MARTEL NO. 40082 000036 CLIENT SAMPLE IDENTIFICATION Café Fountain DF-R [DF--C] Sample Date/Time 11/29/2018 05:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 10:55 BJ

MARTEL NO. 40082 000037 CLIENT SAMPLE IDENTIFICATION Faculty Lounge HS [TL--C] Sample Date/Time 11/29/2018 05:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 10:58 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40082 000038	Faculty Lounge BR-Womens BR HS [BS--NC]	11/29/2018 05:28
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 01/16/2019 11:00 BJ
40082 000039	Faculty Lounge BR-Mens BR HS [BS--NC]	11/29/2018 05:29
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8	2 01/16/2019 11:02 BJ
40082 000040	Boys BR (next to custodial A4) HS-L [BS--NC]	11/29/2018 05:32
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	5.45 ug/l EPA .200.8	2 01/16/2019 11:05 BJ
40082 000041	Boys BR (next to custodial A4) HS-C [BS--NC]	11/29/2018 05:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	non operational EPA .200.8	2 / /
40082 000042	Boys BR (next to custodial A4) HS-R [BS--NC]	11/29/2018 05:33
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	13.2 ug/l EPA .200.8	2 01/16/2019 11:12 BJ
40082 000043	Girls BR (next to custodial A4) HS-L [BS--NC]	11/29/2018 05:00
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	non operational EPA .200.8	2 / /
40082 000044	Girls BR (next to custodial A4) HS-C [BS--NC]	11/29/2018 05:34
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	11.0 ug/l EPA .200.8	2 01/16/2019 11:20 BJ
40082 000045	Girls BR (next to custodial A4) HS-R [BS--NC]	11/29/2018 05:35
Compound	Test Value Test Unit Method	Detection Limit Analysis Date/Time/Initial
Lead	12.1 ug/l EPA .200.8	2 01/16/2019 11:22 BJ



MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000046 Tech Ed 122 DF [DF--C] 11/29/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000047 Tech Ed 122 HS [OT--NC] 11/29/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000048 Dance 123 DF [DF--C] 11/29/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000049 Gym Hall Fountain DF [DF--C] 11/29/2018 05:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 11:25 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000050 Boys Locker Room Office BR HS [BS--NC] 11/29/2018 05:38

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 11:27 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000051 Boys Locker Room DF-L [DF--C] 11/29/2018 05:39

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 11:37 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000052 Boys Locker Room DF-R [DF--C] 11/29/2018 05:39

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 11:42 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000053 Boys Locker Room HS-L [BS--NC] 11/29/2018 05:39

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	18.0	ug/l	EPA .200.8	2	01/16/2019 11:44 BJ



MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Boys Locker Room HS-C [BS--NC] Sample Date/Time 11/29/2018 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.8	ug/l	EPA .200.8	2	01/16/2019 11:47 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Boys Locker Room HS-R [BS--NC] Sample Date/Time 11/29/2018 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	25.8	ug/l*	EPA .200.8	2	01/16/2019 11:49 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Girls Locker Room Office BR HS [BS--NC] Sample Date/Time 11/29/2018 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 11:52 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Girls Locker Room DF-L [DF--C] Sample Date/Time 11/29/2018 05:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 11:54 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Girls Locker Room DF-R [DF--C] Sample Date/Time 11/29/2018 05:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 11:57 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Girls Locker Room HS-L [BS--NC] Sample Date/Time 11/29/2018 05:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	19.3	ug/l	EPA .200.8	2	01/16/2019 11:59 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Girls Locker Room HS-C [BS--NC] Sample Date/Time 11/29/2018 05:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.91	ug/l	EPA .200.8	2	01/16/2019 12:02 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Girls Locker Room HS-R [BS--NC] Sample Date/Time 11/29/2018 05:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.09	ug/l	EPA .200.8	2	01/16/2019 12:09 BJ



MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000062 FAC-122-Home ECC Sink (next to dryer) [HE--C] 11/29/2018 05:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	41.1	ug/l*	EPA .200.8	2	01/16/2019 12:17 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000063 FAC-122-Home ECC (Going Clockwise) Sink-1 [HE--C] 11/29/2018 05:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.43	ug/l	EPA .200.8	2	01/16/2019 12:19 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000064 FAC-122-Home ECC (Going Clockwise) Sink-2 [HE--C] 11/29/2018 05:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.24	ug/l	EPA .200.8	2	01/16/2019 12:22 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000065 FAC-122-Home ECC (Going Clockwise) Sink-3 [HE--C] 11/29/2018 05:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.97	ug/l	EPA .200.8	2	01/16/2019 12:24 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000066 FAC-122-Home ECC (Going Clockwise) Sink-4 [HE--C] 11/29/2018 05:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.1	ug/l	EPA .200.8	2	01/16/2019 12:27 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000067 FAC-122-Home ECC (Going Clockwise) Sink-5 [HE--C] 11/29/2018 05:47

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.59	ug/l	EPA .200.8	2	01/16/2019 12:29 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000068 FAC-122-Home ECC (Going Clockwise) Sink-6 [HE--C] 11/29/2018 05:48

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.91	ug/l	EPA .200.8	2	01/16/2019 12:32 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000069 Hall Fountain (next to 214) DF [DF--C] 11/29/2018 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 12:34 BJ



MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Boys BR (next to 214) HS-L [BS--NC] Sample Date/Time 11/29/2018 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	50.7	ug/l*	EPA .200.8	2	01/16/2019 12:37 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Boys BR (next to 214) HS-C [BS--NC] Sample Date/Time 11/29/2018 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	152	ug/l*	EPA .200.8	2	01/23/2019 11:12 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Boys BR (next to 214) HS-R [BS--NC] Sample Date/Time 11/29/2018 05:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.94	ug/l	EPA .200.8	2	01/16/2019 12:47 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Girls BR (next to 214) HS-L [BS--NC] Sample Date/Time 11/29/2018 05:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.01	ug/l	EPA .200.8	2	01/16/2019 12:52 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Girls BR (next to 214) HS-C [BS--NC] Sample Date/Time 11/29/2018 05:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.62	ug/l	EPA .200.8	2	01/16/2019 12:54 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Girls BR (next to 214) HS-R [BS--NC] Sample Date/Time 11/29/2018 05:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.33	ug/l	EPA .200.8	2	01/16/2019 12:57 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Art 220 HS-L [OT--NC] Sample Date/Time 11/29/2018 05:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 12:59 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Art 220 HS-R [OT--NC] Sample Date/Time 11/29/2018 05:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.66	ug/l	EPA .200.8	2	01/16/2019 13:02 BJ



MARTEL NO. 40082 000078 Art 220 HS [OT--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/29/2018 05:52

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 13:04 BJ

MARTEL NO. 40082 000079 Art 219 HS-L [OT--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/29/2018 05:52

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.22	ug/l	EPA .200.8	2	01/16/2019 13:07 BJ

MARTEL NO. 40082 000080 Art 219 HS-R [OT--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/29/2018 05:53

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 13:09 BJ

MARTEL NO. 40082 000081 Art 219 HS [OT--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/29/2018 05:52

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 13:17 BJ

MARTEL NO. 40082 000082 Girls BR (next to custodial A5) HS-L [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/29/2018 05:53

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.39	ug/l	EPA .200.8	2	01/16/2019 13:24 BJ

MARTEL NO. 40082 000083 Girls BR (next to custodial A5) HS-C [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/29/2018 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 13:27 BJ

MARTEL NO. 40082 000084 Girls BR (next to custodial A5) HS-R [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/29/2018 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.68	ug/l	EPA .200.8	2	01/16/2019 13:29 BJ

MARTEL NO. 40082 000085 Boys BR (next to custodial A5) HS-L [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/29/2018 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 13:32 BJ



MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Boys BR (next to custodial A5) HS-C [BS--NC] Sample Date/Time 11/29/2018 05:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 13:34 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Boys BR (next to custodial A5) HS-R [BS--NC] Sample Date/Time 11/29/2018 05:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 13:37 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Hall Fountain (across from 218) DF-L [DF--C] Sample Date/Time 11/29/2018 05:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 13:39 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Hall Fountain (across from 218) DF-R [DF--C] Sample Date/Time 11/29/2018 05:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 13:42 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Staff Workroom-Womens BR HS [BS--NC] Sample Date/Time 11/29/2018 05:59

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 13:44 BJ

MARTEL NO. 40082 CLIENT SAMPLE IDENTIFICATION Staff Workroom-Mens BR HS [BS--NC] Sample Date/Time 11/29/2018 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/16/2019 13:54 BJ



Martel Laboratories JDS Inc.

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

AACOP1

Page 13 OF 13

01/28/2019

stdl.frx

Notes and references:

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date. 40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

* results exceeded 20.5 ug/l.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Anne Arundel County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Start Date/Time: 11/29/18 5:00am End Date/Time: 6:00am 11/29/18

Sampler/Relinquished By:  Received at Martel by  Date/Time: 11/29/18 7:45am

Severn River MS (2413) Martel No. 40082

241 Peninsula Farm Rd, Arnold, MD 21012

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE
SAMPLING BETWEEN THE HOURS OF 8PM AND 9PM**

Sample #	Room #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, etc.)	Outlet Key Codes	Consumption Corr NC?	Time/notes
1	Main Office Womens BR	Hand Sink (HS)	BS	NC	5:00am
2	Main Office Mens BR	HS	BS	NC	5:00am
3	Health Room	HS	NO	C	5:01am
4	Health Room BR-Left (Left)	HS	BS	NC	5:02am
5	Health Room BR-Right (R.)	HS	BS	NC	5:03am
6	Main Lobby Fountain	Drinking Fountain (DF)	DF	C	5:03am
7	Girls BR-Main Lobby	HS-L	BS	NC	5:04am
8	Girls BR-Main Lobby	HS-Center (C.)	BS	NC	5:06am
9	Girls BR-Main Lobby	HS-R	BS	NC	5:06am
10	Boys BR-Main Lobby	HS-L	BS	NC	5:06am
11	Boys BR-Main Lobby	HS-C	BS	NC	5:07am
12	Boys BR-Main Lobby	HS-R	BS	NC	5:07am
13	Media 129A Office	HS	OT	NC	5:10am
14	Media 129A Office-BR	HS	BS	NC	5:10am
15	Boys BR (Large Group)	HS-L	BS	NC	not working
16	Boys BR (Large Group)	HS-C	BS	NC	5:12am
17	Boys BR (Large Group)	HS-R	BS	NC	5:12am
18	Girls BR (Large Group)	HS-L	BS	NC	5:13am
19	Girls BR (Large Group)	HS-C	BS	NC	5:14am
20	Girls BR (Large Group)	HS-R	BS	NC	5:14am
21	Hall Fountain (next to 009)	DF-L	DF	C	5:15am
22	Hall Fountain (next to 009)	DF-R	DF	C	5:15am
23	Health Room-009-BR-L	HS	BS	NC	5:16am
24	Health Room-009-BR-R	HS	BS	NC	5:16am
25	116 Closet	HS	OT	NC	5:18am

Severn River MS (2413) Martel No. 40082

241 Peninsula Farm Rd, Arnold, MD 21012

26	Hall Fountain (across from 116)	DF	DF	C	5:18am
27	Boys BR (across from 116)	HS-L	BS	NC	not working
28	Boys BR (across from 116)	HS-C	BS	NC	not working
29	Boys BR (across from 116)	HS-R	BS	NC	5:21am
30	Girls BR (across from 116)	HS-L	BS	NC	not working
31	Girls BR (across from 116)	HS-C	BS	NC	5:21am
32	Girls BR (across from 116)	HS-R	BS	NC	5:22am
33	118	HS	CR	NC	5:22am
34	119-Music	HS	OT	NC	5:24am
35	Café Fountain	DF-L	DF	C	5:25am
36	Café Fountain	DF-R	DF	C	5:26am
37	Faculty Lounge	HS	TL	C	5:26am
38	Faculty Lounge BR-Womens BR	HS	BS	NC	5:28am
39	Faculty Lounge BR-Mens BR	HS	BS	NC	5:29am
40	Boys BR (next to custodial A4)	HS-L	BS	NC	5:32am
41	Boys BR (next to custodial A4)	HS-C	BS	NC	not working
42	Boys BR (next to custodial A4)	HS-R	BS	NC	5:33am
43	Girls BR (next to custodial A4)	HS-L	BS	NC	not working
44	Girls BR (next to custodial A4)	HS-C	BS	NC	5:34am
45	Girls BR (next to custodial A4)	HS-R	BS	NC	5:35am
46	Tech Ed 122	DF	DF	C	not working
47	Tech Ed 122	HS	OT	NC	not working
48	Dance 123	DF	DF	C	not working
49	Gym Hall Fountain	DF	DF	C	5:37am
50	Boys Locker Room Office BR	HS	BS	NC	5:38am
51	Boys Locker Room	DF-L	DF	C	5:39am
52	Boys Locker Room	DF-R	DF	C	5:39am
53	Boys Locker Room	HS-L	BS	NC	5:39am
54	Boys Locker Room	HS-C	BS	NC	5:40am
55	Boys Locker Room	HS-R	BS	NC	5:40am
56	Girls Locker Room Office BR	HS	BS	NC	5:40am
57	Girls Locker Room	DF-L	DF	C	5:41am
58	Girls Locker Room	DF-R	DF	C	5:42am
59	Girls Locker Room	HS-L	BS	NC	5:42am
60	Girls Locker Room	HS-C	BS	NC	5:43am
61	Girls Locker Room	HS-R	BS	NC	5:43am

2

Severn River MS (2413) Martel No. 40082

241 Peninsula Farm Rd, Arnold, MD 21012

62	FAC-122-Home ECC	Sink (next to dryer)	HE	C	5:45am
63	FAC-122-Home ECC (Going Clockwise)	Sink-1	HE	C	5:46am
64	FAC-122-Home ECC (Going Clockwise)	Sink-2	HE	C	5:46am
65	FAC-122-Home ECC (Going Clockwise)	Sink-3	HE	C	5:46am
66	FAC-122-Home ECC (Going Clockwise)	Sink-4	HE	C	5:46am
67	FAC-122-Home ECC (Going Clockwise)	Sink-5	HE	C	5:47am
68	FAC-122-Home ECC (Going Clockwise)	Sink-6	HE	C	5:48am
69	Hall Fountain (next to 214)	DF	DF	C	5:49am
70	Boys BR (next to 214)	HS-L	BS	NC	5:49am
71	Boys BR (next to 214)	HS-C	BS	NC	5:49am
72	Boys BR (next to 214)	HS-R	BS	NC	5:50am
73	Girls BR (next to 214)	HS-L	BS	NC	5:50am
74	Girls BR (next to 214)	HS-C	BS	NC	5:50am
75	Girls BR (next to 214)	HS-R	BS	NC	5:51am
76	Art 220	HS-L	OT	NC	5:51am
77	Art 220	HS-R	OT	NC	5:51am
78	Art 220	HS	OT	NC	5:52am
79	Art 219	HS-L	OT	NC	5:53am
80	Art 219	HS-R	OT	NC	5:53am
81	Art 219	HS	OT	NC	5:53am
82	Girls BR (next to custodial A5)	HS-L	BS	NC	5:55am
83	Girls BR (next to custodial A5)	HS-C	BS	NC	5:55am
84	Girls BR (next to custodial A5)	HS-R	BS	NC	5:56am
85	Boys BR (next to custodial A5)	HS-L	BS	NC	5:56am
86	Boys BR (next to custodial A5)	HS-C	BS	NC	5:57am
87	Boys BR (next to custodial A5)	HS-R	BS	NC	5:57am
88	Hall Fountain (across from 218)	DF-L	DF	C	5:57am
89	Hall Fountain (across from 218)	DF-R	DF	C	5:58am
90	Staff Workroom-Womens BR	HS	BS	NC	5:59am
91	Staff Workroom-Mens BR	HS	BS	NC	6:00am