

Lead in Drinking Water – Public and Nonpublic Schools

IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT(S) **Benfield Elementary School**

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On November 16, 2018, **one hundred thirty-nine (139)** lead water samples were collected from **Benfield Elementary School**. Of these lead water samples, none (0) had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings.

ACTION LEVEL (AL)

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the work place and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

IMMEDIATE ACTIONS TAKEN

1. Since there were no samples of consumable and non-consumable water samples above the action level, no further action is required.

NEXT STEPS

1. The school will be resampled every three years in accordance with State regulations.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

1. For additional information, please contact Chris Williams, Environmental Issues Program Manager, at 410-360-0138. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.



AACPS - Operations Division
9034 Ft. Smallwood Road

Monday, January 21, 2019

Pasadena, MD 21122

Certificate of Analysis
FINAL

Attention: Chris Williams; Brian Wells

Report for Lab No: 40079.

Benfield ES (2072)

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 9212

Sampling by Martel personnel on November 16, 2018.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40079	000001	Staff Toilet (main Office)-Left Hand Sink (HS) [BS--NC]	11/16/2018 05:40
Compound	Test Value	Test Unit	Method
Lead	<2	ug/l	EPA .200.8
			Detection Limit
			2
			Analysis Date/Time/Initial
			01/12/2019 07:23 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40079	000002	Staff Toilet (main Office)-Right HS [BS--NC]	11/16/2018 05:40
Compound	Test Value	Test Unit	Method
Lead	<2	ug/l	EPA .200.8
			Detection Limit
			2
			Analysis Date/Time/Initial
			01/12/2019 07:36 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40079	000003	110D Conference Room HS [OT--NC]	11/16/2018 05:40
Compound	Test Value	Test Unit	Method
Lead	<2	ug/l	EPA .200.8
			Detection Limit
			2
			Analysis Date/Time/Initial
			01/12/2019 07:38 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40079	000004	110E Workroom HS [OT--NC]	11/16/2018 05:42
Compound	Test Value	Test Unit	Method
Lead	<2	ug/l	EPA .200.8
			Detection Limit
			2
			Analysis Date/Time/Initial
			01/12/2019 07:41 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40079	000005	107 HS [CR--NC]	11/16/2018 05:43
Compound	Test Value	Test Unit	Method
Lead	<2	ug/l	EPA .200.8
			Detection Limit
			2
			Analysis Date/Time/Initial
			01/12/2019 07:43 CSG
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time
40079	000006	107 Bubbler (B) [DF--C]	11/16/2018 05:43
Compound	Test Value	Test Unit	Method
			Detection Limit
			Analysis Date/Time/Initial



MARTEL NO. 40079 000006 CLIENT SAMPLE IDENTIFICATION 107 Bubbler (B) [DF--C] Sample Date/Time 11/16/2018 05:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 07:46 CSG

MARTEL NO. 40079 000007 CLIENT SAMPLE IDENTIFICATION 107-Bathroom (BR) HS [BS--NC] Sample Date/Time 11/16/2018 05:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 07:48 CSG

MARTEL NO. 40079 000008 CLIENT SAMPLE IDENTIFICATION 105 HS [CR--NC] Sample Date/Time 11/16/2018 05:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 07:50 CSG

MARTEL NO. 40079 000009 CLIENT SAMPLE IDENTIFICATION 105 B [DF--C] Sample Date/Time 11/16/2018 05:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 07:53 CSG

MARTEL NO. 40079 000010 CLIENT SAMPLE IDENTIFICATION 105-BR HS [BS--NC] Sample Date/Time 11/16/2018 05:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 07:55 CSG

MARTEL NO. 40079 000011 CLIENT SAMPLE IDENTIFICATION 103 HS [CR--NC] Sample Date/Time 11/16/2018 05:47

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:06 CSG

MARTEL NO. 40079 000012 CLIENT SAMPLE IDENTIFICATION 103 B [DF--C] Sample Date/Time 11/16/2018 05:47

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:11 CSG

MARTEL NO. 40079 000013 CLIENT SAMPLE IDENTIFICATION 103-BR HS [BS--NC] Sample Date/Time 11/16/2018 05:47

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:13 CSG



MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000014 Media Center-BR HS [BS--NC] 11/16/2018 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:16 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000015 Media Workroom 100A HS [OT--NC] 11/16/2018 05:49

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:18 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000016 176 Faculty Lounge HS [TL--C] 11/16/2018 05:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:21 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000017 Staff BR (across from 175)-Right HS [BS--NC] 11/16/2018 05:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:23 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000018 Staff BR (across from 175)-Left HS [BS--NC] 11/16/2018 05:52

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:25 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000019 Hall Fountain (next to 170) Drinking Fountain (DF)-Left (L) 11/16/2018 05:53

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:28 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000020 Hall Fountain (next to 170) DF-Right (R.) [DF--C] 11/16/2018 05:53

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:30 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000021 170 HS [CR--NC] 11/16/2018 05:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:38 CSG



MARTEL NO. 40079 000022 170 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 05:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:45 CSG

MARTEL NO. 40079 000023 170-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 05:54

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:48 CSG

MARTEL NO. 40079 000024 166 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:50 CSG

MARTEL NO. 40079 000025 166 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:53 CSG

MARTEL NO. 40079 000026 166-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:55 CSG

MARTEL NO. 40079 000027 158 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 05:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 08:58 CSG

MARTEL NO. 40079 000028 158 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 05:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:00 CSG

MARTEL NO. 40079 000029 158-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 05:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:03 CSG



MARTEL NO. 40079 000030 156 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 05:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:05 CSG

MARTEL NO. 40079 000031 156 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 05:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:15 CSG

MARTEL NO. 40079 000032 156-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 05:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:20 CSG

MARTEL NO. 40079 000033 154 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:22 CSG

MARTEL NO. 40079 000034 154 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:25 CSG

MARTEL NO. 40079 000035 154-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:27 CSG

MARTEL NO. 40079 000036 155 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:30 CSG

MARTEL NO. 40079 000037 155 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:32 CSG



MARTEL NO. 40079 000038 155-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:35 CSG

MARTEL NO. 40079 000039 161-Workroom HS [OT--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:37 CSG

MARTEL NO. 40079 000040 150 EC HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:40 CSG

MARTEL NO. 40079 000041 150 EC B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:47 CSG

MARTEL NO. 40079 000042 150 EC-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:55 CSG

MARTEL NO. 40079 000043 148 EC HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:57 CSG

MARTEL NO. 40079 000044 148 EC B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 09:59 CSG

MARTEL NO. 40079 000045 148 EC-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:02 CSG



MARTEL NO. 40079 000046 146 EC HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:04 CSG

MARTEL NO. 40079 000047 146 EC B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:07 CSG

MARTEL NO. 40079 000048 146 EC-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:09 CSG

MARTEL NO. 40079 000049 144 EC HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:12 CSG

MARTEL NO. 40079 000050 144 EC B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:14 CSG

MARTEL NO. 40079 000051 144 EC-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:24 CSG

MARTEL NO. 40079 000052 142 EC HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:29 CSG

MARTEL NO. 40079 000053 142 EC B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:32 CSG



MARTEL NO. 40079 000054 142 EC-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:34 CSG

MARTEL NO. 40079 000055 143 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:37 CSG

MARTEL NO. 40079 000056 143 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:39 CSG

MARTEL NO. 40079 000057 143-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:42 CSG

MARTEL NO. 40079 000058 145 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:44 CSG

MARTEL NO. 40079 000059 145 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:47 CSG

MARTEL NO. 40079 000060 145-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:49 CSG

MARTEL NO. 40079 000061 147 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 10:57 CSG



MARTEL NO. 40079 000062 147 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:04 CSG

MARTEL NO. 40079 000063 147-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:07 CSG

MARTEL NO. 40079 000064 149 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:09 CSG

MARTEL NO. 40079 000065 149 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:12 CSG

MARTEL NO. 40079 000066 149-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:14 CSG

MARTEL NO. 40079 000067 151 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:17 CSG

MARTEL NO. 40079 000068 151 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:19 CSG

MARTEL NO. 40079 000069 151-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:22 CSG



MARTEL NO. 40079 000070 165 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:24 CSG

MARTEL NO. 40079 000071 165 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:34 CSG

MARTEL NO. 40079 000072 165-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:39 CSG

MARTEL NO. 40079 000073 167 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:41 CSG

MARTEL NO. 40079 000074 167 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:44 CSG

MARTEL NO. 40079 000075 167-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:46 CSG

MARTEL NO. 40079 000076 Student Toilet (outside media) HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:49 CSG

MARTEL NO. 40079 000077 102 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:51 CSG



MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000078 102 B [DF-C] 11/16/2018 06:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:54 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000079 102-BR HS [BS-NC] 11/16/2018 06:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:56 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000080 104 HS [CR-NC] 11/16/2018 06:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 11:59 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000081 104 B [DF-C] 11/16/2018 06:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 12:06 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000082 104-BR HS [BS-NC] 11/16/2018 06:32

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 12:14 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000083 106 HS [CR-NC] 11/16/2018 06:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 12:16 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000084 106 B [DF-C] 11/16/2018 06:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 12:19 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000085 106-BR HS [BS-NC] 11/16/2018 06:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 12:21 CSG



MARTEL NO. 40079 000086 108 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 12:24 CSG

MARTEL NO. 40079 000087 108 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 12:26 CSG

MARTEL NO. 40079 000088 108-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 12:29 CSG

MARTEL NO. 40079 000089 109 HS [CR--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 12:31 CSG

MARTEL NO. 40079 000090 109 B [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 12:34 CSG

MARTEL NO. 40079 000091 109-BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 12:44 CSG

MARTEL NO. 40079 000092 111 Health Room HS [NO--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 12:49 CSG

MARTEL NO. 40079 000093 111B Exam 1 HS [NO--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/16/2018 06:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 12:51 CSG



MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000094 111E Exam 2 HS [NO--C] 11/16/2018 06:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 12:54 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000095 Health Room BR (with shower) HS [BS--NC] 11/16/2018 06:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 12:56 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000096 Health Room BR (without shower) HS [BS--NC] 11/16/2018 06:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 12:59 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000097 116 Studio Lab-Art HS (by door) [OT--NC] 11/16/2018 06:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 13:01 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000098 116 Studio Lab-Art HS [OT--NC] 11/16/2018 06:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 13:04 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000099 116 Studio Lab-Art B [DF--C] 11/16/2018 06:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 13:06 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000100 116 Studio Lab-Art-BR HS [BS--NC] 11/16/2018 06:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 13:09 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000101 118 Studio Science HS (by door) [OT--NC] 11/16/2018 06:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 13:16 CSG



MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000102 118 Studio Science HS [OT--NC] 11/16/2018 06:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 13:24 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000103 118 Studio Science B [DF--C] 11/16/2018 06:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 13:26 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000104 118 Studio Science-BR HS [BS--NC] 11/16/2018 06:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 13:29 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000105 120 Before/After Care Activity HS-L [OT--NC] 11/16/2018 06:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 13:31 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000106 120 Before/After Care Activity B-L [DF--C] 11/16/2018 06:45

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 13:34 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000107 120 Before/After Care Activity HS-R [OT--NC] 11/16/2018 06:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 13:37 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000108 120 Before/After Care Activity B-R [DF--C] 11/16/2018 06:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 13:39 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000109 120 Before/After Care Activity-BR HS [BS--NC] 11/16/2018 06:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 13:42 CSG



MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Student BR (next to 125) HS [BS--NC] Sample Date/Time 11/16/2018 06:47

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 13:44 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Gym Staff Toilet (next to 130C) HS [BS--NC] Sample Date/Time 11/16/2018 06:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 13:54 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Gym Staff Toilet (next to double room) HS [BS--NC] Sample Date/Time 11/16/2018 06:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 13:59 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Gym Staff Toilet (across from 130C) HS [BS--NC] Sample Date/Time 11/16/2018 06:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:02 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Gym Fountain DF-L [DF--C] Sample Date/Time 11/16/2018 06:52

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:04 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Gym Fountain DF-R [DF--C] Sample Date/Time 11/16/2018 06:52

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:07 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Kitchen BR HS [BS--NC] Sample Date/Time 11/16/2018 06:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:09 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Kitchen Dual Sink Sink [KS--C] Sample Date/Time 11/16/2018 06:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:12 CSG



MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000118 Kitchen Sink (right of dual Sink) HS [KS--NC] 11/16/2018 06:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:14 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000119 Kitchen Tri-Sink Sink-L [KS--C] 11/16/2018 06:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:17 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000120 Kitchen Tri-Sink Sink-R [KS--C] 11/16/2018 06:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:19 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000121 Kitchen Serving Line Fill Fill Station [OT--C] 11/16/2018 06:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:27 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000122 Kitchen Serving Line Sink HS [KS--NC] 11/16/2018 07:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:34 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000123 Kitchen Serving Line (by paper storage 129E) HS [KS--NC] 11/16/2018 07:01

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:37 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000124 Kitchen Serving Line Fill (next to paper storage 129E) Fill 11/16/2018 07:02

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:39 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000125 138 Instrumental Music HS [OT--NC] 11/16/2018 07:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:42 CSG



MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000126 Student Toilet (outside media) HS [BS--NC] 11/16/2018 07:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:44 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000127 Staff Toilet HS [BS--NC] 11/16/2018 07:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:47 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000128 135 General Music HS [OT--NC] 11/16/2018 07:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:49 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000129 135 General Music B [DF--C] 11/16/2018 07:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:52 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000130 Hall Fountain (outside Café) DF-L [DF--C] 11/16/2018 07:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 14:55 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000131 Hall Fountain (outside Café) DF-R [DF--C] 11/16/2018 07:06

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 15:04 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000132 Women's BR (outside Café) HS-L [BS--NC] 11/16/2018 07:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 15:10 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
 000133 Women's BR (outside Café) HS-Left Center [BS--NC] 11/16/2018 07:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 15:12 CSG



MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000134 Women's BR (outside Café) HS-Right Center [BS--NC] 11/16/2018 07:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 15:15 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000135 Women's BR (outside Café) HS-R [BS--NC] 11/16/2018 07:08

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 15:17 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000136 Men's BR (outside Café) HS-L [BS--NC] 11/16/2018 07:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 15:20 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000137 Men's BR (outside Café) HS-Left Center [BS--NC] 11/16/2018 07:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 15:22 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000138 Men's BR (outside Café) HS-Right Center [BS--NC] 11/16/2018 07:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 15:25 CSG

MARTEL NO. 40079 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000139 Men's BR (outside Café) HS-R [BS--NC] 11/16/2018 07:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/12/2019 15:27 CSG



Martel Laboratories JDS Inc.

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

AACOP1

Page 19 OF 19

01/21/2019

stdl.frx

Notes and references:

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date. 40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager

MARTEL Chain of Custody Record

Martel Laboratories /DS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Anne Arundel County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO₃ Analysis: Lead (EPA 200.8)

Start Date/Time: 11/16/18 5:40 End Date/Time: 11/16/18 7:10

Sampler/Relinquished By: *Amberly Chapman* Received at Martel by: *[Signature]* Date/Time: 11/16/18 9:00

Benfield ES (2072) Martel No. 40079

365 Lynwood Dr, Severna Park, MD 21146

**ALL OUTLET WERE FLUSHED THE NIGHT BEFORE
SAMPLING BETWEEN THE HOURS OF 8PM AND 9PM**

Sample #	Room #	Fixture Type <small>(Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, etc.)</small>	Outlet Key Codes	Consumption For MSJ	Time/notes
1	Staff Toilet (main Office)-Left	Hand Sink (HS)	BS	NC	5:40
2	Staff Toilet (main Office)-Right	HS	BS	NC	↓
3	110D Conference Room	HS	OT	NC	↓
4	110E Workroom	HS	OT	NC	5:42
5	107	HS	CR	NC	5:43
6	107	Bubbler (B)	DF	C	↓
7	107-Bathroom (BR)	HS	BS	NC	↓
8	105	HS	CR	NC	5:45
9	105	B	DF	C	↓
10	105-BR	HS	BS	NC	↓
11	103	HS	CR	NC	5:47
12	103	B	DF	C	↓
13	103-BR	HS	BS	NC	↓
14	Media Center-BR	HS	BS	NC	5:49
15	Media Workroom 100A	HS	OT	NC	↓
16	176 Faculty Lounge	HS	TL	C	5:50
17	Staff BR (across from 175)-Right	HS	BS	NC	5:51
18	Staff BR (across from 175)-Left	HS	BS	NC	5:52
19	Hall Fountain (next to 170)	Drinking Fountain (DF)-Left (L)	DF	C	5:53
20	Hall Fountain (next to 170)	DF-Right (R.)	DF	C	↓
21	170	HS	CR	NC	5:54
22	170	B	DF	C	↓
23	170-BR	HS	BS	NC	↓
24	166	HS	CR	NC	5:55
25	166	B	DF	C	↓

Benfield ES (2072) Martel No. 40079

365 Lynwood Dr, Severna Park, MD 21146

26	166-BR	HS	BS	NC	5:55
27	158	HS	CR	NC	5:57
28	158	B	DF	C	↓
29	158-BR	HS	BS	NC	↓
30	156	HS	CR	NC	5:58
31	156	B	DF	C	↓
32	156-BR	HS	BS	NC	↓
33	154	HS	CR	NC	6:00
34	154	B	DF	C	↓
35	154-BR	HS	BS	NC	↓
36	155	HS	CR	NC	6:07
37	155	B	DF	C	↓
38	155-BR	HS	BS	NC	↓
39	161-Workroom	HS	OT	NC	6:08
40	150 EC	HS	CR	NC	6:10
41	150 EC	B	DF	C	↓
42	150 EC-BR	HS	BS	NC	↓
43	148 EC	HS	CR	NC	6:11
44	148 EC	B	DF	C	↓
45	148 EC-BR	HS	BS	NC	↓
46	146 EC	HS	CR	NC	6:12
47	146 EC	B	DF	C	↓
48	146 EC-BR	HS	BS	NC	↓
49	144 EC	HS	CR	NC	6:13
50	144 EC	B	DF	C	↓
51	144 EC-BR	HS	BS	NC	↓
52	142 EC	HS	CR	NC	6:15
53	142 EC	B	DF	C	↓
54	142 EC-BR	HS	BS	NC	↓
55	143	HS	CR	NC	6:16
56	143	B	DF	C	↓
57	143-BR	HS	BS	NC	↓
58	145	HS	CR	NC	↓
59	145	B	DF	C	6:17
60	145-BR	HS	BS	NC	↓
61	147	HS	CR	NC	6:18

Benfield ES (2072) Martel No. 40079

365 Lynwood Dr, Severna Park, MD 21146

62	147	B	DF	C	618 ↓
63	147-BR	HS	BS	NC	↓
64	149	HS	CR	NC	619
65	149	B	DF	C	↓
66	149-BR	HS	BS	NC	↓
67	151	HS	CR	NC	620
68	151	B	DF	C	↓
69	151-BR	HS	BS	NC	↓
70	165	HS	CR	NC	625
71	165	B	DF	C	↓
72	165-BR	HS	BS	NC	↓
73	167	HS	CR	NC	624
74	167	B	DF	C	↓
75	167-BR	HS	BS	NC	↓
76	Student Toilet (outside media)	HS	BS	NC	630
77	102	HS	CR	NC	631
78	102	B	DF	C	↓
79	102-BR	HS	BS	NC	↓
80	104	HS	CR	NC	632
81	104	B	DF	C	↓
82	104-BR	HS	BS	NC	↓
83	106	HS	CR	NC	633
84	106	B	DF	C	↓
85	106-BR	HS	BS	NC	↓
86	108	HS	CR	NC	634
87	108	B	DF	C	↓
88	108-BR	HS	BS	NC	↓
89	109	HS	CR	NC	635
90	109	B	DF	C	↓
91	109-BR	HS	BS	NC	↓
92	111 Health Room	HS	NO	C	636
93	111B Exam 1	HS	NO	C	↓
94	111E Exam 2	HS	NO	C	↓
95	Health Room BR (with shower)	HS	BS	NC	637
96	Health Room BR (without shower)	HS	BS	NC	637
97	116 Studio Lab-Art	HS (by door)	OT	NC	640

Benfield ES (2072) Martel No. 40079

365 Lynwood Dr, Severna Park, MD 21146

98	116 Studio Lab-Art	HS	OT	NC	6:40
99	116 Studio Lab-Art	B	DF	C	↓
100	116 Studio Lab-Art-BR	HS	BS	NC	↓
101	118 Studio Science	HS (by door)	OT	NC	6:42
102	118 Studio Science	HS	OT	NC	↓
103	118 Studio Science	B	DF	C	↓
104	118 Studio Science-BR	HS	BS	NC	↓
105	120 Before/After Care Activity	HS-L	OT	NC	6:48
106	120 Before/After Care Activity	B-L	DF	C	6:45
107	120 Before/After Care Activity	HS-R	OT	NC	6:46
108	120 Before/After Care Activity	B-R	DF	C	6:46
109	120 Before/After Care Activity-BR	HS	BS	NC	6:46
110	Student BR (next to 125)	HS	BS	NC	6:47
111	Gym Staff Toilet (next to 130C)	HS	BS	NC	6:50
112	Gym Staff Toilet (next to double room)	HS	BS	NC	6:50
113	Gym Staff Toilet (across from 130C)	HS	BS	NC	6:51
114	Gym Fountain	DF-L	DF	C	6:52
115	Gym Fountain	DF-R	DF	C	6:52
116	Kitchen BR	HS	BS	NC	6:55
117	Kitchen Dual Sink	Sink	KS	C	6:56
118	Kitchen Sink (right of dual Sink)	HS	KS	NC	6:56
119	Kitchen Tri-Sink	Sink-L	KS	C	6:57
120	Kitchen Tri-Sink	Sink-R	KS	C	6:57
121	Kitchen Serving Line Fill	Fill Station	OT	C	6:58
122	Kitchen Serving Line Sink	HS	KS	NC	7:00
123	Kitchen Serving Line (by paper storage 129E)	HS	KS	NC	7:01
124	Kitchen Serving Line Fill (next to paper storage 129E)	Fill Station	OT	C	7:02
125	138 Instrumental Music	HS	OT	NC	7:03
126	Student Toilet (outside media)	HS	BS	NC	7:04
127	Staff Toilet	HS	BS	NC	7:04
128	135 General Music	HS	OT	NC	7:05
129	135 General Music	B	DF	C	7:05
130	Hall Fountain (outside Café)	DF-L	DF	C	7:06
131	Hall Fountain (outside Café)	DF-R	DF	C	7:06
132	Women's BR (outside Café)	HS-L	BS	NC	7:07
133	Women's BR (outside Café)	HS-Left Center	BS	NC	7:07

Benfield ES (2072) Martel No. 40079

365 Lynwood Dr, Severna Park, MD 21146

134	Women's BR (outside Café)	HS-Right Center	BS	NC	708
135	Women's BR (outside Café)	HS-R	BS	NC	708
136	Men's BR (outside Café)	HS-L	BS	NC	709
137	Men's BR (outside Café)	HS-Left Center	BS	NC	↓
138	Men's BR (outside Café)	HS-Right Center	BS	NC	↓
139	Men's BR (outside Café)	HS-R	BS	NC	710