

Lead in Drinking Water – Public and Nonpublic Schools

IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT(S) **Magothy River Middle School**

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On November 30, 2018, **one hundred one (101)** lead water samples were collected from **Magothy River Middle School**. Of these lead water samples, eight (8) had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings. The elevated lead result from the sample(s) collected at Magothy River Middle School were as follows:

Sample Number 000026-Kitchen Pot Fill: 49.1 ppb (consumable).
Sample Number 000027-Kitchen Bathroom Hand Sink: 26.6 ppb (non-consumable).
Sample Number 000037-Dance 130 Closet Hand Sink: 32 ppb (non-consumable).
Sample Number 000052-Outside Girls Bathroom Hand Sink-Left: 40.2 ppb (non-consumable).
Sample Number 000055-Outside Boys Bathroom Hand Sink-Right: 69.5 ppb (non-consumable).
Sample Number 000058-123 Digital Pallet Closet Hand Sink-Left: 1510 ppb (non-consumable).
Sample Number 000059-123 Digital Pallet Closet Hand Sink-Right: 804 ppb (non-consumable).
Sample Number 000061- Boys Bathroom (across from 122) Hand Sink-Left: 27 ppb (non-consumable).

ACTION LEVEL (AL)

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the work place and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

IMMEDIATE ACTIONS TAKEN

1. One (1) consumable water source sink will be shut off immediately and retested.
2. Seven (7) non-consumable water sources consisting of hand sinks will be posted with signage indicating "Hand Washing Only" and retested.

NEXT STEPS

1. One (1) consumable and seven (7) non-consumable water sources will be replaced and retested in accordance with the regulations.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

1. For additional information, please contact Chris Williams, Environmental Issues Program Manager, at 410-360-0138. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.

MARTEL



AACPS - Operations Division
9034 Ft. Smallwood Road

Monday, February 4, 2019

Pasadena, MD 21122

Attention: Chris Williams; Brian Wells

Certificate of Analysis
FINAL

Report for Lab No: 40083.

Magothy River MS (2243)

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 9212

Sampling by Martel personnel on November 30, 2018.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
40083 000001	Main Office Fountain Drinking Fountain (DF) [DF--C]	11/30/2018 04:55
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.14 ug/l EPA .200.8 2	01/24/2019 17:23 BJ
40083 000002	Main Office Bathroom (BR)-Left (L) Hand Sink (HS) [BS--NC]	11/30/2018 04:56
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	01/24/2019 17:35 BJ
40083 000003	Main Office BR-Right (R.) HS [BS--NC]	11/30/2018 04:58
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	01/24/2019 17:38 BJ
40083 000004	Health Room HS [NO--C]	11/30/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	17.8 ug/l EPA .200.8 2	01/24/2019 17:40 BJ
40083 000005	Health Room BR-L HS [BS--NC]	11/30/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	3.86 ug/l EPA .200.8 2	01/24/2019 17:43 BJ
40083 000006	Health Room BR-R HS [BS--NC]	11/30/2018 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial



MARTEL NO. 40083 000006 CLIENT SAMPLE IDENTIFICATION: Health Room BR-R HS [BS--NC] Sample Date/Time: 11/30/2018 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	9.54	ug/l	EPA .200.8	2	01/24/2019 17:45 BJ

MARTEL NO. 40083 000007 CLIENT SAMPLE IDENTIFICATION: Boys BR (next to café) HS-Left (L) [BS--NC] Sample Date/Time: 11/30/2018 05:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 17:48 BJ

MARTEL NO. 40083 000008 CLIENT SAMPLE IDENTIFICATION: Boys BR (next to café) HS-Center (C.) [BS--NC] Sample Date/Time: 11/30/2018 05:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 17:50 BJ

MARTEL NO. 40083 000009 CLIENT SAMPLE IDENTIFICATION: Boys BR (next to café) HS-Right (R.) [BS--NC] Sample Date/Time: 11/30/2018 05:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 17:53 BJ

MARTEL NO. 40083 000010 CLIENT SAMPLE IDENTIFICATION: Girls BR (next to café) HS-L [BS--NC] Sample Date/Time: 11/30/2018 05:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 17:55 BJ

MARTEL NO. 40083 000011 CLIENT SAMPLE IDENTIFICATION: Girls BR (next to café) HS-C [BS--NC] Sample Date/Time: 11/30/2018 05:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 18:05 BJ

MARTEL NO. 40083 000012 CLIENT SAMPLE IDENTIFICATION: Girls BR (next to café) HS-R [BS--NC] Sample Date/Time: 11/30/2018 05:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 18:10 BJ

MARTEL NO. 40083 000013 CLIENT SAMPLE IDENTIFICATION: Café Fountain DF-L [DF--C] Sample Date/Time: 11/30/2018 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 18:13 BJ



MARTEL NO. 40083 000014 Café Fountain DF-R [DF--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 05:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 18:15 BJ

MARTEL NO. 40083 000015 Teachers Lounge HS [TL--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 05:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 18:18 BJ

MARTEL NO. 40083 000016 Teachers Lounge BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 05:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 18:20 BJ

MARTEL NO. 40083 000017 Kitchen Sink (next to food storage) HS [KS--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.52	ug/l	EPA .200.8	2	01/24/2019 18:23 BJ

MARTEL NO. 40083 000018 Kitchen Dual Sink Sink [KS--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.83	ug/l	EPA .200.8	2	01/24/2019 18:25 BJ

MARTEL NO. 40083 000019 Kitchen Quad Sink Sink-L [KS--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.92	ug/l	EPA .200.8	2	01/24/2019 18:28 BJ

MARTEL NO. 40083 000020 Kitchen Quad Sink Sink-R [KS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 18:30 BJ

MARTEL NO. 40083 000021 Kitchen Sink (next to walk in) HS [KS--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	14.9	ug/l	EPA .200.8	2	01/24/2019 18:38 BJ



MARTEL NO. 40083 000022 Kitchen Dual Sink Sink [KS--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 18:45 BJ

MARTEL NO. 40083 000023 Kitchen Tri-Sink Sink-L [KS--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.26	ug/l	EPA .200.8	2	01/24/2019 18:48 BJ

MARTEL NO. 40083 000024 Kitchen Tri-Sink Sink-R [KS--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.34	ug/l	EPA .200.8	2	01/24/2019 18:50 BJ

MARTEL NO. 40083 000025 Kitchen Sink (across from Tri-Sink) HS [KS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.66	ug/l	EPA .200.8	2	01/24/2019 18:53 BJ

MARTEL NO. 40083 000026 Kitchen Pot Fill Pot Fill [OT--C] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	49.1	ug/l*	EPA .200.8	2	01/24/2019 18:55 BJ

MARTEL NO. 40083 000027 Kitchen BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	26.6	ug/l*	EPA .200.8	2	01/24/2019 18:58 BJ

MARTEL NO. 40083 000028 Boys BR (back of kitchen) HS-L [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 05:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 19:00 BJ

MARTEL NO. 40083 000029 Boys BR (back of kitchen) HS-C [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 05:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 19:02 BJ



MARTEL NO. 40083 000030 CLIENT SAMPLE IDENTIFICATION Boys BR (back of kitchen) HS-R [BS--NC] Sample Date/Time 11/30/2018 05:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.56	ug/l	EPA .200.8	2	01/24/2019 19:05 BJ

MARTEL NO. 40083 000031 CLIENT SAMPLE IDENTIFICATION Girls BR (back of kitchen) HS-L [BS--NC] Sample Date/Time 11/30/2018 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 19:15 BJ

MARTEL NO. 40083 000032 CLIENT SAMPLE IDENTIFICATION Girls BR (back of kitchen) HS-C [BS--NC] Sample Date/Time 11/30/2018 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 19:20 BJ

MARTEL NO. 40083 000033 CLIENT SAMPLE IDENTIFICATION Girls BR (back of kitchen) HS-R [BS--NC] Sample Date/Time 11/30/2018 05:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 19:22 BJ

MARTEL NO. 40083 000034 CLIENT SAMPLE IDENTIFICATION Tech Ed 129 HS [OT--NC] Sample Date/Time 11/30/2018 05:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.56	ug/l	EPA .200.8	2	01/24/2019 19:25 BJ

MARTEL NO. 40083 000035 CLIENT SAMPLE IDENTIFICATION Tech Ed 129 DF [DF--C] Sample Date/Time 11/30/2018 05:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 19:27 BJ

MARTEL NO. 40083 000036 CLIENT SAMPLE IDENTIFICATION Dance 130 DF [DF--C] Sample Date/Time 11/30/2018 05:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 19:30 BJ

MARTEL NO. 40083 000037 CLIENT SAMPLE IDENTIFICATION Dance 130 Closet HS [OT--NC] Sample Date/Time 11/30/2018 05:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	32.0	ug/l*	EPA .200.8	2	02/04/2019 10:19 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40083	000038	Chief Office-BR HS [BS--NC]	11/30/2018 05:37			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 19:32 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40083	000039	Boys Locker Room DF-L [DF--C]	11/30/2018 05:40			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 19:34 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40083	000040	Boys Locker Room DF-R [DF--C]	11/30/2018 05:40			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 19:37 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40083	000041	Boys Locker Room HS-L [BS--NC]	11/30/2018 05:40			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	3.63	ug/l	EPA .200.8	2	01/24/2019 19:44 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40083	000042	Boys Locker Room HS-C [BS--NC]	11/30/2018 05:40			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	4.26	ug/l	EPA .200.8	2	01/24/2019 19:52 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40083	000043	Boys Locker Room HS-R [BS--NC]	11/30/2018 05:40			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	non	operational	EPA .200.8	2	/ /	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40083	000044	Boys Locker Room HS [BS--NC]	11/30/2018 05:40			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 19:54 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION		Sample Date/Time			
40083	000045	Girls Locker Room DF-L [DF--C]	11/30/2018 05:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 19:57 BJ	



MARTEL NO. 40083 000046 CLIENT SAMPLE IDENTIFICATION: Girls Locker Room DF-R [DF--C] Sample Date/Time: 11/30/2018 05:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 19:59 BJ

MARTEL NO. 40083 000047 CLIENT SAMPLE IDENTIFICATION: Girls Locker Room HS-L [BS--NC] Sample Date/Time: 11/30/2018 05:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.43	ug/l	EPA .200.8	2	01/24/2019 20:02 BJ

MARTEL NO. 40083 000048 CLIENT SAMPLE IDENTIFICATION: Girls Locker Room HS-C [BS--NC] Sample Date/Time: 11/30/2018 05:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.03	ug/l	EPA .200.8	2	01/24/2019 20:04 BJ

MARTEL NO. 40083 000049 CLIENT SAMPLE IDENTIFICATION: Girls Locker Room HS-R [BS--NC] Sample Date/Time: 11/30/2018 05:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	6.47	ug/l	EPA .200.8	2	01/24/2019 20:07 BJ

MARTEL NO. 40083 000050 CLIENT SAMPLE IDENTIFICATION: Girls Locker Room HS [BS--NC] Sample Date/Time: 11/30/2018 05:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 20:09 BJ

MARTEL NO. 40083 000051 CLIENT SAMPLE IDENTIFICATION: Gym Hall Fountain DF [DF--C] Sample Date/Time: 11/30/2018 05:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	/ /

MARTEL NO. 40083 000052 CLIENT SAMPLE IDENTIFICATION: Outside Girls BR HS-L [BS--NC] Sample Date/Time: 11/30/2018 05:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	40.2	ug/l*	EPA .200.8	2	02/04/2019 10:21 BJ

MARTEL NO. 40083 000053 CLIENT SAMPLE IDENTIFICATION: Outside Girls BR HS-R [BS--NC] Sample Date/Time: 11/30/2018 05:50

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	/ /



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
40083	000054	Outside Boys BR HS-L [BS--NC]		11/30/2018 05:50		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	non	operational	EPA .200.8	2	/ /	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
40083	000055	Outside Boys BR HS-R [BS--NC]		11/30/2018 05:50		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	69.5	ug/l*	EPA .200.8	2	02/04/2019 10:24 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
40083	000056	123 Digital Pallet HS [OT--NC]		11/30/2018 05:50		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	11.3	ug/l	EPA .200.8	2	01/24/2019 20:19 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
40083	000057	123 Digital Pallet DF [DF--C]		11/30/2018 05:56		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 20:24 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
40083	000058	123 Digital Pallet Closet HS-L [OT--NC]		11/30/2018 05:57		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	1510	ug/l*	EPA .200.8	2	02/04/2019 10:26 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
40083	000059	123 Digital Pallet Closet HS-R [OT--NC]		11/30/2018 05:57		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	804	ug/l*	EPA .200.8	2	02/04/2019 10:29 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
40083	000060	Hall Fountain (outside 123) DF [DF--C]		11/30/2018 05:59		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 20:26 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
40083	000061	Boys BR (across from 122) HS-L [BS--NC]		11/30/2018 06:00		
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	27.0	ug/l*	EPA .200.8	2	01/24/2019 20:34 BJ	



MARTEL NO. 40083 000062 Boys BR (across from 122) HS-C [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 20:41 BJ

MARTEL NO. 40083 000063 Boys BR (across from 122) HS-R [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 20:44 BJ

MARTEL NO. 40083 000064 Girls BR (across from 122) HS-L [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.31	ug/l	EPA .200.8	2	01/24/2019 20:46 BJ

MARTEL NO. 40083 000065 Girls BR (across from 122) HS-C [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 20:49 BJ

MARTEL NO. 40083 000066 Girls BR (across from 122) HS-R [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 20:51 BJ

MARTEL NO. 40083 000067 122 Closet HS [OT--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 06:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.79	ug/l	EPA .200.8	2	01/24/2019 20:54 BJ

MARTEL NO. 40083 000068 Media BR HS [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 06:05

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 20:56 BJ

MARTEL NO. 40083 000069 Boys BR (outside 107) HS-L [BS--NC] CLIENT SAMPLE IDENTIFICATION Sample Date/Time 11/30/2018 06:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.23	ug/l	EPA .200.8	2	01/24/2019 20:59 BJ



MARTEL NO. 40083 000070 CLIENT SAMPLE IDENTIFICATION Boys BR (outside 107) HS-C [BS--NC] Sample Date/Time 11/30/2018 06:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 21:01 BJ

MARTEL NO. 40083 000071 CLIENT SAMPLE IDENTIFICATION Boys BR (outside 107) HS-R [BS--NC] Sample Date/Time 11/30/2018 06:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 21:11 BJ

MARTEL NO. 40083 000072 CLIENT SAMPLE IDENTIFICATION Girls BR (outside 107) HS-L [BS--NC] Sample Date/Time 11/30/2018 06:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.22	ug/l	EPA .200.8	2	01/24/2019 21:16 BJ

MARTEL NO. 40083 000073 CLIENT SAMPLE IDENTIFICATION Girls BR (outside 107) HS-C [BS--NC] Sample Date/Time 11/30/2018 06:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 21:19 BJ

MARTEL NO. 40083 000074 CLIENT SAMPLE IDENTIFICATION Girls BR (outside 107) HS-R [BS--NC] Sample Date/Time 11/30/2018 06:07

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 21:21 BJ

MARTEL NO. 40083 000075 CLIENT SAMPLE IDENTIFICATION Hall Fountain (next to 111 Classroom) DF-L [DF--C] Sample Date/Time 11/30/2018 06:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 21:24 BJ

MARTEL NO. 40083 000076 CLIENT SAMPLE IDENTIFICATION Hall Fountain (next to 111 Classroom) DF-R [DF--C] Sample Date/Time 11/30/2018 06:09

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 21:26 BJ

MARTEL NO. 40083 000077 CLIENT SAMPLE IDENTIFICATION Students Service BR-L HS [BS--NC] Sample Date/Time 11/30/2018 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.85	ug/l	EPA .200.8	2	01/24/2019 21:29 BJ



MARTEL NO. 40083 000078 CLIENT SAMPLE IDENTIFICATION: Students Service BR-R HS [BS--NC] Sample Date/Time: 11/30/2018 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	11.3	ug/l	EPA .200.8	2	01/24/2019 21:31 BJ

MARTEL NO. 40083 000079 CLIENT SAMPLE IDENTIFICATION: Boys BR (next to 207) HS-L [BS--NC] Sample Date/Time: 11/30/2018 06:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 21:34 BJ

MARTEL NO. 40083 000080 CLIENT SAMPLE IDENTIFICATION: Boys BR (next to 207) HS-C [BS--NC] Sample Date/Time: 11/30/2018 06:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	/ /

MARTEL NO. 40083 000081 CLIENT SAMPLE IDENTIFICATION: Boys BR (next to 207) HS-R [BS--NC] Sample Date/Time: 11/30/2018 06:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 21:41 BJ

MARTEL NO. 40083 000082 CLIENT SAMPLE IDENTIFICATION: Girls BR (next to 207) HS-L [BS--NC] Sample Date/Time: 11/30/2018 06:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.09	ug/l	EPA .200.8	2	01/24/2019 21:49 BJ

MARTEL NO. 40083 000083 CLIENT SAMPLE IDENTIFICATION: Girls BR (next to 207) HS-C [BS--NC] Sample Date/Time: 11/30/2018 06:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 21:51 BJ

MARTEL NO. 40083 000084 CLIENT SAMPLE IDENTIFICATION: Girls BR (next to 207) HS-R [BS--NC] Sample Date/Time: 11/30/2018 06:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 21:54 BJ

MARTEL NO. 40083 000085 CLIENT SAMPLE IDENTIFICATION: Hall Fountain (across from 212) DF-L [DF--C] Sample Date/Time: 11/30/2018 06:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 21:56 BJ



MARTEL NO. 40083 000086 CLIENT SAMPLE IDENTIFICATION Hall Fountain (across from 212) DF-R [DF--C] Sample Date/Time 11/30/2018 06:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 21:59 BJ

MARTEL NO. 40083 000087 CLIENT SAMPLE IDENTIFICATION Teachers Lounge BR-L HS [BS--NC] Sample Date/Time 11/30/2018 06:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 22:01 BJ

MARTEL NO. 40083 000088 CLIENT SAMPLE IDENTIFICATION Teachers Lounge BR-R HS [BS--NC] Sample Date/Time 11/30/2018 06:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 22:04 BJ

MARTEL NO. 40083 000089 CLIENT SAMPLE IDENTIFICATION Hall Fountain (next to 219) DF [DF--C] Sample Date/Time 11/30/2018 06:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 22:06 BJ

MARTEL NO. 40083 000090 CLIENT SAMPLE IDENTIFICATION Boys BR (next to 219) HS-L [BS--NC] Sample Date/Time 11/30/2018 06:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 22:09 BJ

MARTEL NO. 40083 000091 CLIENT SAMPLE IDENTIFICATION Boys BR (next to 219) HS-C [BS--NC] Sample Date/Time 11/30/2018 06:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 22:19 BJ

MARTEL NO. 40083 000092 CLIENT SAMPLE IDENTIFICATION Boys BR (next to 219) HS-R [BS--NC] Sample Date/Time 11/30/2018 06:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.14	ug/l	EPA .200.8	2	01/24/2019 22:24 BJ

MARTEL NO. 40083 000093 CLIENT SAMPLE IDENTIFICATION Girls BR (next to 219) HS-L [BS--NC] Sample Date/Time 11/30/2018 06:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 22:26 BJ



MARTEL NO. 40083 000094 CLIENT SAMPLE IDENTIFICATION: Girls BR (next to 219) HS-C [BS--NC] Sample Date/Time: 11/30/2018 06:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.17	ug/l	EPA .200.8	2	01/24/2019 22:29 BJ

MARTEL NO. 40083 000095 CLIENT SAMPLE IDENTIFICATION: Girls BR (next to 219) HS-R [BS--NC] Sample Date/Time: 11/30/2018 06:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 22:31 BJ

MARTEL NO. 40083 000096 CLIENT SAMPLE IDENTIFICATION: Special Ed 222 HS [OT--NC] Sample Date/Time: 11/30/2018 06:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 22:34 BJ

MARTEL NO. 40083 000097 CLIENT SAMPLE IDENTIFICATION: Art 221 HS-L [OT--NC] Sample Date/Time: 11/30/2018 06:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 22:36 BJ

MARTEL NO. 40083 000098 CLIENT SAMPLE IDENTIFICATION: Art 221 HS-R [OT--NC] Sample Date/Time: 11/30/2018 06:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 22:39 BJ

MARTEL NO. 40083 000099 CLIENT SAMPLE IDENTIFICATION: Art 221 HS [OT--NC] Sample Date/Time: 11/30/2018 06:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/24/2019 22:41 BJ

MARTEL NO. 40083 000100 CLIENT SAMPLE IDENTIFICATION: FAQ-Home EEC 2R2 (by dryer) Sink [HE--C] Sample Date/Time: 11/30/2018 06:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.68	ug/l	EPA .200.8	2	01/24/2019 22:44 BJ

MARTEL NO. 40083 000101 CLIENT SAMPLE IDENTIFICATION: FAQ-Home EEC 2R2 (start at door-going clockwise) Sink-1 [H] Sample Date/Time: 11/30/2018 06:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.74	ug/l	EPA .200.8	2	01/24/2019 22:51 BJ



MARTEL NO. 40083 000102 CLIENT SAMPLE IDENTIFICATION FAQ-Home EEC 2R2 Sink-2 [HE--C] Sample Date/Time 11/30/2018 06:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	16.9	ug/l	EPA .200.8	2	01/24/2019 22:59 BJ

MARTEL NO. 40083 000103 CLIENT SAMPLE IDENTIFICATION FAQ-Home EEC 2R2 Sink-3 [HE--C] Sample Date/Time 11/30/2018 06:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.30	ug/l	EPA .200.8	2	01/24/2019 23:01 BJ

MARTEL NO. 40083 000104 CLIENT SAMPLE IDENTIFICATION FAQ-Home EEC 2R2 Sink-4 [HE--C] Sample Date/Time 11/30/2018 06:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.35	ug/l	EPA .200.8	2	01/24/2019 23:04 BJ

MARTEL NO. 40083 000105 CLIENT SAMPLE IDENTIFICATION FAQ-Home EEC 2R2 Sink-5 [HE--C] Sample Date/Time 11/30/2018 06:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.81	ug/l	EPA .200.8	2	01/24/2019 23:06 BJ

MARTEL NO. 40083 000106 CLIENT SAMPLE IDENTIFICATION FAQ-Home EEC 2R2 Sink-6 [HE--C] Sample Date/Time 11/30/2018 06:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.30	ug/l	EPA .200.8	2	01/24/2019 23:09 BJ

Notes and references:

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date. 40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

* results exceeded 20.5 ug/l.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager

MARTEL Chain of Custody Record

Martel Laboratoles JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Anne Arundel County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Start Date/Time: 11/30/18 4:55 End Date/Time: 11/30/18 6:35

Sampler/Relinquished By: *[Signature]* Received at Martel by: *[Signature]* Date/Time: 11/30/18 7:55

Magothy River MS (2243) Martel No. 40083

1052, 241 Peninsula Farm Rd, Arnold, MD 21012

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE
SAMPLING BETWEEN THE HOURS OF 8PM AND 9PM

Sample #	Room #	Fixture Type <small>(Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, etc.)</small>	Outlet Key		Time/notes
			Codes	Consumption Corr. NC?	
1	Main Office Fountain	Drinking Fountain (DF)	DF	C	4:55
2	Main Office Bathroom (BR)-Left (L)	Hand Sink (HS)	BS	NC	4:56
3	Main Office BR-Right (R.)	HS	BS	NC	4:58
4	Health Room	HS	NO	C	5:00
5	Health Room BR-L	HS	BS	NC	↓
6	Health Room BR-R	HS	BS	NC	
7	Boys BR (next to café)	HS-Left (L)	BS	NC	5:03
8	Boys BR (next to café)	HS-Center (C.)	BS	NC	↓
9	Boys BR (next to café)	HS-Right (R.)	BS	NC	
10	Girls BR (next to café)	HS-L	BS	NC	5:05
11	Girls BR (next to café)	HS-C	BS	NC	↓
12	Girls BR (next to café)	HS-R	BS	NC	
13	Café Fountain	DF-L	DF	C	5:07
14	Café Fountain	DF-R	DF	C	↓
15	Teachers Lounge	HS	TL	C	5:09
16	Teachers Lounge BR	HS	BS	NC	↓
17	Kitchen Sink (next to food storage)	HS	KS	C	dripping 5:24
18	Kitchen Dual Sink	Sink	KS	C	↓
19	Kitchen Quad Sink	Sink-L	KS	C	
20	Kitchen Quad Sink	Sink-R	KS	NC	
21	Kitchen Sink (next to walk in)	HS	KS	C	
22	Kitchen Dual Sink	Sink	KS	C	
23	Kitchen Tri-Sink	Sink-L	KS	C	
24	Kitchen Tri-Sink	Sink-R	KS	C	
25	Kitchen Sink (across from Tri-Sink)	HS	KS	NC	

Magothy River MS (2243) Martel No. 40083

1052, 241 Peninsula Farm Rd, Arnold, MD 21012

26	Kitchen Pot Fill	Pot Fill	OT	C	5:24
27	Kitchen BR	HS	BS	NC	↓
28	Boys BR (back of kitchen)	HS-L	BS	NC	5:28
29	Boys BR (back of kitchen)	HS-C	BS	NC	↓
30	Boys BR (back of kitchen)	HS-R	BS	NC	↓
31	Girls BR (back of kitchen)	HS-L	BS	NC	5:30
32	Girls BR (back of kitchen)	HS-C	BS	NC	↓
33	Girls BR (back of kitchen)	HS-R	BS	NC	↓
34	Tech Ed 129	HS	OT	NC	5:35
35	Tech Ed 129	DF	DF	C	↓
36	Dance 130	DF	DF	C	5:36
37	Dance 130 Closet	HS	OT	NC	↓
38	Chief Office-BR <i>*used to make a pot of coffee</i>	HS	BS	NC	5:37
39	Boys Locker Room	DF-L	DF	C	5:40
40	Boys Locker Room	DF-R	DF	C	↓
41	Boys Locker Room	HS-L	BS	NC	↓
42	Boys Locker Room	HS-C	BS	NC	↓
43	Boys Locker Room	<i>NW</i> HS-R	BS	NC	<i>NW</i>
44	Boys Locker Room	HS	BS	NC	↓
45	Girls Locker Room	DF-L	DF	C	5:44
46	Girls Locker Room	DF-R	DF	C	↓
47	Girls Locker Room	HS-L	BS	NC	↓
48	Girls Locker Room	HS-C	BS	NC	↓
49	Girls Locker Room	HS-R	BS	NC	↓
50	Girls Locker Room	HS	BS	NC	↓
51	Gym Hall Fountain	DF	DF	C	<i>NW</i>
52	Outside Girls BR	HS-L	BS	NC	5:50
53	Outside Girls BR	HS-R <i>NW</i>	BS	NC	<i>NW</i>
54	Outside Boys BR	HS-L <i>NW</i>	BS	NC	<i>NW</i>
55	Outside Boys BR	HS-R <i>3:50</i>	BS	NC	<i>NW</i> 5:50
56	123 Digital Pallet	HS	OT	NC	5:56
57	123 Digital Pallet	DF	DF	C	↓
58	123 Digital Pallet Closet	HS-L	OT	NC	5:57
59	123 Digital Pallet Closet	<i>*dripping</i> HS-R	OT	NC	↓
60	Hall Fountain (outside 123)	DF	DF	C	5:59
61	Boys BR (across from 122)	HS-L	BS	NC	6:00

Magothy River MS (2243) Martel No. 40083

1052, 241 Peninsula Farm Rd, Arnold, MD 21012

62	Boys BR (across from 122)	HS-C	BS	NC	6:00
63	Boys BR (across from 122)	HS-R	BS	NC	↓
64	Girls BR (across from 122)	HS-L	BS	NC	
65	Girls BR (across from 122)	HS-C	BS	NC	
66	Girls BR (across from 122)	HS-R	BS	NC	
67	122 Closet	HS	OT	NC	
68	Media BR	HS	BS	NC	6:05
69	Boys BR (outside 107)	HS-L	BS	NC	6:07
70	Boys BR (outside 107)	HS-C	BS	NC	↓
71	Boys BR (outside 107)	HS-R	BS	NC	
72	Girls BR (outside 107)	HS-L	BS	NC	
73	Girls BR (outside 107)	HS-C	BS	NC	
74	Girls BR (outside 107)	HS-R	BS	NC	
75	Hall Fountain (next to 111 Classroom)	DF-L	DF	C	6:09
76	Hall Fountain (next to 111 Classroom)	DF-R	DF	C	↓
77	Students Service BR-L	HS	BS	NC	6:11
78	Students Service BR-R	HS	BS	NC	↓
79	Boys BR (next to 207)	HS-L	BS	NC	6:21
80	Boys BR (next to 207)	HS-C	BS	NC	not working
81	Boys BR (next to 207)	HS-R	BS	NC	↓
82	Girls BR (next to 207)	HS-L	BS	NC	
83	Girls BR (next to 207)	HS-C	BS	NC	
84	Girls BR (next to 207)	HS-R	BS	NC	
85	Hall Fountain (across from 212)	DF-L	DF	C	
86	Hall Fountain (across from 212)	DF-R	DF	C	↓
87	Teachers Lounge BR-L	HS	BS	NC	6:24
88	Teachers Lounge BR-R	HS	BS	NC	↓ Dripping
89	Hall Fountain (next to 219)	DF	DF	C	6:26
90	Boys BR (next to 219)	HS-L	BS	NC	↓
91	Boys BR (next to 219)	HS-C	BS	NC	
92	Boys BR (next to 219)	HS-R	BS	NC	
93	Girls BR (next to 219)	HS-L	BS	NC	
94	Girls BR (next to 219)	HS-C	BS	NC	
95	Girls BR (next to 219)	HS-R	BS	NC	
96	Special Ed 222	HS	OT	NC	
97	Art 221	HS-L	OT	NC	6:30

Magothy River MS (2243) Martel No. 40083

1052, 241 Peninsula Farm Rd, Arnold, MD 21012

98	Art 221	HS-R	OT	NC	6:30
99	Art 221	HS	OT	NC	↓
100	FAQ-Home EEC 2R2 (by dryer)	Sink	HE	C	6:34
101	FAQ-Home EEC 2R2 (start at door-going clockwise)	Sink-1	HE	C	↓
102	FAQ-Home EEC 2R2	Sink-2	HE	C	↓
103	FAQ-Home EEC 2R2	Sink-3	HE	C	↓
104	FAQ-Home EEC 2R2	Sink-4	HE	C	↓
105	FAQ-Home EEC 2R2	Sink-5	HE	C	↓
106	FAQ-Home EEC 2R2	Sink-6	HE	C	6:36