

Lead in Drinking Water – Public and Nonpublic Schools

IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT(S) **Arnold Elementary School**

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On September 24, 2019, 93 lead water samples were collected from Arnold Elementary School. Of these lead water samples, zero (0) had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings.

ACTION LEVEL (AL)

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the workplace and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.


TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

1. For additional information, please contact **Chris Williams, Brian Wells or Phil Fabian** at **443-770-5950**. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.



AACPS - Operations Division
9034 Ft. Smallwood Road

Tuesday, November 19, 2019

Pasadena, MD 21122

Certificate of Analysis
FINAL

Attention: Chris Williams; Brian Wells

Report for Lab No: 48001.

Arnold ES (2052)

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 9212

Sampling by Martel personnel on September 24, 2019.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48001	000001	Lounge---B100 C Conference Room Faucet, Cold [TL--C]				09/24/2019 05:03
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	11/07/2019 16:39 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48001	000003	Classroom---B100 E Workroom Faucet, Cold [TL--C]				09/24/2019 05:04
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	11/07/2019 16:51 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48001	000004	Nurses Office---B106 Health Room Drinking Water Fountain [09/24/2019 05:07
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	11/07/2019 16:53 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48001	000005	Nurses Office---B106 Health Room Faucet, Cold [NO--C]				09/24/2019 05:07
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	11/07/2019 16:56 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48001	000006	Nurses Office---B106 Health Room (next to eye wash) Faucet,				09/24/2019 05:08
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	11/07/2019 16:58 BJ
MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48001	000007	Nurses Office---B106 X Exam Health Room Drinking Water				09/24/2019 05:11
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial



MARTEL NO. 48001 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000007 Nurses Office---B106 X Exam Health Room Drinking Water 09/24/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.32	ug/l	EPA .200.8	2	11/07/2019 17:01 BJ

MARTEL NO. 48001 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000008 Nurses Office---B106 X Exam Health Room Faucet, Cold 09/24/2019 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 17:03 BJ

MARTEL NO. 48001 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000009 Nurses Office---B106 C Exam Health Room Drinking Water 09/24/2019 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 17:06 BJ

MARTEL NO. 48001 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000010 Nurses Office---B106 C Exam Health Room Faucet, Cold 09/24/2019 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 17:08 BJ

MARTEL NO. 48001 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000011 Nurses Office---B106 Health Room BR - Right Faucet, Cold [09/24/2019 05:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 17:11 BJ

MARTEL NO. 48001 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000012 Nurses Office---B106 Health Room BR - Left Faucet, Cold [B 09/24/2019 05:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 17:21 BJ

MARTEL NO. 48001 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000013 Classroom---B108 Drinking Water Fountain [CF--C] 09/24/2019 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 17:26 BJ

MARTEL NO. 48001 CLIENT SAMPLE IDENTIFICATION Sample Date/Time
000014 Classroom---B108 Faucet, Cold [CS--C] 09/24/2019 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 17:29 BJ



Certificate of Analysis

MARTEL NO. 48001 000015 CLASSROOM---C100 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 17:31 BJ

MARTEL NO. 48001 000016 CLASSROOM---C100 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 05:17

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 17:34 BJ

MARTEL NO. 48001 000018 CLASSROOM---C102 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 17:36 BJ

MARTEL NO. 48001 000019 CLASSROOM---C102 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 05:18

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 17:39 BJ

MARTEL NO. 48001 000021 CLASSROOM---C104 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 17:41 BJ

MARTEL NO. 48001 000022 CLASSROOM---C104 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 17:44 BJ

MARTEL NO. 48001 000024 CLASSROOM---C106 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 17:46 BJ

MARTEL NO. 48001 000025 CLASSROOM---C106 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 17:54 BJ



Certificate of Analysis

MARTEL NO. 48001 000027 CLIENT SAMPLE IDENTIFICATION Classroom---C108 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:01 BJ

MARTEL NO. 48001 000028 CLIENT SAMPLE IDENTIFICATION Classroom---C108 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 05:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:04 BJ

MARTEL NO. 48001 000030 CLIENT SAMPLE IDENTIFICATION Classroom---D100 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 05:26

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:06 BJ

MARTEL NO. 48001 000031 CLIENT SAMPLE IDENTIFICATION Classroom---D100 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 05:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:09 BJ

MARTEL NO. 48001 000033 CLIENT SAMPLE IDENTIFICATION Classroom---D102 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 05:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:11 BJ

MARTEL NO. 48001 000034 CLIENT SAMPLE IDENTIFICATION Classroom---D102 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 05:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:14 BJ

MARTEL NO. 48001 000036 CLIENT SAMPLE IDENTIFICATION Classroom---D104 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 05:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:16 BJ

MARTEL NO. 48001 000037 CLIENT SAMPLE IDENTIFICATION Classroom---D104 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 05:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:19 BJ



Certificate of Analysis

MARTEL NO. 48001 000039 CLIENT SAMPLE IDENTIFICATION Classroom---D106 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 05:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:21 BJ

MARTEL NO. 48001 000040 CLIENT SAMPLE IDENTIFICATION Classroom---D106 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 05:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:31 BJ

MARTEL NO. 48001 000042 CLIENT SAMPLE IDENTIFICATION Classroom---D108 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 05:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:36 BJ

MARTEL NO. 48001 000043 CLIENT SAMPLE IDENTIFICATION Classroom---D108 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 05:34

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:39 BJ

MARTEL NO. 48001 000046 CLIENT SAMPLE IDENTIFICATION Classroom---A100 Before/After Care Drinking Water Fountain Sample Date/Time 09/24/2019 05:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:41 BJ

MARTEL NO. 48001 000047 CLIENT SAMPLE IDENTIFICATION Classroom---A100 Before/After Care Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 05:37

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:44 BJ

MARTEL NO. 48001 000054 CLIENT SAMPLE IDENTIFICATION Hallway---Fountain (across from A103 Café) - Left Top Drinki Sample Date/Time 09/24/2019 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:46 BJ

MARTEL NO. 48001 000055 CLIENT SAMPLE IDENTIFICATION Hallway---Fountain (across from A103 Café) - Left Bottom Dri Sample Date/Time 09/24/2019 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:49 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48001 000056	Hallway---Fountain (across from A103 Café) - Right Drinking	09/24/2019 05:40			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:51 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48001 000060	Classroom---A106 Drinking Water Fountain [CF--C]	09/24/2019 05:41			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:54 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48001 000061	Classroom---A106 Faucet, Cold [CS--C]	09/24/2019 05:41			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 18:56 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48001 000062	Classroom---A108 Drinking Water Fountain [CF--C]	09/24/2019 05:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 19:04 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48001 000063	Classroom---A108 Faucet, Cold [CS--C]	09/24/2019 05:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 19:11 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48001 000064	Kitchen---Kitchen - Dual Sink Faucet, Cold [KS--C]	09/24/2019 05:48			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 19:14 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48001 000067	Kitchen---Kitchen - Tri Sink - Left Faucet, Cold [KS--C]	09/24/2019 05:48			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 19:16 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48001 000068	Kitchen---Kitchen - Tri Sink - Right Faucet, Cold [KS--C]	09/24/2019 05:48			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 19:19 BJ



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48001	000075	Gymnasium---Gym Fountain - Left Top Drinking Water Fountain				09/24/2019 05:51
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	11/07/2019 19:21 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48001	000076	Gymnasium---Gym Fountain - Left Bottom Drinking Water				09/24/2019 05:51
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	11/07/2019 19:24 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48001	000077	Gymnasium---Gym Fountain - Left Right Drinking Water Fountai				09/24/2019 05:51
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	11/07/2019 19:26 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48001	000078	Lounge---B204 A Media Work Room Faucet, Cold [TL--C]				09/24/2019 05:56
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	11/07/2019 19:29 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48001	000081	Classroom---C200 Drinking Water Fountain [CF--C]				09/24/2019 06:04
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	11/07/2019 19:31 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48001	000082	Classroom---C200 Faucet, Cold [CS--C]				09/24/2019 06:04
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	11/07/2019 19:41 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48001	000083	Classroom---C202 Drinking Water Fountain [CF--C]				09/24/2019 06:08
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	11/07/2019 19:46 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48001	000084	Classroom---C202 Faucet, Cold [CS--C]				09/24/2019 06:08
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead		<2	ug/l	EPA .200.8	2	11/07/2019 19:49 BJ



Certificate of Analysis

MARTEL NO. 48001 000085 CLASSROOM---C210 DRINKING WATER FOUNTAIN [CF--C] SAMPLE DATE/TIME 09/24/2019 06:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 19:51 BJ

MARTEL NO. 48001 000086 CLASSROOM---C210 FAUCET, COLD [CS--C] SAMPLE DATE/TIME 09/24/2019 06:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 19:54 BJ

MARTEL NO. 48001 000087 CLASSROOM---C212 DRINKING WATER FOUNTAIN [CF--C] SAMPLE DATE/TIME 09/24/2019 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 19:56 BJ

MARTEL NO. 48001 000088 CLASSROOM---C212 FAUCET, COLD [CS--C] SAMPLE DATE/TIME 09/24/2019 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 19:59 BJ

MARTEL NO. 48001 000089 CLASSROOM---C213 DRINKING WATER FOUNTAIN [CF--C] SAMPLE DATE/TIME 09/24/2019 06:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 20:01 BJ

MARTEL NO. 48001 000090 CLASSROOM---C213 FAUCET, COLD [CS--C] SAMPLE DATE/TIME 09/24/2019 06:13

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 20:04 BJ

MARTEL NO. 48001 000091 CLASSROOM---C211 DRINKING WATER FOUNTAIN [CF--C] SAMPLE DATE/TIME 09/24/2019 06:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 20:06 BJ

MARTEL NO. 48001 000092 CLASSROOM---C211 FAUCET, COLD [CS--C] SAMPLE DATE/TIME 09/24/2019 06:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 20:14 BJ



Certificate of Analysis

MARTEL NO. 48001 000096 CLIENT SAMPLE IDENTIFICATION Hallway---Hall Fountain (across from C206) - Left Top Drinki Sample Date/Time 09/24/2019 06:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 20:22 BJ

MARTEL NO. 48001 000097 CLIENT SAMPLE IDENTIFICATION Hallway---Hall Fountain (across from C206) - Left Bottom Dri Sample Date/Time 09/24/2019 06:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 20:24 BJ

MARTEL NO. 48001 000098 CLIENT SAMPLE IDENTIFICATION Hallway---Hall Fountain (across from C206) - Right Drinking Sample Date/Time 09/24/2019 06:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 20:27 BJ

MARTEL NO. 48001 000102 CLIENT SAMPLE IDENTIFICATION Classroom---C203 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 06:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 20:29 BJ

MARTEL NO. 48001 000103 CLIENT SAMPLE IDENTIFICATION Classroom---C203 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 06:19

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 20:32 BJ

MARTEL NO. 48001 000104 CLIENT SAMPLE IDENTIFICATION Classroom---C201 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 20:34 BJ

MARTEL NO. 48001 000105 CLIENT SAMPLE IDENTIFICATION Classroom---C201 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 06:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 20:37 BJ

MARTEL NO. 48001 000106 CLIENT SAMPLE IDENTIFICATION Classroom---D201 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 06:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 20:39 BJ



MARTEL NO. 48001 000107 CLIENT SAMPLE IDENTIFICATION Classroom---D201 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 06:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 20:42 BJ

MARTEL NO. 48001 000108 CLIENT SAMPLE IDENTIFICATION Classroom---D203 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 06:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 20:52 BJ

MARTEL NO. 48001 000109 CLIENT SAMPLE IDENTIFICATION Classroom---D203 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 06:23

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 20:57 BJ

MARTEL NO. 48001 000113 CLIENT SAMPLE IDENTIFICATION Hallway---Hall Fountain (across from D204) - Left Top Drinki Sample Date/Time 09/24/2019 06:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 20:59 BJ

MARTEL NO. 48001 000114 CLIENT SAMPLE IDENTIFICATION Hallway---Hall Fountain (across from D204) - Left Bottom Dri Sample Date/Time 09/24/2019 06:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:02 BJ

MARTEL NO. 48001 000115 CLIENT SAMPLE IDENTIFICATION Hallway---Hall Fountain (across from D204) - Right Drinking Sample Date/Time 09/24/2019 06:27

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:04 BJ

MARTEL NO. 48001 000119 CLIENT SAMPLE IDENTIFICATION Classroom---D209 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 06:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:07 BJ

MARTEL NO. 48001 000120 CLIENT SAMPLE IDENTIFICATION Classroom---D209 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 06:28

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:09 BJ



MARTEL NO. 48001 000121 CLIENT SAMPLE IDENTIFICATION Classroom---D211 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 06:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:12 BJ

MARTEL NO. 48001 000122 CLIENT SAMPLE IDENTIFICATION Classroom---D211 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 06:29

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:14 BJ

MARTEL NO. 48001 000123 CLIENT SAMPLE IDENTIFICATION Classroom---D212 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 06:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:17 BJ

MARTEL NO. 48001 000124 CLIENT SAMPLE IDENTIFICATION Classroom---D212 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 06:30

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:24 BJ

MARTEL NO. 48001 000125 CLIENT SAMPLE IDENTIFICATION Classroom---D210 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 06:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:32 BJ

MARTEL NO. 48001 000126 CLIENT SAMPLE IDENTIFICATION Classroom---D210 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 06:31

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:35 BJ

MARTEL NO. 48001 000127 CLIENT SAMPLE IDENTIFICATION Classroom---D202 Drinking Water Fountain [CF--C] Sample Date/Time 09/24/2019 06:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:37 BJ

MARTEL NO. 48001 000128 CLIENT SAMPLE IDENTIFICATION Classroom---D202 Faucet, Cold [CS--C] Sample Date/Time 09/24/2019 06:33

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:40 BJ



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48001 000129	Classroom---D200 Drinking Water Fountain [CF--C]	09/24/2019 06:39			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:42 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48001 000130	Classroom---D200 Faucet, Cold [CS--C]	09/24/2019 06:39			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:45 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48001 000133	Classroom---A200 Drinking Water Fountain [CF--C]	09/24/2019 06:00			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:47 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48001 000134	Classroom---A200 Faucet, Cold [CS--C]	09/24/2019 06:42			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:50 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48001 000136	Classroom---A202 Drinking Water Fountain [CF--C]	09/24/2019 06:43			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 21:52 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48001 000137	Classroom---A202 Faucet, Cold [CS--C]	09/24/2019 06:43			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 22:02 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48001 000141	Lounge---A208 Work Room Faucet, Cold [TL--C]	09/24/2019 06:44			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 22:07 BJ

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time			
48001 000142	Lounge---A212 Faculty Faucet, Cold [TL--C]	09/24/2019 06:46			
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	11/07/2019 22:10 BJ



MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
48001	000143	Lounge---A212 Faculty Ice Machine [IM--C]				09/24/2019 06:00	
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial		
Lead	non	operational	EPA .200.8	2	/ /		

Page 13 OF 13

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

stdl.frx

Notes and references:

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date. 40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Anne Arundel County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Start Date/Time: 9-24 5:03 End Date/Time: 9-24 6:46

Sampler/Relinquished By: [Signature] Received at Martel by: [Signature] Date/Time: 9-24 10:30

Arnold ES (2052)

Joyce Lane East, Arnold MD 21012

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE
SAMPLING BETWEEN THE HOURS OF 8PM AND 9PM

Martel Lab
No.

48001

Sample #	Room #	Fixture Type <i>(Sink, Bubbler, Water Fountain, Gooseneck, Ice</i>	Outlet Key Codes	C or NC?	TIME/NOTES
1	Lounge---B100 C Conference Room	Faucet, Cold	TL	C	5:03
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
3	Classroom---B100 E Workroom	Faucet, Cold	TL	C	5:04
4	Nurses Office---B106 Health Room	Drinking Water Fountain	NO	C	5:07
5	Nurses Office---B106 Health Room	Faucet, Cold	NO	C	5:07
6	Nurses Office---B106 Health Room (next to eye wash)	Faucet, Cold	NO	C	5:08
7	Nurses Office---B106 X Exam Health Room	Drinking Water Fountain	NO	C	5:11
8	Nurses Office---B106 X Exam Health Room	Faucet, Cold	NO	C	5:11
9	Nurses Office---B106 C Exam Health Room	Drinking Water Fountain	NO	C	5:12
10	Nurses Office---B106 C Exam Health Room	Faucet, Cold	NO	C	5:12
11	Nurses Office---B106 Health Room BR - Right	Faucet, Cold	BS	C	5:13
12	Nurses Office---B106 Health Room BR - Left	Faucet, Cold	BS	C	5:13
13	Classroom---B108	Drinking Water Fountain	CF	C	5:16
14	Classroom---B108	Faucet, Cold	CS	C	↓
15	Classroom---C100	Drinking Water Fountain	CF	C	5:17
16	Classroom---C100	Faucet, Cold	CS	C	↓
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
18	Classroom---C102	Drinking Water Fountain	CF	C	5:18
19	Classroom---C102	Faucet, Cold	CS	C	↓
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
21	Classroom---C104	Drinking Water Fountain	CF	C	5:20
22	Classroom---C104	Faucet, Cold	CS	C	↓
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
24	Classroom---C106	Drinking Water Fountain	CF	C	5:24
25	Classroom---C106	Faucet, Cold	CS	C	5:24

Arnold ES (2052)

Joyce Lane East, Arnold MD 21012

DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
27	Classroom---C108	Drinking Water Fountain	CF	C	5:25
28	Classroom---C108	Faucet, Cold	CS	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
30	Classroom---D100	Drinking Water Fountain	CF	C	5:26
31	Classroom---D100	Faucet, Cold	CS	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
33	Classroom---D102	Drinking Water Fountain	CF	C	5:28
34	Classroom---D102	Faucet, Cold	CS	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
36	Classroom---D104	Drinking Water Fountain	CF	C	5:31
37	Classroom---D104	Faucet, Cold	CS	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
39	Classroom---D106	Drinking Water Fountain	CF	C	5:33
40	Classroom---D106	Faucet, Cold	CS	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
42	Classroom---D108	Drinking Water Fountain	CF	C	5:34
43	Classroom---D108	Faucet, Cold	CS	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
46	Classroom---A100 Before/After Care	Drinking Water Fountain	CF	C	5:37
47	Classroom---A100 Before/After Care	Faucet, Cold	CS	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
54	Hallway---Fountain (across from A103 Café) - Left Top	Drinking Water Fountain	DF	C	5:40
55	Hallway---Fountain (across from A103 Café) - Left Bottom	Drinking Water Fountain	DF	C	↓
56	Hallway---Fountain (across from A103 Café) - Right	Drinking Water Fountain	DF	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
60	Classroom---A106	Drinking Water Fountain	CF	C	5:41
61	Classroom---A106	Faucet, Cold	CS	C	↓

Arnold ES (2052)

Joyce Lane East, Arnold MD 21012

62	Classroom---A108	Drinking Water Fountain	CF	C	5:44
63	Classroom---A108	Faucet, Cold	CS	C	↓
64	Kitchen---Kitchen - Dual Sink	Faucet, Cold	KS	C	5:18
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
67	Kitchen---Kitchen - Tri Sink - Left	Faucet, Cold	KS	C	5:48
68	Kitchen---Kitchen - Tri Sink - Right	Faucet, Cold	KS	C	↑
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
75	Gymnasium---Gym Fountain - Left Top	Drinking Water Fountain	DF	C	5:51
76	Gymnasium---Gym Fountain - Left Bottom	Drinking Water Fountain	DF	C	↓
77	Gymnasium---Gym Fountain - Left Right	Drinking Water Fountain	DF	C	↓
78	Lounge---B204 A Media Work Room	Faucet, Cold	TL	C	5:56
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
81	Classroom---C200	Drinking Water Fountain	CF	C	6:04
82	Classroom---C200	Faucet, Cold	CS	C	↓
83	Classroom---C202	Drinking Water Fountain	CF	C	6:08
84	Classroom---C202	Faucet, Cold	CS	C	↓
85	Classroom---C210	Drinking Water Fountain	CF	C	6:10
86	Classroom---C210	Faucet, Cold	CS	C	↓
87	Classroom---C212	Drinking Water Fountain	CF	C	6:11
88	Classroom---C212	Faucet, Cold	CS	C	↓
89	Classroom---C213	Drinking Water Fountain	CF	C	6:13
90	Classroom---C213	Faucet, Cold	CS	C	↓
91	Classroom---C211	Drinking Water Fountain	CF	C	6:14
92	Classroom---C211	Faucet, Cold	CS	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
96	Hallway---Hall Fountain (across from C206) - Left Top	Drinking Water Fountain	DF	C	6:16
97	Hallway---Hall Fountain (across from C206) - Left Bottom	Drinking Water Fountain	DF	C	6:16

Arnold ES (2052)

Joyce Lane East, Arnold MD 21012

98	Hallway---Hall Fountain (across from C206) - Right	Drinking Water Fountain	DF	C	
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
102	Classroom---C203	Drinking Water Fountain	CF	C	6:19
103	Classroom---C203	Faucet, Cold	CS	C	↓
104	Classroom---C201	Drinking Water Fountain	CF	C	6:20
105	Classroom---C201	Faucet, Cold	CS	C	↓
106	Classroom---D201	Drinking Water Fountain	CF	C	6:22
107	Classroom---D201	Faucet, Cold	CS	C	↓
108	Classroom---D203	Drinking Water Fountain	CF	C	6:23
109	Classroom---D203	Faucet, Cold	CS	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
113	Hallway---Hall Fountain (across from D204) - Left Top	Drinking Water Fountain	DF	C	6:27
114	Hallway---Hall Fountain (across from D204) - Left Bottom	Drinking Water Fountain	DF	C	↓
115	Hallway---Hall Fountain (across from D204) - Right	Drinking Water Fountain	DF	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
119	Classroom---D209	Drinking Water Fountain	CF	C	6:28
120	Classroom---D209	Faucet, Cold	CS	C	↓
121	Classroom---D211	Drinking Water Fountain	CF	C	6:29
122	Classroom---D211	Faucet, Cold	CS	C	↓
123	Classroom---D212	Drinking Water Fountain	CF	C	6:30
124	Classroom---D212	Faucet, Cold	CS	C	↓
125	Classroom---D210	Drinking Water Fountain	CF	C	6:31
126	Classroom---D210	Faucet, Cold	CS	C	↓
127	Classroom---D202	Drinking Water Fountain	CF	C	6:33
128	Classroom---D202	Faucet, Cold	CS	C	↓
129	Classroom---D200	Drinking Water Fountain	CF	C	6:34
130	Classroom---D200	Faucet, Cold	CS	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
133	Classroom---A200	Drinking Water Fountain	CF	C	

Arnold ES (2052)

Joyce Lane East, Arnold MD 21012

134	Classroom---A200	Faucet, Cold	CS	C	6:42
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
136	Classroom---A202	Drinking Water Fountain	CF	C	6:43
137	Classroom---A202	Faucet, Cold	CS	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
141	Lounge---A208 Work Room	Faucet, Cold	TL	C	6:44
142	Lounge---A212 Faculty	Faucet, Cold	TL	C	6:46
143	Lounge---A212 Faculty	Ice Machine	IM	C	—
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX