

Lead in Drinking Water – Public and Nonpublic Schools

IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT(S) **Bates Middle School**

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On December 6, 2019, twenty-seven (27) lead water samples were collected from Bates Middle School. Of these lead water samples, zero (0) had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings.

ACTION LEVEL (AL)

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These include lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the workplace and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

IMMEDIATE ACTIONS TAKEN

- None

NEXT STEPS

- The water will be retested every three (3) years.

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

1. For additional information, please contact *Chris Williams or Brian Wells* at *443-770-5951*. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.



AACPS - Operations Division
9034 Ft. Smallwood Road

Monday, February 17, 2020

Pasadena, MD 21122

Attention: Chris Williams; Brian Wells

Certificate of Analysis
FINAL

Report for Lab No: 48045.

Bates MS (4043)

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 9212

Sampling by Martel personnel on December 6, 2019.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48045 000006	Hallway---Hall Fountain (outside room 103): Drinking Founta					12/06/2019 04:57
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	02/07/2020 14:48 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48045 000007	Nurses Office---Health - Treatment Room: HS					12/06/2019 04:59
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	02/07/2020 15:01 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48045 000008	Nurses Office---Health - Treatment Room - BR: HS					12/06/2019 04:59
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	<2	ug/l	EPA .200.8	2	02/07/2020 15:04 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48045 000009	Nurses Office---Health Room: HS					12/06/2019 04:59
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	2.33	ug/l	EPA .200.8	2	02/07/2020 15:07 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48045 000010	Nurses Office---Health Room - BR: HS					12/06/2019 04:59
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead	14.4	ug/l	EPA .200.8	2	02/07/2020 15:09 BJ	

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION					Sample Date/Time
48045 000019	Hallway---Hall Fountain (next to room 190): DF					12/06/2019 05:04
Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	



MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
48045 000019	Hallway---Hall Fountain (next to room 190): DF	12/06/2019 05:04
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 15:12 BJ
48045 000020	Hallway---Hall Fountain (across 111): DF	12/06/2019 05:05
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 15:15 BJ
48045 000025	Hallway---Hall Fountain (outside 117): DF	12/06/2019 05:09
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 15:17 BJ
48045 000026	Hallway---Hall Fountain (outside 113): DF	12/06/2019 05:10
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 15:20 BJ
48045 000027	Cafeteria---Café Fountain (Left): DF	12/06/2019 05:11
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 15:23 BJ
48045 000028	Cafeteria---Café Fountain (Right): DF	12/06/2019 05:11
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 15:34 BJ
48045 000031	Kitchen---Kitchen Pot Fill (across from white porcelain): P	12/06/2019 05:14
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 15:39 BJ
48045 000032	Kitchen---Kitchen Tri-Sink (Left): Sink (L)	12/06/2019 05:14
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 15:42 BJ



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
48045 000033	Kitchen---Kitchen Tri-Sink (Right): Sink (R.)	12/06/2019 05:14
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 15:45 BJ
48045 000035	Kitchen---Kitchen Tri-Sink (Left) (Window Side): Sink (L)	12/06/2019 05:15
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 15:47 BJ
48045 000036	Kitchen---Kitchen Tri-Sink (Right) (Window Side): Sink (R.)	12/06/2019 05:15
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 15:50 BJ
48045 000042	Lounge---Teacher's Lounge 111 - Kitchen: HS	12/06/2019 05:06
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 15:53 BJ
48045 000046	Hallway---Hall Fountain (across from 223): DF	12/06/2019 05:20
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 15:56 BJ
48045 000047	Classroom---Media Office: HS	12/06/2019 05:20
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 15:58 BJ
48045 000053	Hallway---Hall Fountain - outside 219: DF	12/06/2019 05:26
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 16:01 BJ
48045 000073	Hallway---Hall Fountain (outside 205): DF	12/06/2019 05:23
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 16:09 BJ



Certificate of Analysis

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
48045 000086	Hallway---Hall Fountain (next to Boys BR - 35): DF	12/06/2019 05:30
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	2.42 ug/l EPA .200.8 2	02/07/2020 16:18 BJ
48045 000096	Hallway---Hall Fountain - next to 49 - Right: DF	12/06/2019 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	non operational EPA .200.8 2	//
48045 000105	Hallway---Hall Fountain - next to 49 - Left: DF	12/06/2019 05:35
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 16:20 BJ
48045 000107	Hallway---Fountain (outside 301): DF	12/06/2019 06:06
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 16:23 BJ
48045 000108	Classroom---303 (island): HS	12/06/2019 06:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	non operational EPA .200.8 2	//
48045 000109	Classroom---303 (island): B	12/06/2019 06:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	non operational EPA .200.8 2	//
48045 000112	Classroom---302 (island): HS	12/06/2019 06:08
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 16:26 BJ
48045 000113	Classroom---302 (island): B	12/06/2019 06:08
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/07/2020 16:28 BJ



Certificate of Analysis

MARTEL NO. 48045 CLIENT SAMPLE IDENTIFICATION 000119 Hallway---Fountain (outside 403): DF Sample Date/Time 12/06/2019 06:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/07/2020 16:31 BJ

Page 5 OF 5

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

stdl.frx

Notes and references:

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date. 40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

All samples tested were in acceptable condition, unless otherwise noted.
The results presented herein relate only to the samples or items tested.


Project Manager

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Anne Arundel County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Start Date/Time: 12/6/19 4:57 End Date/Time: 12/6/19 6:11

Sampler/Relinquished By: *Ann Cpl* Received at Martel by: *[Signature]* Date/Time: 12-6-19 10:50

Bates MS (4043)

701 Chase St, Annapolis, MD 21401

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE
SAMPLING BETWEEN THE HOURS OF 8PM AND 9PM

Martel Lab
No.
48045

Sample #	Room #	Fixture Type <i>(Sink, Bubbler, Water Fountain, Gooseneck, Ice</i>	Outlet Key Codes	C or NC?	TIME/NOTES
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
6	Hallway---Hall Fountain (outside room 103)	Drinking Fountain (DF)	DF	C	4:57
7	Nurses Office---Health - Treatment Room	HS	NO	C	4:59
8	Nurses Office---Health - Treatment Room - BR	HS	BS	C	↓
9	Nurses Office---Health Room	HS	NO	C	↓
10	Nurses Office---Health Room - BR	HS	BS	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
19	Hallway---Hall Fountain (next to room 190)	DF	DF	C	5:04
20	Hallway---Hall Fountain (across 111)	DF	DF	C	5:05
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
25	Hallway---Hall Fountain (outside 117)	DF	DF	C	5:09

Bates MS (4043)

701 Chase St, Annapolis, MD 21401

26	Hallway---Hall Fountain (outside 113)	DF	DF	C	S:10
27	Cafeteria---Café Fountain (Left)	DF	DF	C	S:11
28	Cafeteria---Café Fountain (Right)	DF	DF	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
31	Kitchen---Kitchen Pot Fill (across from white porcelain)	Pot Fill	KS	C	S:14
32	Kitchen---Kitchen Tri-Sink (Left)	Sink (L)	KS	C	↓
33	Kitchen---Kitchen Tri-Sink (Right)	Sink (R.)	KS	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
35	Kitchen---Kitchen Tri-Sink (Left) (Window Side)	Sink (L)	KS	C	S:15
36	Kitchen---Kitchen Tri-Sink (Right) (Window Side)	Sink (R.)	KS	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
42	Lounge---Teacher's Lounge 111 - Kitchen	HS	TL	C	S:06
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
46	Hallway---Hall Fountain (across from 223)	DF	DF	C	S:20
47	Classroom---Media Office	HS	OT	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
53	Hallway---Hall Fountain - outside 219	DF	DF	C	S:26
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX

Bates MS (4043)

701 Chase St, Annapolis, MD 21401

DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
73	Hallway--Hall Fountain (outside 205)	DF	DF	C	5:23
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
86	Hallway--Hall Fountain (next to Boys BR - 35)	DF	DF	C	5:30
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
96	Hallway--Hall Fountain - next to 49 - Right	DF	DF		5:35 ^{12/15}
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX

Bates MS (4043)

701 Chase St, Annapolis, MD 21401

DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
105	Hallway---Hall Fountain - next to 49 - Left	DF	DF	C	S:35
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
107	Hallway---Fountain (outside 301)	DF	DF	C	6:06
108	Classroom---303 (island)	HS	CS	C	NW
109	Classroom---303 (island)	B	CF	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
112	Classroom---302 (island)	HS	CS	C	6:08
113	Classroom---302 (island)	B	CF	C	↓
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
119	Hallway---Fountain (outside 403)	DF	DF	C	6:11