

# Lead in Drinking Water – Public and Nonpublic Schools

## **IMPORTANT NOTICE: ELEVATED WATER SAMPLE RESULT(S)** **Central Elementary School**

### **ELEVATED LEAD WATER SAMPLE RESULT(S)**

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On December 12, 2019, fifty (50) lead water samples were collected from Central Elementary School. Of these lead water samples, six (6) had levels of lead exceeding the action level of 20 parts per billion (ppb) for lead in drinking water in school buildings. The elevated lead results from the sample(s) collected at Central Elementary School are as follows:

- Sample #20 Nurses Office Health Room Bubbler – 43.2ppb
- Sample #59 Classroom 12 Bubbler (left) – 26.9ppb
- Sample #61 Classroom 12 Bubbler (right) – 34.7ppb
- Sample #69 Classroom 15 Bubbler (left) – 50.6ppb
- Sample #72 Classroom 19 Bubbler (left) – 21.8ppb
- Sample #75 Classroom 20 Bubbler (left) – 28ppb

### **ACTION LEVEL (AL)**

The AL is 20 ppb for lead in drinking water in school buildings. The AL is the concentration of lead which, if exceeded, triggers required remediation.

### **HEALTH EFFECTS OF LEAD**

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

### **SOURCES OF HUMAN EXPOSURE TO LEAD**

There are many different sources of human exposure to lead. These include lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the workplace and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

### **IMMEDIATE ACTIONS TAKEN**

- Sample #'s 20, 61, and 72, will be turned off.
- Sample #'s 59, 69 and 75 will remain off.
- Sample #'s 41, 55 and 60 will be turned back on. These fixtures failed the initial lead in water testing. After replacement and retesting, the lead level is now below the action level.

## **NEXT STEPS**

- Sample #'s 20, 61 and 72 will be replaced and retested.
- Sample #'s 59, 69 and 75 will be removed since these outlets have failed twice.

## **TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:**

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

*Please note that boiling the water will not reduce lead levels.*

## **ADDITIONAL INFORMATION**

1. For additional information, please contact *Chris Williams or Brian Wells* at **443-770-5950**. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at [www.epa.gov/lead](http://www.epa.gov/lead). If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.



**AACPS - Operations Division**  
9034 Ft. Smallwood Road

Monday, February 17, 2020

Pasadena, MD 21122

**Certificate of Analysis**  
**FINAL**

**Attention: Chris Williams; Brian Wells**

Report for Lab No: 48053.

Central ES (4112)

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 9212

Sampling by Martel personnel on December 12, 2019.

MARTEL NO.	CLIENT SAMPLE IDENTIFICATION	Sample Date/Time
48053 000001	Office---Office Work Room (old health room): Hand Sink (HS)	12/12/2019 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/10/2020 18:48 BJ
48053 000008	Classroom---HE (across from office area): HS	12/12/2019 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/10/2020 18:56 BJ
48053 000009	Classroom---HE (across from office area): Bubbler (B)	12/12/2019 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/10/2020 18:58 BJ
48053 000014	Lounge---Staff Lounge: HS	12/12/2019 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/10/2020 19:01 BJ
48053 000018	Nurses Office---Health Room BR: HS	12/12/2019 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial
Lead	<2 ug/l EPA .200.8 2	02/10/2020 19:03 BJ
48053 000019	Nurses Office---Health Room : HS	12/12/2019 05:00
Compound	Test Value Test Unit Method Detection Limit	Analysis Date/Time/Initial



# Certificate of Analysis

MARTEL NO. 48053      000019      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
Nurses Office---Health Room : HS      12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 19:06 BJ

MARTEL NO. 48053      000020      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
Nurses Office---Health Room : B      12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	43.2	ug/l*	EPA .200.8	2	02/10/2020 19:08 BJ

MARTEL NO. 48053      000021      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
Hallway---HB (across from Art): HS      12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 19:11 BJ

MARTEL NO. 48053      000022      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
Hallway---HB (across from Art): B      12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	//

MARTEL NO. 48053      000023      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
Classroom---Classroom 30: HS      12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 19:13 BJ

MARTEL NO. 48053      000024      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
Classroom---Classroom 30: B      12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 19:23 BJ

MARTEL NO. 48053      000026      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
Classroom---Classroom 31: HS      12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 19:28 BJ

MARTEL NO. 48053      000027      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time  
Classroom---Classroom 31: B      12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 19:31 BJ



# Certificate of Analysis

MARTEL NO. 48053      000029      Classroom---Classroom 32: HS      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 19:33 BJ

MARTEL NO. 48053      000030      Classroom---Classroom 32: B      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 19:36 BJ

MARTEL NO. 48053      000032      Classroom---Classroom 33: HS      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 19:38 BJ

MARTEL NO. 48053      000033      Classroom---Classroom 33: B      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 19:41 BJ

MARTEL NO. 48053      000035      Classroom---Classroom 34: HS      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	non	operational	EPA .200.8	2	/  /

MARTEL NO. 48053      000036      Classroom---Classroom 34: B      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 19:43 BJ

MARTEL NO. 48053      000038      Classroom---Classroom 35: HS      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 19:46 BJ

MARTEL NO. 48053      000039      Classroom---Classroom 35: B      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 19:54 BJ



# Certificate of Analysis

MARTEL NO. 48053      000041      CLIENT SAMPLE IDENTIFICATION Classroom---Classroom 7: B-L      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	13.0	ug/l	EPA .200.8	2	02/10/2020 20:01 BJ

MARTEL NO. 48053      000042      CLIENT SAMPLE IDENTIFICATION Classroom---Classroom 7: HS      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 20:04 BJ

MARTEL NO. 48053      000043      CLIENT SAMPLE IDENTIFICATION Classroom---Classroom 7: B-R      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	5.87	ug/l	EPA .200.8	2	02/10/2020 20:06 BJ

MARTEL NO. 48053      000045      CLIENT SAMPLE IDENTIFICATION Hallway---Hall Fountain (outside 7): Drinking Fountain (DF)      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 20:09 BJ

MARTEL NO. 48053      000046      CLIENT SAMPLE IDENTIFICATION Classroom---Classroom 8: B-L      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	8.01	ug/l	EPA .200.8	2	02/10/2020 20:11 BJ

MARTEL NO. 48053      000047      CLIENT SAMPLE IDENTIFICATION Classroom---Classroom 8: HS      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 20:14 BJ

MARTEL NO. 48053      000048      CLIENT SAMPLE IDENTIFICATION Classroom---Classroom 8: B-R      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.66	ug/l	EPA .200.8	2	02/10/2020 20:16 BJ

MARTEL NO. 48053      000055      CLIENT SAMPLE IDENTIFICATION Classroom---Classroom 11: B-L      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	19.1	ug/l	EPA .200.8	2	02/10/2020 20:19 BJ



# Certificate of Analysis

MARTEL NO. 48053      000056      Classroom---Classroom 11: HS      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 20:21 BJ

MARTEL NO. 48053      000057      Classroom---Classroom 11: B-R      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 20:31 BJ

MARTEL NO. 48053      000059      Classroom---Classroom 12: B-L      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	26.9	ug/l*	EPA .200.8	2	02/10/2020 20:36 BJ

MARTEL NO. 48053      000060      Classroom---Classroom 12: HS      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	7.77	ug/l	EPA .200.8	2	02/10/2020 20:39 BJ

MARTEL NO. 48053      000061      Classroom---Classroom 12: B-R      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	34.7	ug/l*	EPA .200.8	2	02/10/2020 20:42 BJ

MARTEL NO. 48053      000068      Hallway---Hall Fountain (across from Girls): DF      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 20:44 BJ

MARTEL NO. 48053      000069      Classroom---Classroom 15: B-L      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	50.6	ug/l*	EPA .200.8	2	02/10/2020 20:47 BJ

MARTEL NO. 48053      000070      Classroom---Classroom 15: HS      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.15	ug/l	EPA .200.8	2	02/10/2020 20:49 BJ



# Certificate of Analysis

MARTEL NO. 48053      000071      Classroom---Classroom 15: B-R      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 20:52 BJ

MARTEL NO. 48053      000072      Classroom---Classroom 19: B-L      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	21.8	ug/l*	EPA .200.8	2	02/10/2020 20:54 BJ

MARTEL NO. 48053      000073      Classroom---Classroom 19: HS      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.75	ug/l	EPA .200.8	2	02/10/2020 20:57 BJ

MARTEL NO. 48053      000074      Classroom---Classroom 19: B-R      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.41	ug/l	EPA .200.8	2	02/10/2020 21:04 BJ

MARTEL NO. 48053      000075      Classroom---Classroom 20: B-L      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	28.0	ug/l*	EPA .200.8	2	02/10/2020 21:12 BJ

MARTEL NO. 48053      000076      Classroom---Classroom 20: HS      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 21:15 BJ

MARTEL NO. 48053      000077      Classroom---Classroom 20: B-R      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	4.13	ug/l	EPA .200.8	2	02/10/2020 21:17 BJ

MARTEL NO. 48053      000078      Hallway---Hall Fountain (across from 20): DF      CLIENT SAMPLE IDENTIFICATION      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 21:20 BJ





MARTEL NO. 48053      000087      CLIENT SAMPLE IDENTIFICATION Classroom---Classroom 24: HS-R      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	3.48	ug/l	EPA .200.8	2	02/10/2020 21:22 BJ

MARTEL NO. 48053      000088      CLIENT SAMPLE IDENTIFICATION Classroom---Classroom 24: B      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 21:25 BJ

MARTEL NO. 48053      000089      CLIENT SAMPLE IDENTIFICATION Cafeteria---Café Fountain: DF      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 21:27 BJ

MARTEL NO. 48053      000090      CLIENT SAMPLE IDENTIFICATION Kitchen---Kitchen Dual Sink: Sink      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 21:30 BJ

MARTEL NO. 48053      000092      CLIENT SAMPLE IDENTIFICATION Kitchen---Kitchen Tri-Sink: Sink Left      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 21:32 BJ

MARTEL NO. 48053      000093      CLIENT SAMPLE IDENTIFICATION Kitchen---Kitchen Tri-Sink: Sink Right      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 21:42 BJ

MARTEL NO. 48053      000097      CLIENT SAMPLE IDENTIFICATION Gymnasium---Gym Fountain: DF      Sample Date/Time 12/12/2019 05:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	02/10/2020 21:47 BJ



**Certificate of Analysis**

**Martel Laboratories JDS Inc.**

1025 Cromwell Bridge Road - Baltimore, Maryland 21286  
PH 410-825-7790 FAX 410-821-1054 EMAIL: martel@martellabs.com

AACOP1

Page 8 OF 8  
02/17/2020  
stdl.frx

**Notes and references:**

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date. 40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

\* results exceeded 20.5 ug/l.

All samples tested were in acceptable condition, unless otherwise noted.  
The results presented herein relate only to the samples or items tested.

  
Project Manager

## MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

### Anne Arundel County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Start Date/Time: 12/12/19 5:02am End Date/Time: 12/12/19 5:56am

Sampler/Relinquished By: [Signature] Received at Martel by: [Signature] Date/Time: 12/12/19 1030

Central ES (4112)

130 Stepney Ln, Edgewater, MD 21037

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE  
SAMPLING BETWEEN THE HOURS OF 8PM AND 9PM

Martel Lab  
No.

**48053**

Sample #	Room #	Fixture Type <i>(Sink, Bubbler, Water Fountain, Gooseneck, Ice</i>	Outlet Key Codes	Cor. NC?	TIME/NOTES
1	Office---Office Work Room (old health room)	Hand Sink (HS)	OT	C	5:02am
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
8	Classroom---HE (across from office area)	HS	CS	C	5:03am
9	Classroom---HE (across from office area)	Bubbler (B)	CF	C	5:04am
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
14	Lounge---Staff Lounge	HS	TL	C	5:06am
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
18	Nurses Office---Health Room BR	HS	BS	C	5:07am
19	Nurses Office---Health Room	HS	CS	C	5:07am
20	Nurses Office---Health Room	B	CF	C	5:07am
21	Hallway---HB (across from Art)	HS	CS	C	5:08am
22	Hallway---HB (across from Art)	B	CF	C	not working
23	Classroom---Classroom 30	HS	CS	C	5:11am
24	Classroom---Classroom 30	B	CF	C	5:11am
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX

Central ES (4112)

130 Stepey Ln, Edgewater, MD 21037

26	Classroom---Classroom 31	HS	CS	C	5:19am
27	Classroom---Classroom 31	B	CF	C	5:19am
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
29	Classroom---Classroom 32	HS	CS	C	5:21am
30	Classroom---Classroom 32	B	CF	C	5:21am
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
32	Classroom---Classroom 33	HS	CS	C	5:23am
33	Classroom---Classroom 33	B	CF	C	5:23am
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
35	Classroom---Classroom 34	HS	CS	C	not working
36	Classroom---Classroom 34	B	CF	C	5:25am
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
38	Classroom---Classroom 35	HS	CS	C	5:27am
39	Classroom---Classroom 35	B	CF	C	5:27am
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
41	Classroom---Classroom 7	B-L	DF	C	5:30am
42	Classroom---Classroom 7	HS	CS	C	5:30am
43	Classroom---Classroom 7	B-R	CF	C	5:30am
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
45	Hallway---Hall Fountain (outside 7)	Drinking Fountain (DF)	DF	C	5:31am
46	Classroom---Classroom 8	B-L	DF	C	5:32am
47	Classroom---Classroom 8	HS	CS	C	5:32am
48	Classroom---Classroom 8	B-R	CF	C	5:32am
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
55	Classroom---Classroom 11	B-L	DF	C	5:33am
56	Classroom---Classroom 11	HS	CS	C	5:34am
57	Classroom---Classroom 11	B-R	CF	C	5:34am
DONOTTAKE	XXXXXXXXXXXXXX	XXXXXXXXXXXXXX			XXXXXX
59	Classroom---Classroom 12	B-L	DF	C	5:36am
60	Classroom---Classroom 12	HS	CS	C	5:36am
61	Classroom---Classroom 12	B-R	CF	C	5:36am

covered in duct tape

Central ES (4112)

130 Stepney Ln, Edgewater, MD 21037

DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
68	Hallway---Hall Fountain (across from Girls)	DF	DF	C	5:37am
69	Classroom---Classroom 15	B-L	DF	C	5:39am
70	Classroom---Classroom 15	HS	CS	C	5:39am
71	Classroom---Classroom 15	B-R	CF	C	5:39am
72	Classroom---Classroom 19	B-L	DF	C	5:42am
73	Classroom---Classroom 19	HS	CS	C	5:42am
74	Classroom---Classroom 19	B-R	CF	C	5:42am
75	Classroom---Classroom 20	B-L	DF	C	5:44am
76	Classroom---Classroom 20	HS	CS	C	5:44am
77	Classroom---Classroom 20	B-R	CF	C	5:44am
78	Hallway---Hall Fountain (across from 20)	DF	DF	C	5:46am
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
87	Classroom---Classroom 24	HS-R	CS	C	5:47am
88	Classroom---Classroom 24	B	CF	C	5:47am
89	Cafeteria---Café Fountain	DF	DF	C	5:49am
90	Kitchen---Kitchen Dual Sink	Sink	KS	C	5:50am
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
92	Kitchen---Kitchen Tri-Sink	Sink Left	KS	C	5:51am
93	Kitchen---Kitchen Tri-Sink	Sink Right	KS	C	5:51am
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
DONOTTAKE	XXXXXXXXXXXXX	XXXXXXXXXXXXX			XXXXXX
97	Gymnasium---Gym Fountain	DF	DF	C	5:56am