

Lead in Drinking Water – Public and Nonpublic Schools

Updated in response to legislation effective as of June 1, 2021

IMPORTANT NOTICE: ELEVATED LEAD WATER SAMPLE RESULT(S) **Hillsmere Elementary School**

ELEVATED LEAD WATER SAMPLE RESULT(S)

All Maryland public and nonpublic schools are required to sample all drinking water outlets for the presence of lead pursuant to the Code of Maryland Regulations. On September 19, 2023, forty-nine (49) lead water samples were collected from Hillsmere Elementary School. Of these lead water samples, zero (0) had levels of lead exceeding the State's revised action level of 5 parts per billion (ppb) (*formerly 20 ppb; 5 ppb effective June 1, 2021*) for lead in drinking water in school buildings.

ACTION LEVEL (AL)

Effective June 1, 2021, the State's AL for lead in drinking water samples collected from outlets in school buildings has been lowered to 5 ppb. The AL is the concentration of lead which, if exceeded, triggers required remediation of drinking water outlets.

HEALTH EFFECTS OF LEAD

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Lead is stored in the bones and it can be released later in life. During pregnancy, the fetus receives lead from the mother's bones, which may affect brain development. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

SOURCES OF HUMAN EXPOSURE TO LEAD

There are many different sources of human exposure to lead. These sources include: lead-based paint, lead-contaminated dust or soil, some plumbing materials, certain types of pottery, pewter, brass fixtures, food, and cosmetics, exposure in the workplace and exposure from certain hobbies, brass faucets, fittings, and valves. According to the Environmental Protection Agency (EPA), 10 to 20 percent of a person's potential exposure to lead may come from drinking water, while for an infant consuming formula mixed with lead-containing water this may increase to 40 to 60 percent.

IMMEDIATE ACTIONS TAKEN

No actions were needed.

NEXT STEPS

N/A

TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER:

1. Run your water to flush out lead: If water hasn't been used for several hours, run water for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using it for drinking or cooking.
2. Use cold water for cooking and preparing baby formula: Lead from the plumbing dissolves more easily into hot water.

Please note that boiling the water will not reduce lead levels.

ADDITIONAL INFORMATION

For additional information, please contact the Environmental, Health and Safety Office at 443-770-5950. For additional information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at www.epa.gov/lead. If you are concerned about exposure; contact your local health department or healthcare provider to find out how you can get your child tested for lead.



1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 martel@martellabs.com

AACPS - Operations Division
9034 Ft. Smallwood Road

Pasadena, MD 21122
Attention: Chris Williams; Brian Wells

Monday, January 8, 2024

Certificate of Analysis
FINAL

Project Information:

Report for Lab No: 70001.

School: Hillsmere ES

Sampling by regulation to Maryland House Bill 270 - Lead in Drinking Water

P.O. Number: PO 21B21062901660

Sampling by Martel personnel on September 19, 2023

References and Important Notes:

SM="Standard Methods for the Examination of Water and Wastewater", American Public Health Association, American Water Works Association, and Water Environment Federation. Year in method code is approved date.
40CFR141=U.S. "Code of Federal Regulations", Title 40, Protection of the Environment, Part 141, National Primary Drinking Water Regulations.

* results exceeded 5.5 ug/l.

Notices:

Chain of Custody Form(s) are attached and are an integral part of this report.
This report will be retained for at least five years and will be disposed of without notice.
Measurement uncertainty for each listed test is available upon request.
The results presented herein relate only to the samples or items tested.
All samples tested were in acceptable condition, unless otherwise noted.

DL2020



Certificate of Analysis

MARTEL NO. 70001 1 CLIENT SAMPLE IDENTIFICATION Lounge 101C Conference Room [TL--C] Sample Date/Time 09/19/2023 05:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 17:12 EK

MARTEL NO. 70001 2 CLIENT SAMPLE IDENTIFICATION Lounge 101F Workroom [TL--C] Sample Date/Time 09/19/2023 05:04

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 17:24 EK

MARTEL NO. 70001 3 CLIENT SAMPLE IDENTIFICATION Classroom 111 [CF--C] Sample Date/Time 09/19/2023 05:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 17:27 EK

MARTEL NO. 70001 4 CLIENT SAMPLE IDENTIFICATION Classroom 113 [CF--C] Sample Date/Time 09/19/2023 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 17:29 EK

MARTEL NO. 70001 5 CLIENT SAMPLE IDENTIFICATION Classroom 115 [CF--C] Sample Date/Time 09/19/2023 05:11

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 17:32 EK

MARTEL NO. 70001 6 CLIENT SAMPLE IDENTIFICATION Classroom 122 [CF--C] Sample Date/Time 09/19/2023 05:12

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 17:34 EK

MARTEL NO. 70001 7 CLIENT SAMPLE IDENTIFICATION Classroom 120 [CF--C] Sample Date/Time 09/19/2023 05:14

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 17:36 EK

MARTEL NO. 70001 8 CLIENT SAMPLE IDENTIFICATION Classroom 118 [CF--C] Sample Date/Time 09/19/2023 05:15

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 17:39 EK

Martel Laboratories JDS Inc.

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 martel@martellabs.com

AACOP1

01/08/2024

P 02



Certificate of Analysis

MARTEL NO. 70001 9 CLIENT SAMPLE IDENTIFICATION Lounge 108 Nursing [TL--C] Sample Date/Time 09/19/2023 05:16

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 17:41 EK

MARTEL NO. 70001 10 CLIENT SAMPLE IDENTIFICATION Nurses Office 102C Health [NO--C] Sample Date/Time 09/19/2023 05:20

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 17:44 EK

MARTEL NO. 70001 11 CLIENT SAMPLE IDENTIFICATION Nurses Office 102 Health [NO--C] Sample Date/Time 09/19/2023 05:21

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 17:54 EK

MARTEL NO. 70001 12 CLIENT SAMPLE IDENTIFICATION Nurses Office 102 Health BR-Left [NO--C] Sample Date/Time 09/19/2023 05:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	2.89	ug/l	EPA .200.8	2	01/04/2024 17:59 EK

MARTEL NO. 70001 13 CLIENT SAMPLE IDENTIFICATION Nurses Office 102 Health BR-Right [NO--C] Sample Date/Time 09/19/2023 05:22

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 18:01 EK

MARTEL NO. 70001 14 CLIENT SAMPLE IDENTIFICATION Lounge 119 Maker Space [TL--C] Sample Date/Time 09/19/2023 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 18:04 EK

MARTEL NO. 70001 15 CLIENT SAMPLE IDENTIFICATION Lounge 117 C [TL--C] Sample Date/Time 09/19/2023 05:24

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 18:06 EK

MARTEL NO. 70001 16 CLIENT SAMPLE IDENTIFICATION Hallway Foutnatin (across from Boys BR 121)-Left/Top [BF--] Sample Date/Time 09/19/2023 05:25

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 18:09 EK

Martel Laboratories *JDS* Inc.

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 martel@martellabs.com

AACOP1

01/08/2024

P 03



Certificate of Analysis

MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70001	17	Hallway Founatin (across from Boys BR 121)-Left/Bottom [D]				09/19/2023 05:23	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/04/2024 18:11 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70001	18	Hallway Founatin (across from Boys BR 121)-Right [DF--C]				09/19/2023 05:25	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/04/2024 18:14 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70001	19	Classroom 131 [CF--C]				09/19/2023 05:29	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/04/2024 18:16 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70001	20	Classroom 133 [CF--C]				09/19/2023 05:30	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/04/2024 18:18 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70001	21	Classroom 135 [CF--C]				09/19/2023 05:30	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/04/2024 18:26 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70001	22	Classroom 137 [CF--C]				09/19/2023 05:31	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/04/2024 18:33 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70001	23	Classroom 139 [CF--C]				09/19/2023 05:31	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/04/2024 18:36 EK	
MARTEL NO.		CLIENT SAMPLE IDENTIFICATION				Sample Date/Time	
70001	24	Classroom 146 [CF--C]				09/19/2023 05:35	
Compound		Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial	
Lead		<2	ug/l	EPA .200.8	2	01/04/2024 18:38 EK	



Certificate of Analysis

MARTEL NO. 70001 25 CLIENT SAMPLE IDENTIFICATION Classroom 144 [CF--C] Sample Date/Time 09/19/2023 05:35

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 18:41 EK

MARTEL NO. 70001 26 CLIENT SAMPLE IDENTIFICATION Classroom 142 [CF--C] Sample Date/Time 09/19/2023 05:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 18:43 EK

MARTEL NO. 70001 27 CLIENT SAMPLE IDENTIFICATION Classroom 140 [CF--C] Sample Date/Time 09/19/2023 05:36

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 18:45 EK

MARTEL NO. 70001 28 CLIENT SAMPLE IDENTIFICATION Lounge 136 Faculty [TL--C] Sample Date/Time 09/19/2023 05:40

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 18:48 EK

MARTEL NO. 70001 29 CLIENT SAMPLE IDENTIFICATION Classroom 150 Music [CF--C] Sample Date/Time 09/19/2023 05:41

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 18:50 EK

MARTEL NO. 70001 30 CLIENT SAMPLE IDENTIFICATION Classroom 154 [CF--C] Sample Date/Time 09/19/2023 05:42

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 18:53 EK

MARTEL NO. 70001 31 CLIENT SAMPLE IDENTIFICATION Classroom 156 [CF--C] Sample Date/Time 09/19/2023 05:43

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 19:02 EK

MARTEL NO. 70001 32 CLIENT SAMPLE IDENTIFICATION Classroom 160-Left [CF--C] Sample Date/Time 09/19/2023 05:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 19:07 EK

Martel Laboratories JDS Inc.

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 martel@martellabs.com

AACOP1

01/08/2024

P 05

MARTEL NO. 70001 33 CLIENT SAMPLE IDENTIFICATION Classroom 160-Right [CF--C] Sample Date/Time 09/19/2023 05:44

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	01/04/2024 19:10 EK

MARTEL NO. 70001 34 CLIENT SAMPLE IDENTIFICATION Kitchen Tri Sink-Left [KS--C] Sample Date/Time 09/19/2023 05:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	01/04/2024 19:12 EK

MARTEL NO. 70001 35 CLIENT SAMPLE IDENTIFICATION Kitchen Tri Sink-Right [KS--C] Sample Date/Time 09/19/2023 05:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	01/04/2024 19:15 EK

MARTEL NO. 70001 36 CLIENT SAMPLE IDENTIFICATION Kitchen Dual Sink [KS--C] Sample Date/Time 09/19/2023 05:46

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	01/04/2024 19:17 EK

MARTEL NO. 70001 37 CLIENT SAMPLE IDENTIFICATION Gymnasium Foutnatin-Left/Top [BF--C] Sample Date/Time 09/19/2023 05:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	01/04/2024 19:19 EK

MARTEL NO. 70001 38 CLIENT SAMPLE IDENTIFICATION Gymnasium Foutnatin-Left/Bottom [DF--C] Sample Date/Time 09/19/2023 05:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	01/04/2024 19:22 EK

MARTEL NO. 70001 39 CLIENT SAMPLE IDENTIFICATION Gymnasium Foutnatin-Right [DF--C] Sample Date/Time 09/19/2023 05:51

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	01/04/2024 19:24 EK

MARTEL NO. 70001 40 CLIENT SAMPLE IDENTIFICATION Lounge 205 Worker [TL--C] Sample Date/Time 09/19/2023 05:55

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	01/04/2024 19:27 EK



Certificate of Analysis

MARTEL NO. 70001 41 CLIENT SAMPLE IDENTIFICATION Classroom 213 [CF--C] Sample Date/Time 09/19/2023 05:56

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 19:34 EK

MARTEL NO. 70001 42 CLIENT SAMPLE IDENTIFICATION Classroom 215 [CF--C] Sample Date/Time 09/19/2023 05:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 19:41 EK

MARTEL NO. 70001 43 CLIENT SAMPLE IDENTIFICATION Classroom 217 [CF--C] Sample Date/Time 09/19/2023 05:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 19:44 EK

MARTEL NO. 70001 44 CLIENT SAMPLE IDENTIFICATION Classroom 219 [CF--C] Sample Date/Time 09/19/2023 05:57

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 19:46 EK

MARTEL NO. 70001 45 CLIENT SAMPLE IDENTIFICATION Classroom 212 [CF--C] Sample Date/Time 09/19/2023 05:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 19:49 EK

MARTEL NO. 70001 46 CLIENT SAMPLE IDENTIFICATION Classroom 210 [CF--C] Sample Date/Time 09/19/2023 05:58

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 19:51 EK

MARTEL NO. 70001 47 CLIENT SAMPLE IDENTIFICATION Classroom 208 [CF--C] Sample Date/Time 09/19/2023 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 19:54 EK

MARTEL NO. 70001 48 CLIENT SAMPLE IDENTIFICATION Classroom 206 [CF--C] Sample Date/Time 09/19/2023 06:00

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA .200.8	2	01/04/2024 19:56 EK

Martel Laboratories *JDS* Inc.

1025 Cromwell Bridge Road - Baltimore, Maryland 21286
PH 410-825-7790 martel@martellabs.com

AACOP1

01/08/2024

P 07



Certificate of Analysis

MARTEL NO. 70001 49 CLASSROOM 204 [CF--C] Sample Date/Time 09/19/2023 06:03

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	01/04/2024 19:59 EK

MARTEL NO. 70001 34F KITCHEN TRI SINK-LEFT [KS--C] Sample Date/Time 09/19/2023 06:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	01/04/2024 20:01 EK

MARTEL NO. 70001 35F KITCHEN TRI SINK-RIGHT [KS--C] Sample Date/Time 09/19/2023 06:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	01/04/2024 20:11 EK

MARTEL NO. 70001 36F KITCHEN DUAL SINK [KS--C] Sample Date/Time 09/19/2023 06:10

Compound	Test Value	Test Unit	Method	Detection Limit	Analysis Date/Time/Initial
Lead	<2	ug/l	EPA 200.8	2	01/04/2024 20:16 EK

MARTEL Chain of Custody Record

Martel Laboratories JDS Inc., 1025 Cromwell Bridge Rd., Baltimore, MD 21286, (410) 825-7790, FAX (410) 821-1054, email: martel@martellabs.com

Anne Arundel County Public Schools Drinking Water Lead Testing

Bottle Type: 250 ml plastic, preserved with HNO3 Analysis: Lead (EPA 200.8)

Start Date/Time: 9/19/23 0500 End Date/Time: 9/19/23 0615

Sampler/Relinquished By: [Signature] Received at Martel by: [Signature] Date/Time: 9/19/23 1100

Hillsmere ES

3052 Arundel on the Bay Rd, Annapolis, MD 21403

ALL OUTLET WERE FLUSHED THE NIGHT BEFORE
SAMPLING BETWEEN THE HOURS OF 5 PM AND 9PM

Floor

Martel NO:

70001

Martel #	Sample #	Room #	Fixture Type (Sink, Bubbler, Water Fountain, Gooseneck, Ice Machine, Hose Bibb, etc.)	Outlet Key Code	Fixture Type Key	Consumption C or NC?	Time/notes
1	1	Lounge	101C Conference Room	TL	Faucet, Cold	C	1 0504
2	2	Lounge	101F Workroom	TL	Faucet, Cold	C	1 0505
3	3	Classroom	111	CF	Drinking Water Fountain-Bubbler Style	C	1 0510
4	4	Classroom	113	CF	Drinking Water Fountain-Bubbler Style	C	1 0511
5	5	Classroom	115	CF	Drinking Water Fountain-Bubbler Style	C	1 0511
6	6	Classroom	122	CF	Drinking Water Fountain-Bubbler Style	C	1 0512
7	7	Classroom	120	CF	Drinking Water Fountain-Bubbler Style	C	1 0514
8	8	Classroom	118	CF	Drinking Water Fountain-Bubbler Style	C	1 0515
9	9	Lounge	108 Nursing	TL	Faucet, Cold	C	1 0516
10	10	Nurses Office	102C Health	NO	Faucet, Cold	C	1 0520
11	11	Nurses Office	102 Health	NO	Faucet, Cold	C	1 0521
12	12	Nurses Office	102 Health BR-Left	NO	Faucet, Cold	C	1 0522
13	13	Nurses Office	102 Health BR-Right	NO	Faucet, Cold	C	1 0522
14	14	Lounge	119 Maker Space	TL	Faucet, Cold	C	1 0525
15	15	Lounge	117 C	TL	Faucet, Cold	C	1 0524
16	16	Hallway	Fountain (across from Boys BR 121)-Left/Top	BF	Bottle Refill Dispenser/Water Refill Station	C	1 0525
17	17	Hallway	Fountain (across from Boys BR 121)-Left/Bottom	DF	Drinking Water Fountain- Cooler/Chiller Style	C	1 0523
18	18	Hallway	Fountain (across from Boys BR 121)-Right	DF	Drinking Water Fountain- Cooler/Chiller Style	C	1 0525
19	19	Classroom	131	CF	Drinking Water Fountain-Bubbler Style	C	1 0529
20	20	Classroom	133	CF	Drinking Water Fountain-Bubbler Style	C	1 0530
21	21	Classroom	135	CF	Drinking Water Fountain-Bubbler Style	C	1 0530
22	22	Classroom	137	CF	Drinking Water Fountain-Bubbler Style	C	1 0531
23	23	Classroom	139	CF	Drinking Water Fountain-Bubbler Style	C	1 0531

BONNIE

Hillsmere ES

3052 Arundel on the Bay Rd, Annapolis, MD 21403

24	24	Classroom	146	CF	Drinking Water Fountain-Bubbler Style	C	1	0535
25	25	Classroom	144	CF	Drinking Water Fountain-Bubbler Style	C	1	0535
26	26	Classroom	142	CF	Drinking Water Fountain-Bubbler Style	C	1	0536
27	27	Classroom	140	CF	Drinking Water Fountain-Bubbler Style	C	1	536
28	28	Lounge	136 Faculty	TL	Faucet, Cold	C	1	540
29	29	Classroom	150 Music	CF	Drinking Water Fountain-Bubbler Style	C	1	541
30	30	Classroom	154	CF	Drinking Water Fountain-Bubbler Style	C	1	542
31	31	Classroom	156	CF	Drinking Water Fountain-Bubbler Style	C	1	543
32	32	Classroom	160-Left	CF	Drinking Water Fountain-Bubbler Style	C	1	544
33	33	Classroom	160-Right	CF	Drinking Water Fountain-Bubbler Style	C	1	544
34	34	Kitchen	Tri Sink-Left	KS	Faucet, Cold	C	1	546
35	35	Kitchen	Tri Sink-Right	KS	Faucet, Cold	C	1	546
36	36	Kitchen	Dual Sink	KS	Faucet, Cold	C	1	546
37	37	Gymnasium	Fountain-Left/Top	BF	Bottle Refill Dispenser/Water Refill Station	C	1	551
38	38	Gymnasium	Fountain-Left/Bottom	DF	Drinking Water Fountain Cooler/Chiller Style	C	1	557
39	39	Gymnasium	Fountain-Right	DF	Drinking Water Fountain Cooler/Chiller Style	C	1	557
40	40	Lounge	205 Worker	TL	Faucet, Cold	C	2	555
41	41	Classroom	213	CF	Drinking Water Fountain-Bubbler Style	C	2	556
42	42	Classroom	215	CF	Drinking Water Fountain-Bubbler Style	C	2	557
43	43	Classroom	217	CF	Drinking Water Fountain-Bubbler Style	C	2	557
44	44	Classroom	219	CF	Drinking Water Fountain-Bubbler Style	C	2	557
45	45	Classroom	212	CF	Drinking Water Fountain-Bubbler Style	C	2	558
46	46	Classroom	210	CF	Drinking Water Fountain-Bubbler Style	C	2	58
47	47	Classroom	208	CF	Drinking Water Fountain-Bubbler Style	C	2	600
48	48	Classroom	206	CF	Drinking Water Fountain-Bubbler Style	C	2	600
49	49	Classroom	204	CF	Drinking Water Fountain-Bubbler Style	C	2	603
50	34	Kitchen	Tri Sink-Left	KS	Faucet, Cold	C		FLUSH 610
51	35	Kitchen	Tri Sink-Right	KS	Faucet, Cold	C		FLUSH 610
52	36	Kitchen	Dual Sink	KS	Faucet, Cold	C		FLUSH 610